

MPR ASSOCIATES, INC.

June 28, 1982

Mr. Thomas Cheng
Systematic Evaluation Program Branch
U. S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, Maryland 20014

Subject: Oyster Creek Nuclear Generating Station,
Systematic Evaluation Program (SEP)

Dear Mr. Cheng:

At the request of GPU Nuclear (Mr. Y. Nagai), we are enclosing the results of our review and comparison of the control rod drive (CRD) pump discharge line as-built drawings with the analytical model used by EG&G in their analysis of this piping. Included in the enclosure is a marked-up copy of the GPU Nuclear Sketch (SK-F-M-0020) showing the CRD pump discharge as-built geometry and support locations with corresponding locations of node numbers used in the EG&G model (marked in red) and five sheets of CRD as-built support detail drawings (SK-F-5-0028 Sheets 1 through 5). Table 1 in the enclosure is a summary of as-built piping geometry and support locations compared to the modeled locations. The Table 1 summary references the node numbers that are marked on the enclosed sketch. Table 2 in the enclosure is a summary of the as-built support information (support type and direction) compared to modeled support input.

Results of the review and comparison are summarized as follows:

1. The piping system modeled by EG&G starts at the elbow of the CRD pump discharge line. Seven and one half inches of piping from the pump discharge nozzle to the elbow was left out. This can be seen by looking at nodes 5 and 1230 on the marked-up as-built support location sketch. The addition of this pipe section in the EG&G model could reduce stresses by adding local flexibility in the area of the socket weld-elbow.

8209020276 820831
PDR ADOCK 05000219
P PDR

Mr. Yoshito Nagai

-2-

June 28, 1982

2. The piping system modeled by EG&G does not model the one inch recirculation lines coming out of the discharge line approximately 5-1/2 feet above the pump anchor points. This can be seen at nodes 45 and 1195 on the marked-up as-built support location sketch. The addition of the recirculation lines could provide both vertical and horizontal support which is not included in the EG&G model.
3. The U-bolt type supports modeled by EG&G do not take into account friction between the bolt and piping for the direction parallel to the pipe. An example is shown on the marked-up as-built support location sketch, for a U-bolt support at node 1105, where the system is assumed to be free to move in the X-direction. This very conservative assumption should be re-evaluated and some credit for friction in these supports considered.
4. Geometry variations from the as-built locations vary significantly from the modeled system starting at node location number 235. The as-built dimensions show the piping system turning through a 45 degree turn where the modeled system does not. The maximum geometry variations from as-built drawings, from Table 1, are as follows:

| <u>Maximum X-Direction Variation</u> | <u>Maximum Y-Direction Variation</u> | <u>Maximum Z-Direction Variation</u> |
|--|--|--|
| 5 ft at Node 1065 | 5 ft at Node 410 | 8 ft at Node 585 |

5. The piping system modeled by EG&G fails to model eight supports at various points along the piping system. Piping supports that were not modeled by EG&G are shown in the marked-up as-built support location sketch by red circled letters (B, D, E, F, G, H, I, and J).

At your request, copies of this letter and enclosure are being transmitted directly to EG&G, Idaho, Mr. Keith Morton.

MPR ASSOCIATES, INC.


Mr. Yoshito Nagai

-3-

June 28, 1982

Please contact us if you have any questions on the attached.

Sincerely,



Wm. R. Schmidt

Enclosure

cc: Y. Nagai, GPUN
K. Morton, EG&G

TABLE 1

SUMMARY OF AS-BUILT PIPING AND SUPPORT LOCATIONS
COMPARED TO MODELED LOCATIONS

Page 1 of 3

| NODE POINT | AS-BUILT LOCATIONS | | | MODELED LOCATIONS | | |
|------------|--------------------|-----------|-----------|-------------------|-----------|-----------|
| | X (ft) | Y (ft) | Z (ft) | X (ft) | Y (ft) | Z (ft) |
| *5 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| *1230 | 6.167 | 0.0 | 0.0 | 6.167 | 0.0 | 0.0 |
| 30 | .167 | 5.208 | 0.0 | .167 | 4.290 | 0.0 |
| *35 | .167 | 5.208 | - | .167 | 4.290 | -.75 |
| 1205 | 6.334 | 5.208 | 0.0 | 6.334 | 4.290 | 0.0 |
| *1235 | 6.334 | 5.208 | - | 6.334 | 4.290 | -.75 |
| 45 | .167 | 6.333 | 0.0 | .167 | 6.413 | 0.0 |
| 1195 | 6.334 | 6.333 | 0.0 | 6.334 | 6.413 | 0.0 |
| *55 | .167 | 6.5 | -.458 | .167 | 6.580 | -1.0 |
| *1185 | 6.334 | 6.5 | -.458 | 6.334 | 6.580 | -1.0 |
| 60 | .167 | 6.5 | -1.25 | .167 | 6.580 | -1.5 |
| 1175 | 6.334 | 6.5 | -1.25 | 6.334 | 6.580 | -1.5 |
| *110 | .167 | 6.5 | -8.75 | .167 | 6.580 | -10.0 |
| *1135 | 6.334 | 6.5 | -8.583 | 6.334 | 6.580 | -9.0 |
| *1105 | 3.917 | 6.5 | -10.833 | 3.334 | 6.580 | -11.0 |
| 140 | .167 | 6.5 | -13.75 | .167 | 6.580 | -13.931 |
| 150 | .417 | 6.5 | -14.00 | .264 | 6.580 | -14.167 |
| *170 | .417 | 6.5 | -18.125 | .264 | 6.580 | -18.098 |
| 175 | .417 | 6.5 | -18.583 | .264 | 6.580 | -18.931 |
| *230 | .417 | 16.208 | -18.750 | .264 | 16.580 | -19.098 |
| 235 | .417 | 17.417 | -18.750 | .264 | 17.413 | -19.098 |
| (A) | -3.119 | 17.583 | -22.286 | - | - | - |
| *(B) | -3.119 | 17.583 | -29.786 | - | - | - |
| *295 | -3.119 | 17.583 | -36.953 | .264 | 17.580 | -30.348 |
| *(D) | -3.119 | 17.583 | -40.286 | - | - | - |

Support Location - Refer to Table 2 for support type and direction.

TABLE 1 (CONTINUED)

| SUPPORT POINT | AS-BUILT LOCATIONS | | | MODELED LOCATIONS | | |
|---------------|--------------------|-----------|-----------|-------------------|-----------|-----------|
| | X (ft) | Y (ft) | Z (ft) | X (ft) | Y (ft) | Z (ft) |
| 335 | -3.119 | 17.583 | -42.619 | .264 | 17.580 | -38.181 |
| *360 | -3.119 | 23.500 | -42.786 | .264 | 23.580 | -38.348 |
| *410 | -3.119 | 42.452 | -42.786 | .264 | 37.580 | -38.348 |
| 440 | -3.119 | 46.042 | -42.786 | .264 | 46.413 | -38.348 |
| 460 | -1.354 | 46.208 | -44.551 | 2.716 | 46.580 | -40.800 |
| *470 | -1.104 | 46.208 | -44.551 | 3.765 | 46.580 | -40.849 |
| *495 | 8.854 | 46.208 | -44.551 | 10.765 | 46.580 | -40.849 |
| *(E) | 15.438 | 46.208 | -44.551 | - | - | - |
| *510 | 15.813 | 46.208 | -44.551 | 15.265 | 46.580 | -40.849 |
| *(F) | 21.021 | 46.208 | -45.009 | - | - | - |
| *551 | 21.021 | 46.208 | -45.551 | 25.765 | 46.580 | -41.849 |
| *(G) | 21.021 | 46.208 | -46.468 | - | - | - |
| *580 | 21.021 | 46.208 | -58.718 | 25.765 | 46.580 | -50.015 |
| *585 | 21.021 | 46.208 | -59.593 | 25.765 | 46.580 | -51.515 |
| *635 | 21.021 | 46.208 | -70.801 | 25.765 | 46.580 | -66.515 |
| 650 | 21.021 | 46.208 | -74.301 | 25.765 | 46.580 | -70.946 |
| *660 | 22.082 | 46.208 | -75.528 | 26.826 | 46.580 | -72.076 |
| *(H) | 27.974 | 46.208 | -81.421 | - | - | - |
| *(I) | 31.333 | 46.208 | -84.780 | - | - | - |
| 730 | 38.404 | 46.208 | -91.851 | 41.680 | 46.580 | -86.930 |
| *755 | 46.473 | 46.208 | -95.883 | 46.437 | 46.580 | -89.522 |
| *780 | 51.343 | 46.208 | -97.900 | 53.367 | 46.580 | -92.392 |
| *805 | 56.334 | 46.208 | -99.830 | 58.525 | 46.580 | -94.114 |
| *830 | 59.334 | 46.208 | -99.830 | 63.525 | 46.580 | -94.114 |
| 835 | 59.917 | 46.208 | -99.830 | 64.359 | 46.580 | -94.114 |
| *845 | 60.084 | 45.208 | -99.830 | 64.525 | 45.330 | -94.114 |
| 870 | 60.084 | 39.208 | -99.830 | 64.525 | 40.247 | -94.114 |

Support Location - Refer to Table 2 for support type and direction.

TABLE 1 (CONTINUED)

| DE POINT | AS-BUILT LOCATIONS | | | MODELED LOCATIONS | | |
|----------|--------------------|-----------|-----------|-------------------|-----------|-----------|
| | X (ft) | Y (ft) | Z (ft) | X (ft) | Y (ft) | Z (ft) |
| *900 | 61.141 | 39.041 | -99.830 | 69.525 | 40.080 | -94.114 |
| *920 | 69.375 | 39.041 | -99.830 | 73.525 | 40.080 | -94.114 |
| 925 | 70.084 | 39.041 | -99.830 | 74.359 | 40.080 | -94.114 |
| *945 | 70.250 | 37.499 | -99.830 | 74.525 | 36.830 | -94.114 |
| 960 | 70.250 | 34.791 | -99.830 | 74.525 | 33.747 | -94.114 |
| 971 | 70.250 | 34.624 | -101.225 | 74.525 | 33.580 | -94.864 |
| *1245 | 70.250 | 34.624 | - | 74.692 | 33.580 | -95.322 |
| *(J) | 70.250 | 30.666 | -101.225 | - | - | - |
| 995 | 70.250 | 27.082 | -101.225 | 74.525 | 27.747 | -95.864 |
| 1010 | 70.250 | 26.916 | -102.308 | 74.525 | 27.580 | -95.864 |
| *1250 | 69.417 | 26.916 | -102.308 | 74.317 | 27.580 | -95.864 |
| 1255 | 68.542 | 26.916 | -102.308 | 73.817 | 27.580 | -95.864 |
| *1290 | 65.083 | 26.916 | -102.308 | 69.025 | 27.580 | -95.864 |
| 1020 | 70.250 | 26.916 | -103.641 | 74.525 | 27.580 | -97.198 |
| *1025 | 69.417 | 26.916 | -103.808 | 74.359 | 27.580 | -97.364 |
| 1030 | 68.542 | 26.916 | -103.808 | 73.775 | 27.580 | -97.364 |
| *1065 | 63.542 | 26.916 | -103.808 | 68.525 | 27.580 | -97.364 |
| *1085 | 63.083 | 26.916 | -102.308 | 66.525 | 27.580 | -96.864 |

Support Location - Refer to Table 2 for support type and direction.

TABLE 2

SUMMARY OF AS-BUILT SUPPORT INFORMATION
COMPARED TO THE MODELED SUPPORT INFORMATION

Page 1 of 4

| NODE POINT | AS-BUILT SUPPORTS | | MODELED SUPPORTS | |
|------------|----------------------|-----------------------|----------------------|---|
| | DIRECTION OF SUPPORT | TYPE OF SUPPORT | DIRECTION OF SUPPORT | STIFFNESS OF SUPPORT (lb/in or lb-in/rad) |
| 5 | 1,2,3,4,5,6* | Pump Anchor Pt. | 1,2,3,4,5,6 | Rigid |
| 1230 | 1,2,3,4,5,6 | Pump Anchor Pt. | 1,2,3,4,5,6 | Rigid |
| 35 | 1,2,3 | ** | 1,2,3 | 1 & 2 - $.333 \times 10^3$ 3 - $.7378 \times 10^6$ |
| 1235 | 1,2,3 | ** | 1,2,3 | 1 & 2 - $.333 \times 10^3$ 3 - $.7378 \times 10^6$ |
| 55 | 2 | Spring | 2 | 50 |
| 1185 | 2 | Spring | 2 | 50 |
| 110 | 2 | Hanger | 2 | 10^5 |
| 1135 | 2 | Hanger | 2 | 10^5 |
| 1105 | 1,2,3 | U-Bolt 1 = Pipe*** | 2,3 | 10^5 |
| 170 | 1,2,3 | U-Bolt 3 = Pipe | 1,2 | 10^5 |
| 230 | 1,2,3 | U-Bolt 2 = Pipe | 1,3 | 10^5 |
| (B) | 2 | Hanger | None | - |
| 295 | 1,2,3 | U-Bolt 3 = Pipe | 1,2 | 10^5 |
| (D) | 2 | Hanger | None | - |

TABLE 2 (CONTINUED)

| NODE POINT | AS-BUILT SUPPORTS | | MODELED SUPPORTS | |
|------------|----------------------|------------------------|----------------------|--|
| | DIRECTION OF SUPPORT | TYPE OF SUPPORT | DIRECTION OF SUPPORT | STIFFNESS OF SUPPORT (lb/in or lb-in/rad) |
| 360 | 1,2,3 | U-Bolt 2 = Pipe | 1,3 | 10 ⁵ |
| 410 | 1,2,3 | U-Bolt 2 = Pipe | 1,3 | 10 ⁵ |
| 470 | 2 | Spring | 2 | 50 |
| 495 | 2 | Hanger | 2 | 10 ⁵ |
| (E) | 2 | Hanger | None | - |
| 510 | 1,2,3 | U-Bolt 1 = Pipe | 2,3 | 10 ⁵ |
| (F) | 2 | Hanger | None | - |
| 551 | 2 | Hanger | 2 | 10 ⁵ |
| (G) | 1,2,3 | U-Bolt 3 = Pipe | None | - |
| 580 | 1,2,3 | U-Bolt 3 = Pipe | 1,2 | 10 ⁵ |
| 585 | 2 | Hanger | 2 | 10 ⁵ |
| 635 | 1,2,3 | U-Bolt 3 = Pipe | 1,2 | 10 ⁵ |
| 660 | 2 | Hanger | 2 | 10 ⁵ |
| (H) | 1,2,3 | U-Bolt | None | - |
| (I) | 1,2,3 | U-Bolt | None | - |
| 730 | 2 | Dead Weight Support | 2 | 10 ⁵ |

TABLE 2 (CONTINUED)

| NODE POINT | AS-BUILT SUPPORTS | | MODELED SUPPORTS | |
|------------|----------------------|------------------------|----------------------|--|
| | DIRECTION OF SUPPORT | TYPE OF SUPPORT | DIRECTION OF SUPPORT | STIFFNESS OF SUPPORT (lb/in or lb-in/rad) |
| 755 | 1,2,3,4,5,6 | Concrete Wall | Angled Support | 10^5 |
| 780 | No Support | | Angled Support | 10^5 |
| 805 | 1,2,3 | Pipe Clamp 1 = Pipe | 2,3 | 10^5 |
| 830 | No Support | | 2 | 10^5 |
| 845 | 1,2,3 | U-Bolt 2 = Pipe | 1,3 | 10^5 |
| 900 | 1,2,3 | Pipe Clamp 1 = Pipe | 2,3 | 10^5 |
| 920 | 2 | Spring | 2 | 50 |
| 945 | 1,2,3 | U-Bolt 2 = Pipe | 1,3 | 10^5 |
| (J) | 1,2,3 | U-Bolt 2 = Pipe | None | 10^5 |
| 1025 | 1,2,3 | U-Bolt 1 = Pipe | 2,3 | 10^5 |
| 1250 | 1,2,3 | U-Bolt 1 = Pipe | 2,3 | 10^5 |
| 1065 | 1,2,3 | U-Bolt 1 = Pipe | 2,3 | 10^5 |
| 1290 | 1,2,3,4,5,6 | CRD Filter Pt. | 1,2,3,4,5,6 | Rigid |
| 1085 | 1,2,3,4,5,6 | CRD Filter Pt. | 1,2,3,4,5,6 | Rigid |

TABLE 2 (CONTINUED)

| NODE POINT | AS-BUILT SUPPORTS | | MODELED SUPPORTS | |
|------------|----------------------|-----------------|----------------------|---|
| | DIRECTION OF SUPPORT | TYPE OF SUPPORT | DIRECTION OF SUPPORT | STIFFNESS OF SUPPORT (lb/in or lb-in/rad) |
| 1245 | 1,2,3 | ** | 1,2,3 | 1 & 2 - $.333 \times 10^3$ 3 - $.7378 \times 10^6$ |

* Support Direction

- 1 X Trans lb/in
- 2 Y Trans lb/in
- 3 Z Trans lb/in
- 4 X Rot lb-in/rad
- 5 Y Rot lb-in/rad
- 6 Z Rot lb-in/rad

** = Attached branch piping

*** = (Parallel to)

REVIEW OF THE MPR ASSOCIATES, INC. COMMENTS
ON THE ORIGINAL CRD RETURN LINE ANALYSIS

At the request of GPU Nuclear, MPR Associates, Inc. (MPR) reviewed and made comments on the original analysis of the CRD return line. The following is a review of the MPR comments and their utilization in the current analysis.

Comments 1, 2, and 4 deal with piping geometry variations in the original model. The system was accurately modeled based upon the information available. These geometry variations were not shown on the original isometric drawings. However, they have been incorporated into the current model based upon the as-built drawings.

The third comment indicates that the friction between U-bolts and the piping, parallel to the pipe, should be taken into account. Due to the lack of information concerning frictional values and their behavior during a seismic event, it was deemed appropriate to assume free movement in the axial direction of the pipe at U-bolt locations. This assumption was made for both the original and current analyses.

Comment 5 shows several supports that were not incorporated into the original model. Again, the support configuration was modeled accurately based upon the information available. With the exception of support "J", these supports were not shown on the isometric drawings. For the current analysis, all of these supports have been incorporated except for two. At each of the points designated "E" and "J" the piping is supported off of adjacent piping. The information provided is insufficient to determine the response of the adjacent piping during a seismic event, and its effects upon the CRD return line. As shown in the results, the stresses are very low at these points, thus leaving a margin of safety in the event the adjacent piping might cause adverse effects.