

Component & Materials Engineering Division		Project No.: 9140-67	Calculation No.: CMED-058057
		Project Name/Station/Unit: Zion Station Units 1 & 2	
		Client: Commonwealth Edison Company	Spec. No.: -
<input checked="" type="checkbox"/> Safety-Related <input type="checkbox"/> Non-Safety-Related		Calculation Title/Purpose: The purpose of this calculation is to evaluate the structural integrity and mounting details adequacy of the Portable Flame and Smoke Detector (PFSD) Sentry Units.	
REV.	DESCRIPTION	RESPONSIBILITY	DATE
00	ORIGINAL ISSUE	PREPARER: <i>A. H. Bejanpour</i> A. H. Bejanpour	12/29/93
	Review Method: Detail Review	REVIEWER: <i>M. Hassabaila</i> M. Hassabaila	12/29/93
	Status: Is Input Verified ? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	APPROVER: <i>M. H. Sanwarwalla</i> M. H. Sanwarwalla	12.29.93
	Review Method:	PREPARER:	
	Status: Is Input Verified ? <input type="checkbox"/> Yes <input type="checkbox"/> No	REVIEWER:	
	Review Method:	APPROVER:	
	Status: Is Input Verified ? <input type="checkbox"/> Yes <input type="checkbox"/> No	PREPARER:	
	Review Method:	REVIEWER:	
	Status: Is Input Verified ? <input type="checkbox"/> Yes <input type="checkbox"/> No	APPROVER:	
	Review Method:	PREPARER:	
	Status: Is Input Verified ? <input type="checkbox"/> Yes <input type="checkbox"/> No	REVIEWER:	
	Review Method:	APPROVER:	
	Status: Is Input Verified ? <input type="checkbox"/> Yes <input type="checkbox"/> No	PREPARER:	
	Review Method:	REVIEWER:	
	Status: Is Input Verified ? <input type="checkbox"/> Yes <input type="checkbox"/> No	APPROVER:	

9402230146 940211
 PDR ADOCK 05000295
 F PDR

Client	Commonwealth Edison Co.
Project	Zion Station Unit(s) 1 & 2
Proj. No.	9140-67 Equip.

Prepared by	<i>A. Bejzypom</i>	Date	12/29/93
Reviewed by	<i>M. Hamelick</i>	Date	12/29/93
Approved by	<i>[Signature]</i>	Date	12.29.93

1.0 PURPOSE

The purpose of this calculation is to evaluate the structural integrity and mounting details adequacy of the Portable Flame and Smoke Detector (PFSD) Sentry Units.

2.0 DESIGN INPUT

All the references listed in Sec. 7.0. The details in the figures shown in the calculation are updated from walkdown dated 11/22/93.

Equipment Data: Portable Flame and Smoke Detector Sentry Units
Location: Aux. Building (Ref. 7.1)
Elevation: Anywhere in Aux. Bldg.
Classifications: Non-Safety-Related
Modification No(s): N/A

3.0 ASSUMPTIONS

- Aluminum pole material is 6063, T6 or better
- Other assumptions are stated in the calculation, they are conservative and need no further verification.

4.0 APPROACH

Background:
Per Ref. 7.1, The sentry portable flame and smoke detector is to replace the existing fire watch. The units can be located anywhere in the auxiliary




Fig. - 4.1

Sentry Units

Rev. 00 Date

Safety-Related

Non-Safety Related

Page 2 of

Client	Commonwealth Edison Co.
Project	Zion Station Unit(s) 1 & 2
Proj. No.	9140-67 Equip.

Prepared by	Date
Reviewed by	Date
Approved by	Date

building. For now, the units temporarily will be placed in the corner of rooms for evaluation of the effectiveness. If the results of the evaluation show that the units are effective the units will be permanently mounted.

Mounting of the unit to fixture (wall or column): The temporary attachment is such that the PFSD can be easily detached from the location of anchor. However, in the case of wall connection there must be means by which the unit can be anchored to the wall (i.e. existing unistrut on the wall or embedded plate). In cases where there are no existing means at the desired location, such means have to be provided for the anchoring purpose. Examples of such means are permanent fixture like a unistrut mounted to the wall by expansion anchor where the wall is a concrete wall, or threaded bar and plate (bolt through) for concrete block wall. In this case two (2) eyebolts are to be mounted to the cart on the horizontal member of the cart as shown in Figs. 4.2 and 4.3. Two pieces of chain with sufficient length are to be permanently connected to the two eyebolts on the cart. The other end of the chain should have adjustable hook which will be mounted to the wall fixture (i.e. eyebolt). The wall fixture could be 3/8"φ "U" bolt or eyebolt welded to the embedded plate or connected to unistrut using spring nuts, or eyebolt expansion anchor, directly embedded to the wall. In cases where the unit can be used next to a column the chain can be used to anchor the




Fig. 4.2




Fig 4.3

Sentry Units

Safety-Related Non-Safety Related

Rev. 00 Date

Page 3 of

Client: Commonwealth Edison Co.
Project: Zion Station Unit(s) 1 & 2
Proj. No. 9140-67 Equip.

Prepared by: _____ Date: _____
Reviewed by: _____ Date: _____
Approved by: _____ Date: _____

unit to the column, (i.e. chain from one eyebolt around the column to adjacent eyebolt) no permanent fix will be necessary in this case. Where none of the above options are available the unit can be stand alone without any restraint, provided that the area where the unit may tip over and fall is clear of any equipment that may damage during the seismic event by the fall of portable fire detection unit. In this case the wedge or any other device that can be used to prevent the unit from rolling shall be utilized. Because, if the unit tips over backward the unit will roll forward (see Tip over Analysis).




Fig 4.4

Structural integrity: Per Ref. 7.1, the structural integrity and mounting details for the subject equipment will be evaluated for the gravity and seismic forces. From Ref. 7.2, the enveloping response spectra for all the elevations in the Auxiliary Building are developed as shown in attachment 2. The peak acceleration from the enveloped response spectra will be used as the seismic accelerations. The maximum seismic acceleration will be calculated by multiplying the peak seismic acceleration by Seismic Amplification Factor ($S_{AF} = 1.5$). The dead loads and seismic forces will be applied through the center of gravity for evaluating the structural integrity of critical links and adequacy of mounting details. The stresses in the critical areas of the equipment will be calculated and will be compared to the allowables (AISC, Ref. 7.6) to show the structural integrity of the equipment.

Note 1: The reaction loads will be calculated at the anchor point to the wall or wall fixture (i.e. unistrut) due to one horizontal and the vertical

Sentry Units

Safety-Related Non-Safety Related

Rev. 00 Date

Page 5 of

Client Commonwealth Edison Co.

Project Zion Station Unit(s) 1 & 2

Proj. No. 9140-67 Equip.

Prepared by

Date

Reviewed by

Date

Approved by

Date

Basic Units:

$in = \frac{2.54}{cm}$	$in = 1L$	$lb = 1m$	$ft = 12-in$	$kips = lb \cdot 1000$
$gm = \frac{1}{453.582} lb$	$psi = \frac{lb}{in^2}$	$cm = \frac{1}{2.54} in$	$m = 100 cm$	$ksi = 1000 \frac{lb}{in^2}$

GENERAL PROPERTIES:

Assuming Sheet Gage #18 for Upper Enclosure - thickness:

$t_{ue} = 0.0516 in$

Weight of Face Plate for Upper Enclosure (fp):

$W_{fp} = 1.75 lb$

Weight of Upper Enclosure (ue):

$W_{ue} = 4.75 lb$

Weight of Smoke Detector (SD):

$W_{SD} = 0.625 lb$

Weight of Smoke Detector (SD):

$W_{FD} = 0.5 lb$

Ref. 7.5

Total Weight of Upper Enclosure including the devices:

$W_e = W_{fp} + W_{ue} + W_{SD} + W_{FD}$

$W_e = 7.625 lb$

Main Enclosure thickness (Sheet Gage #16, Ref. 7.5, 7.4):

$t_E = 0.0625 in$

Aluminum Pole:

Outside Diameters (4 sections):

$i = 1..4$

$D_1 = 2.5 in$

$D_3 = 2.0 in$

$D_2 = 2.25 in$

$D_4 = 1.75 in$

Thickness:

$t_p = \frac{1}{16} in$

Cross-sectional Area (for each section):

$A_i = \frac{\pi}{4} [(D_i)^2 - (D_i - 2t_p)^2]$

$A = \begin{bmatrix} 0.479 \\ 0.43 \\ 0.38 \\ 0.331 \end{bmatrix} in^2$

Moment of inertia:

$I_i = \frac{\pi}{64} [(D_i)^4 - (D_i - 2t_p)^4]$

$I = \begin{bmatrix} 0.356 \\ 0.257 \\ 0.179 \\ 0.118 \end{bmatrix} in^4$

Sectional Modulus:

$S_i = \frac{\pi}{32} \left[\frac{(D_i)^4 - (D_i - t_p)^4}{D_i} \right]$

$S = \begin{bmatrix} 0.148 \\ 0.119 \\ 0.094 \\ 0.071 \end{bmatrix} in^3$

Client Commonwealth Edison Co.

Prepared by

Date

Project Zion Station Unit(s) 1 & 2

Reviewed by

Date

Proj. No. 9140-67 Equip.

Approved by

Date

Material Properties:

Weight density: $w_{dA} = 2.8 \frac{gm}{cm^3}$

$w_{dA} = 0.10116 \cdot lb \cdot in^{-3}$

Mass Density $m_{dA} = \frac{w_{dA}}{386.4}$

$m_{dA} = 0.0002618 \cdot lb \cdot in^{-3}$

Sectional Length: $L_1 = 6\text{-ft}$ $L_2 = 4\text{-ft}$ $L_3 = 4\text{-ft}$ $L_4 = 4\text{-ft}$

C.G. of each Sec. $y_1 = 3.5\text{-ft}$ $y_2 = 8\text{-ft}$ $y_3 = 12\text{-ft}$ $y_4 = 16\text{-ft}$

$W_5 = \left(\sum_i A_i \cdot L_i \right) \cdot (w_{dA})$

$W_5 = 9.03 \cdot lb$

Calculating the C.G. of aluminum pole: $y_5 = \frac{\sum_i A_i \cdot L_i \cdot y_i \cdot (w_{dA})}{W_5}$

$y_5 = 102.079 \cdot in$

Weight of Battery (800 AMP):

Weight *

y * dimension see Fig 5.1

$W_1 = 60 \cdot lb$

$y_1 = 6 \cdot in$

Weight of Backup Enclosure and components:

$W_2 = 16 \cdot lb$

$y_2 = 18 \cdot in$

Weight of Enclosure (Item-3):

$W_3 = (2 \cdot ((16 \cdot in + 40 \cdot in) \cdot 9 \cdot in + (16 \cdot in \cdot 40 \cdot in))) \cdot \left(t_E \cdot 0.283 \frac{lb}{in^3} \right)$

$W_3 = 40.469 \cdot lb$

$y_3 = \frac{40}{2} \cdot in$

Weight of Miscellaneous Items (assumed):
(Including the two cable reels, alarm light, control circuit board, console, wire...)

$W_4 = 15 \cdot lb$

$y_4 = 34 \cdot in$

Weight of Aluminum Pole from above:

$W_5 = 9.027 \cdot lb$

$y_5 = 102.079 \cdot in$

Weight of upper enclosure including devises:

$W_6 = 7.625 \cdot lb$

$y_6 = 17.5 \cdot ft$

Weight of cart and power cord reels:

$W_7 = 23 \cdot lb$

$y_7 = \frac{1}{4} \cdot 43 \cdot in$

* Based on approximate measurement and conservative assumptions

Client	Commonwealth Edison Co.
Project	Zion Station Unit(s) 1 & 2
Proj. No.	9140-67 Equip.

Prepared by	Date
Reviewed by	Date
Approved by	Date

C.G. of the assembly: $j = 1..7$

$$Y1 = \frac{\sum_j W_j y_j}{\sum_j W_j} \quad Y1 = 27.684 \cdot \text{in}$$

C.G. of the cart assembly without pole and upper enclosure:

$$i = 1..4 \quad Y2 = \frac{\sum_i W_i y_i}{\sum_i W_i} \quad Y2 = 14.965 \cdot \text{in} \quad W_{TL} = \sum_i W_i$$

C.G. of pole and upper enclosure:

$$Y3 = \frac{W_5 y_5 + W_6 y_6}{W_5 + W_6} \quad Y3 = 151.495 \cdot \text{in}$$

Natural Frequency of Aluminum Pole:

Assuming aluminum pole to be uniform beam, one end fixed, the other end free.
The uniform load 'w' per unit length plus an end load 'W'

Per Ref. 7.8, page 576, case 3c, the natural frequency can be calculated from formula shown below:

$$f_1 = \frac{1.732}{2\pi} \sqrt{\frac{EIg}{W L^3 + 0.236 w L^4}}$$

where:

L = total length $L_t = \sum_i L_i$ I = area moment of inertia $I_m = \frac{\sum_i I_i L_i}{L_t}$

E = modulus of elasticity (Ref. 7.4) $E = 10.6 \cdot 10^6 \text{ psi}$ w = uniform load per unit length $w_p = \frac{W_5}{L_t}$

g = gravitational acceleration $g = 386.4 \frac{\text{in}}{\text{sec}^2}$

W = end load [(Upper Enclosure) + (Smoke & Flame Detector)]: $W_6 = 7.625 \cdot \text{lb}$

$L_t = 216 \cdot \text{in}$

$I_m = 0.242 \cdot \text{in}^4$

$w_p = 0.042 \cdot \text{lb} \cdot \text{in}^{-1}$

$$f_1 = \frac{1.732}{2\pi} \sqrt{\frac{EI_m g}{W_6 L_t^3 + 0.236 w_p L_t^4}} \quad f_1 = 0.875 \cdot \text{sec}^{-1}$$

Client	Commonwealth Edison Co.
Project	Zion Station Unit(s) 1 & 2
Proj. No.	9140-67 Equip.

Prepared by	Date
Reviewed by	Date
Approved by	Date

The following are maximum accelerations applicable to Aux-Turb-D.G. Building:


———— OBE 0.5% damping ————	
OBE Vert. Per Ref. 7.2, p. 6	aov = 0.06 (g)
OBE Horiz. Per Ref. 7.2:	aoh = 2.1 (g)
———— SSE 2% damping ————	
SSE Vert. Per Ref. 7.2, p. 6	asv = 0.12 (g)
SSE Horiz. Per Ref. 7.2,	ash = 2 (g)
Use amplification factor of (1.5):	$S_{AF} = 1.5$
$a_x = S_{AF} \max(aoh \ ash)$	$a_x = 3.15 (g)$
$a_y = S_{AF} \max(aov \ asv) + 1$	$a_y = 1.18 (g)$
$a_z = S_{AF} \max(aoh \ ash)$	$a_z = 3.15 (g)$

See Attachment "2"
Enveloped Response
Spectra

Per Ref. 7.2, p 7, "The direction of the earthquake motion can be parallel to either of the principal axes of the equipment and/or equipment supports. The direction causing the most severe combination of stresses shall be used for design."

In this case the horizontal accelerations are the same for either directions, therefore, the results will be the same also. The C.G. of the whole assembly is approximately in the same high as the location of the eyebolt.

$WT = \sum_j W_j$	$WT = 171.121 \cdot lb$
Eyebolt diameter:	$d_1 = 0.375 \text{ in}$
Stress Area:	$A_{t1} = 0.0773 \text{ in}^2$
Shear Area:	$A_{s1} = 0.0678 \text{ in}^2$
$\alpha = 45 \text{ deg}$	$d_e = 0.375 \text{ in}$




Washer
Fig. 5.2



shoulder nut eyebolt
Fig. 5.2a

Seismic force could be F1 or F2 or F3	$F = F1 = F2 = F3$
$F = a_x \cdot WT$ (1 eyebolts in each side)	$F = 539.033 \cdot lb$
$F_t = F \sin(\alpha)$	$F_t = 381.154 \cdot lb$
$F_s = F \cos(\alpha)$	$F_s = 381.154 \cdot lb$
assuming: $b = 1.75 \text{ in}$	$d_{e1} = 0.25 \text{ in}$
$M = 2 \cdot f \cdot d_{e1}$ $f = \frac{M}{2 \cdot d_{e1}}$ $M = F_s \cdot b$ $f = \frac{M}{2 \cdot d_{e1}}$	$f = 1334.038 \cdot lb$



$e^* \cdot d_{e1}$ Fig. 5.2b




Fig. 5.2c

Note: M will be slightly smaller than $M = F_s \cdot b - F_t \cdot (e^*)$

Client	Commonwealth Edison Co.
Project	Zion Station Unit(s) 1 & 2
Proj. No.	9140-67 Equip.

Prepared by	Date
Reviewed by	Date
Approved by	Date

$$\sigma = \frac{F_t + f}{A t_1} \quad \sigma = 22.189 \cdot \text{ksi} < 20 \text{ ksi} \cdot \left(\frac{4}{3}\right) = 26.667 \cdot \text{ksi} \text{ (Ref. 7.6- assuming A307 material)}$$

$$\tau = \frac{F_s}{A s_1} \quad \tau = 5.622 \cdot \text{ksi} < 10 \text{ ksi} \cdot \left(\frac{4}{3}\right) = 13.333 \cdot \text{ksi}$$


$$\frac{4}{3} \cdot 26 \text{ ksi} - 1.8 \tau = 24.548 \cdot \text{ksi} > \sigma = 22.189 \cdot \text{ksi} \text{ (Ref. 7.6- assuming A307 material)}$$

Chain Connection to the Wall:

Per Ref. 7.7,	Trade Size	Cat. No.	Work Load Limits	
Type 304 Stainless Steel Chain	3/16"	3392T29	1200-lb	Recommended > * F = 539.033-lb
Passing Link Chain	40.....0.219"	3596T16	600-lb	

* Using one chain in each side of the cart

Chain can be permanently bolted or welded at one end to the cart and in the other end can be attached temporary (adjustable hook) or permanently (weld, etc.) to Unistrut eyebolt / Expansion Anchor eyebolt, etc.).



Unistrut: the capacity per Ref. 7.11

Type	Span	Load Capacity	
P1000	24"	1690-lb · 0.5 = 845-lb	} F = 539.033-lb
P3000	24"	1330-lb · 0.5 = 665-lb	

* safety factor

A 3/8" eyebolt attached to the unistrut can be used to provide connection for the chain's adjustable hook. The other suggestion is a 3/8" eyebolt expansion anchor, as shown in Fig. 4.4, Detail -2, that may be mounted directly to the wall.

Per Ref. 7.9, 3/8" Wedge Type Expansion Anchors can be used recommended effective embedded length is 3", capacity for 1 5/8" EMB = 2328-lbs tension and 4767 lbs shear.

$$F_{\text{tension}} = \sigma A t_1 \quad F_{\text{tension}} = 1715.192 \cdot \text{lb} \quad \text{These loads for Expansion Anchor will be increased by 30\% for conservatism and will be given to the SED if it is requested.}$$

$$F_{\text{shear}} = \tau A s_1 \quad F_{\text{shear}} = 381.154 \cdot \text{lb}$$

$$F_{\text{exp.tens}} = (1.3) F_{\text{tension}} \quad F_{\text{exp.tens}} = 2229.749 \cdot \text{lb} \quad F_{\text{exp.shr}} = (1.3) F_{\text{shear}} \quad F_{\text{exp.shr}} = 495.5 \cdot \text{lb}$$

3/8" expansion is adequate.

Sentry Units

Rev. 00 Date

Safety-Related

Non-Safety Related

Page 10 of

Client Commonwealth Edison Co.

Prepared by

Date

Project Zion Station Unit(s) 1 & 2

Reviewed by

Date

Proj. No. 9140-67

Equip.

Approved by

Date

Upper Box Face Plate Details:

Plate Dimension: 8.0" x 12.0" (Ref. 7.5) h = 12-in w = 8-in

Thickness: $t_{ue} = 0.052 \cdot \text{in}$

Weight of Face Plate + component:

$W_{fp} = 1.75 \cdot \text{lb}$ $W_{SD} = 0.625 \cdot \text{lb}$ $W_{FD} = 0.5 \cdot \text{lb}$

$W_{pt} = W_{fp} + W_{SD} + W_{FD}$ $W_{pt} = 2.875 \cdot \text{lb}$

For conservatism in the analysis, assume the eccentricities to be as:

$e_x = 0 \cdot \text{in}$ $e_y = 3 \cdot \text{in}$ $e_z = 2 \cdot \text{in}$

Seismic & Dead Loads:

Forces:

$F_x = W_{pt} a_x$ $F_x = 9.056 \cdot \text{lb}$

$F_y = W_{pt} a_y$ $F_y = 3.392 \cdot \text{lb}$

$F_z = W_{pt} a_z$ $F_z = 9.056 \cdot \text{lb}$

Moments:

$M_x = F_y e_z + F_z e_y$ $M_x = 33.954 \cdot \text{lb} \cdot \text{in}$

$M_y = F_x e_z + F_z e_x$ $M_y = 18.113 \cdot \text{lb} \cdot \text{in}$

$M_z = F_y e_x + F_x e_y$ $M_z = 27.169 \cdot \text{lb} \cdot \text{in}$

Screw: Per Ref. 7.5 # 5 screws are used

Screw diameter (Ref. 7.4): $d_5 = 0.125 \cdot \text{in}$

Tensile Stress Area (Ref. 7.4): $A_{5.1} = 0.0079 \cdot \text{in}^2$

Shear Area (Ref. 7.4): $A_{5.5} = 0.0067 \cdot \text{in}^2$

see Fig 5.3
conservatively
assuming

$c = 3.25 \cdot \text{in}$
 $h = 5 \cdot \text{in}$




Fig. 5.3

Sentry Units

Rev. 00 Date

Safety-Related

Non-Safety Related

Page 11 of

Client: Commonwealth Edison Co.

Prepared by

Date

Project: Zion Station Unit(s) 1 & 2

Reviewed by

Date

Proj. No. 9140-67

Equip.

Approved by

Date

Moment of Inertia:

$$I_{xx} = 4 \cdot A_{S,I} \cdot h^2$$

$$I_{xx} = 0.79 \cdot \text{in}^4$$

$$I_{yy} = 4 \cdot (A_{S,I} \cdot c^2)$$

$$I_{yy} = 0.334 \cdot \text{in}^4$$

$$I_{zz} = I_{xx} + I_{yy}$$

$$I_{zz} = 1.124 \cdot \text{in}^4$$

Stresses in Screw:

$$\sigma_s = \frac{F_z}{(4 \cdot A_{S,I})} + \frac{M_x \cdot h}{I_{xx}} + \frac{M_y \cdot c}{I_{yy}}$$

$$\sigma_s = 677.85054 \cdot \text{psi}$$

$$\tau_s = \frac{\sqrt{F_x^2 + F_y^2}}{4 \cdot A_{S,S}} + \frac{M_z \cdot (\sqrt{c^2 + h^2})}{I_{zz}}$$

$$\tau_s = 505.025 \cdot \text{psi}$$

Allowable Stresses:

Screw material is assumed to be A-307. Per Ref. 7.6, Table 1.5.2.1, the Allowable Stresses on Fasteners with A-307 material are:

Allowable Tension: $F_t = 20 \cdot \text{ksi} > \sigma_s = 0.678 \cdot \text{ksi}$

Allowable Shear: $F_v = 10 \cdot \text{ksi} > \tau_s = 0.505 \cdot \text{ksi}$

Therefore, the 4 # 5 screws are adequate to withstand the seismic loading and are sufficient to mount the face plate for upper enclosure.

Checking the Mounting of Flame and Smoke Detector:

(The Smoke and flame detector, both have a similar mounting details evaluating the mounting details for smoke detector envelop the other)

For conservatism in the analysis, assume the eccentricities to be as:

$$e_x = 1 \cdot \text{in}$$

$$e_y = 1 \cdot \text{in}$$

$$e_z = 3 \cdot \text{in}$$

Weight of Smoke Detector assumed: $W_s = 1 \cdot \text{lb} > W_{SD} = 0.625 \cdot \text{lb}$

Seismic & Dead Loads: Forces: $F_x = W_s \cdot a_x \quad F_x = 3.15 \cdot \text{lb}$
 $F_y = W_s \cdot a_y \quad F_y = 1.18 \cdot \text{lb}$
 $F_z = W_s \cdot a_z \quad F_z = 3.15 \cdot \text{lb}$

Sentry Units

Safety-Related Non-Safety Related

Rev. 00 Date

Page 12 of

Client Commonwealth Edison Co.
Project Zion Station Unit(s) 1 & 2
Proj. No. 9140-67 Equip.

Prepared by Date
Reviewed by Date
Approved by Date

Moments: $M_x = F_y \cdot e_z + F_z \cdot e_y$ $M_x = 6.69 \cdot \text{lb} \cdot \text{in}$
 $M_y = F_x \cdot e_z + F_z \cdot e_x$ $M_y = 12.6 \cdot \text{lb} \cdot \text{in}$
 $M_z = F_y \cdot e_x + F_x \cdot e_y$ $M_z = 4.33 \cdot \text{lb} \cdot \text{in}$

Screw: Per Ref. 7.5 # 5 screws are used

Screw diameter (Ref. 7.4): $d_s = 0.125 \text{ in}$

Tensile Stress Area (Ref. 7.4): $A_{5,t} = 0.0079 \text{ in}^2$

Shear Area (Ref. 7.4): $A_{5,s} = 0.0067 \text{ in}^2$

see Fig. 5.4,
conservatively
assuming

$c = 1.5 \text{ in}$
 $de2 = 4 \text{ in}$




Fig. 5.4

Moment of Inertia: $I_{yy} = 2 \cdot (A_{5,t} \cdot c^2)$ $I_{yy} = 0.036 \text{ in}^4$

Stresses in Screw:

$$\sigma_s = \frac{F_z}{2 \cdot A_{5,t}} + \frac{M_x}{2 \cdot de2} + \frac{M_y \cdot c}{I_{yy}} \quad \sigma_s = 836.86709 \text{ psi}$$

$$\tau_s = \frac{\sqrt{F_x^2 + F_y^2}}{2 \cdot A_{5,s}} + \frac{M_z}{A_{5,s} \cdot c} \quad \tau_s = 466.45 \text{ psi}$$

Allowable Stresses:

Screw material is assumed to be A-307. Per Ref. 7.6, Table 1.5.2.1, the Allowable Stresses on Fasteners with A-307 material are:

Allowable Tension: $F_t = 20 \text{ ksi} > \sigma_s = 0.837 \text{ ksi}$

Allowable Shear: $F_v = 10 \text{ ksi} > \tau_s = 0.466 \text{ ksi}$

Therefore, the 2 # 5 screws are adequate to withstand the seismic loading.

Checking 1/4" screw holding the upper enclosure to pipe clamps: (see Fig 5.1)

For conservatism in the analysis, assume the eccentricities to be as:

$e_x = 1 \text{ in}$ $e_y = 3 \text{ in}$ $e_z = 3.5 \text{ in}$

Client **Commonwealth Edison Co.**

Prepared by

Date

Project **Zion Station Unit(s) 1 & 2**

Reviewed by

Date

Proj. No. **9140-67**

Equip.

Approved by

Date

Weight of Upper Enclosure: $W_6 = 7.625 \cdot \text{lb}$

Seismic & Dead Loads:

Forces: $F_x = W_6 \cdot a_x$ $F_x = 24.019 \cdot \text{lb}$

$F_y = W_6 \cdot a_y$ $F_y = 8.997 \cdot \text{lb}$

$F_z = W_6 \cdot a_z$ $F_z = 24.019 \cdot \text{lb}$

Moments: $M_x = F_y \cdot e_z + F_z \cdot e_y$ $M_x = 103.548 \cdot \text{lb} \cdot \text{in}$

$M_y = F_x \cdot e_z + F_z \cdot e_x$ $M_y = 108.084 \cdot \text{lb} \cdot \text{in}$

$M_z = F_y \cdot e_x + F_x \cdot e_y$ $M_z = 81.054 \cdot \text{lb} \cdot \text{in}$

Screw: Per Ref. 7.5 1/4"-20 screws are used

Screw diameter (Ref. 7.4): $d_c = 0.25 \cdot \text{in}$

Tensile Stress Area (Ref. 7.4): $A_{c,t} = 0.0317 \cdot \text{in}^2$

Shear Area (Ref. 7.4): $A_{c,s} = 0.0269 \cdot \text{in}^2$

see Fig. 5.5 & 5.1 $\left\{ \begin{array}{l} dx_1 = 0.375 \cdot \text{in} \\ dy_1 = 2 \cdot \text{in} \end{array} \right.$

Moment of Inertia: $I_{xx} = 2 \cdot (A_{c,t} \cdot dy_1^2)$ $I_{xx} = 0.254 \cdot \text{in}^4$

Stresses in Screw:

$$\sigma_c = \frac{F_z}{(2 \cdot A_{c,t})} + \frac{M_x \cdot dy_1}{I_{xx}} + \frac{My}{2 \cdot A_{c,t} \cdot dx_1} \quad \sigma_c = 5.7416 \cdot \text{ksi}$$

$$\tau_c = \frac{\sqrt{F_x^2 + F_y^2}}{2 \cdot A_{c,s}} + \frac{Mz \cdot dy_1}{I_{xx}} \quad \tau_c = 1.116 \cdot \text{ksi}$$




Fig. 5.5 (screws holding upper enclosure to pipe clamp)

Sentry Units

Safety-Related Non-Safety Related

Rev. 00 Date

Page 14 of

Client: Commonwealth Edison Co.
Project: Zion Station Unit(s) 1 & 2
Proj. No. 9140-67 Equip.

Prepared by: _____ Date: _____
Reviewed by: _____ Date: _____
Approved by: _____ Date: _____

Allowable Stresses:

Screw material is assumed to be A-307. Per Ref. 7.6, Table 1.5.2.1, the Allowable Stresses on fasteners with A-307 material are:

Allowable Tension: $F_t = \left(\frac{4}{3}\right) \cdot 20 \text{ ksi} \quad F_t = 26.667 \cdot \text{ksi} > \sigma_c = 5.742 \cdot \text{ksi}$

Allowable Shear: $F_v = \left(\frac{4}{3}\right) \cdot 10 \text{ ksi} \quad F_v = 13.333 \cdot \text{ksi} > \tau_c = 1.116 \cdot \text{ksi}$

Therefore, the (2) 1/4"-20 screws are adequate to withstand the seismic loading.

Checking 1/4" screw holding the Aluminum Pole to Cart:

Weight: $WA = W_6 + W_5 \quad WA = 16.652 \cdot \text{lb}$

Eccentricities:

$e_x = 0 \cdot \text{in} \quad e_y = \left| Y_3 - \left(15.5 + \frac{13.5}{2} \right) \right| \cdot \text{in} \quad e_y = 129.245 \cdot \text{in} \quad e_z = \frac{3.5 \cdot \text{in} \cdot W_6}{WA} \quad e_z = 1.603 \cdot \text{in}$

$k = 1.2 \quad a_{x_1} = 0 \quad a_{x_2} = 3.15 \quad a_{z_1} = 3.15 \quad a_{z_2} = 0$

Seismic & Dead Loads: Seismic force acting in only one horizontal direction + vertical $a_x = \begin{pmatrix} 0 \\ 3.15 \end{pmatrix} \quad a_z = \begin{pmatrix} 3.15 \\ 0 \end{pmatrix}$

Forces: $F_x = WA \cdot a_x \quad F_x^T = (0 \quad 52.455) \text{ lb}$

$F_y = WA \cdot a_y \quad F_y = 19.65 \cdot \text{lb}$

$F_z = WA \cdot a_z \quad F_z^T = (52.455 \quad 0) \text{ lb}$

Moments: $M_x = F_y \cdot e_z + F_z \cdot e_y \quad M_x^T = (6811.083 \quad 31.491) \text{ lb} \cdot \text{in}$

$M_y = F_x \cdot e_z + F_z \cdot e_x \quad M_y^T = (0 \quad 84.066) \text{ lb} \cdot \text{in}$

$M_z = F_y \cdot e_x + F_x \cdot e_y \quad M_z^T = (0 \quad 6780) \text{ lb} \cdot \text{in}$

Screw: Per Ref. 7.5 1/4"-20 screws are used

Screw diameter (Ref. 7.4): $d_c = 0.25 \text{ in}$

Tensile Stress Area (Ref. 7.4): $A_{c,t} = 0.0317 \cdot \text{in}^2$

Shear Area (threads are excluded from shear planes) $A_{c,s} = \frac{\pi}{4} \cdot d_c^2 \quad A_{c,s} = 0.049 \cdot \text{in}^2$

see Figs. 5.6 & 5.1 $dx_1 = 0.375 \text{ in} \quad dy = \frac{13.5}{2} \text{ in}$




Fig. 5.6

Client	Commonwealth Edison Co.
Project	Zion Station Unit(s) 1 & 2
Proj. No.	9140-67 Equip.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Moment of Inertia: $I_{XX} = 2 \cdot (A_{c.t} \cdot dy^2)$ $I_{XX} = 2.889 \cdot \text{in}^4$

Stresses in Screw:

$$\sigma_A = \frac{Fz}{2 \cdot A_{c.t}} + \frac{Mx \cdot dy}{I_{XX}} + \frac{My}{2 \cdot A_{c.t} \cdot dx}$$

$$\sigma_A = \left(\frac{16.74298}{3.60947} \right) \cdot \text{ksi}$$

$$\tau_{A_k} = \frac{\sqrt{(F_x)^2 + (F_y)^2}}{2 \cdot A_{c.s}} + \frac{Mz_k \cdot dy}{I_{XX}}$$

$$\tau_A = \left(\frac{0.2}{16.413} \right) \cdot \text{ksi}$$

Allowable Stresses:

Screw material is assumed to be A-307. Per Ref. 7.6, Table 1.5.2.1, the Allowable Stresses on Fasteners with A-307 material are:

Allowable Shear when threads are excluded from shear plane: $F_v = 60 \cdot \text{ksi} \cdot 0.22$

Allowable Tension: $F_t = \frac{4}{3} \cdot 20 \cdot \text{ksi}$ $F_t = 26.667 \cdot \text{ksi} > \sigma_A = \left(\frac{16.743}{3.609} \right) \cdot \text{ksi}$

Allowable Shear: $F_v = \frac{4}{3} \cdot F_v$ $F_v = 17.6 \cdot \text{ksi} > \tau_A = \left(\frac{0.2}{16.413} \right) \cdot \text{ksi}$

$$\sigma_{al_k} = \min \left(\frac{4}{3} \cdot 26 \cdot \text{ksi} - 1.8 \cdot \tau_{A_k} \cdot F_t \right)$$

$$\sigma_{al} = \left(\frac{26.667}{5.124} \right) \cdot \text{ksi} > \sigma_A = \left(\frac{16.743}{3.609} \right) \cdot \text{ksi}$$

Therefore, the (2) 1/4"-20 screws are adequate to withstand the seismic loading.

Checking Clamp for Bending:

Clamp Thickness & width: $t_{p2c} = 0.625 \cdot \text{in}$ $b_{pc} = 1.25 \cdot \text{in}$

$$\sigma_{pc} = \frac{F_x \cdot 1.25 \cdot \text{in}}{2 \cdot 2 \cdot \left(\frac{b_{pc} \cdot t_{p2c}^2}{6} \right)}$$

$$\max(\sigma_{pc}) = 20.143 \cdot \text{ksi}$$

$\max(\sigma_{pc}) = 20.143 \cdot \text{ksi} < 36 \cdot \text{ksi} \cdot 0.9 = 32.4 \cdot \text{ksi}$




Fig. 5.7

Client	Commonwealth Edison Co.
Project	Zion Station Unit(s) 1 & 2
Proj. No.	9140-67 Equip.

Prepared by	Date
Reviewed by	Date
Approved by	Date

Checking Aluminum Pole:

$$\sigma_{Ap} = \frac{F_y}{A_1} + \frac{M_x \frac{D_1}{2}}{I_1} + \frac{M_z \frac{D_1}{2}}{I_1} \quad \max(\sigma_{Ap}) = 23.978 \text{ ksi}$$

$$\tau_{Apk} = \frac{\sqrt{(F_{Xk})^2 + (F_{Zk})^2}}{A_1} + \frac{M_y \frac{D_1}{2}}{I_1} \quad \max(\tau_{Ap}) = 0.11 \text{ ksi}$$

Yield for the assumed Aluminum (6063, T6) from Ref. 7.4: $S_{y Ap} = 31 \text{ ksi}$

$$S_{allow Ap} = S_{y Ap}^{0.9} \quad S_{allow Ap} = 27.9 \text{ ksi} \quad \gg \quad \max(\sigma_{Ap}) = 23.978 \text{ ksi}$$

Checking the mounting of Main Enclosure to Cart:

Weight: $WE = WT - W_7 \quad WE = 148.121 \text{ lb}$

calculating the bolt center: $y_1 = 13.5 \text{ in} \quad y_3 = 13.5 \text{ in} \quad y_2 = 13.5 \text{ in} \quad y_4 = 0 \text{ in}$

$$Y = \frac{\sum y_i}{4} \quad Y = 10.125 \text{ in}$$

Eccentricities:

$$\begin{aligned} e_x &= 0 \text{ in} & e_z &= 4.5 \text{ in} \\ e_y &= |Y_1 - Y| & e_y &= 17.559 \text{ in} \end{aligned}$$

Seismic & Dead Loads:

Forces:	$F_x = WE \cdot a_x$	$F_x^T = (0 \quad 466.583 \quad 0) \text{ lb}$
	$F_y = WE \cdot a_y$	$F_y = 174.783 \text{ lb}$
	$F_z = WE \cdot a_z$	$F_z^T = (466.583 \quad 0 \quad 0) \text{ lb}$
Moments:	$M_x = F_y \cdot e_z + F_z \cdot e_y$	$M_x^T = (8979.447 \quad 786.525) \text{ lb} \cdot \text{in}$
	$M_y = F_x \cdot e_z + F_z \cdot e_x$	$M_y^T = (0 \quad 2099.622) \text{ lb} \cdot \text{in}$
	$M_z = F_y \cdot e_x + F_x \cdot e_y$	$M_z^T = (0 \quad 8192.922) \text{ lb} \cdot \text{in}$

Client Commonwealth Edison Co.

Prepared by

Date

Project Zion Station Unit(s) 1 & 2

Reviewed by

Date

Proj. No. 9140-67

Equip.

Approved by

Date

Per Ref. 7.5 1/4"-20 screws are used

Screw diameter (Ref. 7.4): $d_c = 0.25$ in

Tensile Stress Area (Ref. 7.4): $A_{c.t} = 0.0317$ in²

Shear Area (Ref. 7.4): $A_{c.s} = 0.0269$ in²

$$dy_1 = |y_1 - Y| \quad dy_1 = 3.375 \text{ in}$$

$$dx_1 = 3.75 \text{ in}$$

$$dy_2 = |y_2 - Y| \quad dy_2 = 3.375 \text{ in}$$


$$dx_2 = 3.75 \text{ in}$$

$$dy_3 = |y_3 - Y| \quad dy_3 = 3.375 \text{ in}$$

$$dx_3 = 0 \text{ in}$$

$$dy_4 = |y_4 - Y| \quad dy_4 = 10.125 \text{ in}$$

$$dx_4 = 0 \text{ in}$$



Moment of Inertia: $I_{xx} = \sum_i A_{c.t} (dy_i)^2 \quad I_{xx} = 4.333 \text{ in}^4$

$$I_{yy} = \sum_i A_{c.t} (dx_i)^2 \quad I_{yy} = 0.892 \text{ in}^4$$

Fig. 5.8

Stresses in Screw:

$$R_i = \sqrt{(dy_i)^2 + (dx_i)^2} \quad \max(R) = 10.125 \text{ in}$$

$$\sigma_E = \frac{F_z}{4 \cdot A_{c.t}} + \frac{M_x \max(dy)}{I_{xx}} + \frac{M_y \max(dx)}{I_{yy}} \quad \sigma_E = \left(\frac{24.662}{10.669} \right) \cdot \text{ksi}$$

$$\tau_{E_k} = \frac{\sqrt{(F_{x_k})^2 + (F_y)^2}}{4 \cdot A_{c.s}} + \frac{M_z \max(R)}{I_{xx} + I_{yy}} \quad \tau_E = \left(\frac{1.624}{20.508} \right) \cdot \text{ksi}$$

Allowable Stresses:

Screw material is assumed to be A-307. Per Ref. 7.6, Table 1.5.2.1, the Allowable Stresses on Fasteners with A-307 material are:

Allowable Tension: $F_t = \frac{4}{3} \cdot 20 \text{ ksi} \quad F_t = 26.667 \cdot \text{ksi} > \sigma_E = \left(\frac{24.662}{10.669} \right) \cdot \text{ksi}$

Allowable Shear: $F_v = \frac{4}{3} \cdot (10 \text{ ksi}) \quad F_v = 13.333 \cdot \text{ksi} > \tau_E = \left(\frac{1.624}{20.508} \right) \cdot \text{ksi}$

$$\sigma_{E.al_k} = \min \left(\frac{4}{3} \cdot 26 \text{ ksi} - 1.8 \cdot \tau_{E_k} \cdot F_t \right) \quad \sigma_{E.al} = \left(\frac{26.667}{-2.248} \right) \cdot \text{ksi} > \sigma_E = \left(\frac{24.662}{10.669} \right) \cdot \text{ksi}$$

Therefore, the (4) 1/4"-20 screws are adequate to withstand the seismic loading.

Client Commonwealth Edison Co.

Prepared by

Date

Project Zion Station Unit(s) 1 & 2

Reviewed by

Date

Proj. No. 9140-67

Equip.

Approved by

Date

Tip Over Analysis:

Total Weight for Lower Enclosure (LE): $W_{TL} = 131.469 \cdot lb$


Horizontal Acceleration: $ax_2 = 3.15$

Horizontal Force on C.G. of LE: $F_h = W_{TL} \cdot ax_2$

$$F_h = 414.127 \cdot lb$$

Vertical Force on C.G. of LE: $F_v = W_{TL} \cdot ay$

$$F_v = 155.133 \cdot lb$$



$$\alpha = \text{atan} \left(\frac{F_v}{F_h} \right)$$

C.G. for LE: $Y_2 = 14.965 \cdot \text{in}$ use 15" $\alpha = 20.536 \cdot \text{deg}$




Fig. 5.9

$70^\circ > 31^\circ$ Therefore, the unit may tip over or roll or roll and tip over because the direction of the earthquake motion is reversible and the extension of the resultant force as shown in the Fig. 5.10 falls outside the perimeter of the unit's base.

To prevent the rolling of the unit devices such as wheel wedge may be used.




Fig. 5.10

Sentry Units

Safety-Related

Non-Safety Related

Client Commonwealth Edison Co.

Prepared by

Date

Project Zion Station Unit(s) 1 & 2

Reviewed by

Date

Proj. No. 9140-67 Equip.

Approved by

Date

6.0 CONCLUSIONS

The structural integrity and mounting details as shown in Fig. 4.2 and 4.3, for subject portable fire detection has been evaluated and found to be acceptable per Zion Station requirements.

7.0 REFERENCES

- 7.1 CMED-057954, meeting notes "Qualification of Portable Flame Detector Sentry Units to be installed at Zion Station" dated 07/13/93.
- 7.2 Seismic Design Criteria for Zion Station DC-SE-002-ZI, Rev. 03, Dated 06-03-91.
- 7.3 Faxed information from POEM Lighting Company, dated 07/12/93.
- 7.4 Marks' Standard Handbook for Mechanical Engineers, 8th Edition
- 7.5 Field walk_down information, dated 9/13/93 (updated on 12/22/93).
- 7.6 AISC, Manual of Steel Construction 8th Edition.
- 7.7 McMASTER-CARR Supply Co., Catalog 92. (attached)
- 7.8 Formulas for Stress and Strain Fifth Edition, Roark and Young, McGraw Hill.
- 7.9 SED file No. DC-SE-01-CE, Rev. 2, dated 04/29/81
- 7.10 Not used

Client	Commonwealth Edison Co.	Prepared by	Date
Project	Zion Station Unit(s) 1 & 2	Reviewed by	Date
Proj. No.	9140-67 Equip.	Approved by	Date

7.11 Unistrut General Engineering Catalog No. 10R

8.0 ATTACHMENTS

8.1 Meeting Note Ref. 7.1

8.2 Walk_down Information Ref. 7.5

8.3 Enveloped Response Spectra for Aux. Building.

8.4 Faxed information From POEM Lighting Company Ref. 7.3

- end -