

CONFIRMATORY ACTION LETTER

August 23, 1982

Docket No. 50-346

Toledo Edison Company  
 ATTN: Mr. Richard P. Crouse  
 Vice President  
 Nuclear  
 Edison Plaza  
 300 Madison Avenue  
 Toledo, OH 43652

Gentlemen:

This letter modifies Item 3 of our Confirmatory Action Letter to you dated August 13, 1982, as follows:

- Reactor power will be limited to 1% of rated thermal power until NRR completes its review of the retired auxiliary feedwater header and issues a SER on this matter and the flow verification and water hammer test results have been reviewed by Region III.

These actions are agreeable with Region III and NRR. If your understanding of this matter differs from that described above, please contact this office immediately.

Sincerely,

Original signed by  
 James G. Keppler

James G. Keppler  
 Regional Administrator

cc: T. D. Murray, Station  
 Superintendent  
 DMB/Document Control Desk (RIDS)  
 Resident Inspector, RIII  
 Harold W. Kohn, Power Siting  
 Commission  
 Helen W. Evans, State of Ohio  
 Robert M. Quillin, Director  
 Ohio Dept. of Health  
 G. Lainas, NRR  
 J. Taylor, IE  
 E. Jordan, IE  
 J. Lieberman, IE  
 A. Deagazio, NRR

8209020419 820823  
 PDR ADOCK 05000346  
 P PDR

*LEO1*  
*See for John Stoltz*  
*Wilson*  
 Lainas 8/24/82  
 per telecon

OFFICE	RIII	RIII	RIII	RIII	RIII	RIII	RIII
SURNAME	Byron/rl	Reyes	Streeter	Spessard	Davis	Keppler	Lainas 8/24/82
DATE	8/23/82	8/23	8/23	8/23	8/23	8/24/82	