



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

August 26, 1982

12 AUG 30 8 9:11  
GENERAL REGIONAL  
ADMINISTRATOR

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly

SUBJECT: Crand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Failure to Establish a Fire Watch  
Reference: LER 82-028/01 T-0  
AECM-82/363

On August 14, 1982, a fire watch, required by LCO under Technical Specification 3.7.6.4, had not been implemented. Attached is LER 82-028/01 T-0 with supplementary information.

Yours truly,

*John P. McGaughy, Jr.*  
JP McGaughy J.R.

JPM:ac  
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8209020459 820826  
PDR ADCK 05000416  
S PDR

OFFICIAL COPY

TE 22