

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | J | S | G | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
7 8 9 14 15 25 26 57 CAT 58

0 1 | L | 6 | 0 | 5 | 0 | 0 | 2 | 7 | 2 | 7 | 0 | 7 | 3 | 1 | 8 | 2 | 8 | 0 | 8 | 1 | 8 | 8 | 2 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On July 31, 1982, during routine surveillance, an operator discovered a service
0 3 | water leak from a flexible hose on the jacket cooling water system of No. 1C Diesel
0 4 | Generator. The diesel was declared inoperable, and Action Statement 3.8.1.1.a was
0 5 | entered. Tags were immediately placed to prevent operation and possible damage to
0 6 | the diesel. (82-012, 82-03, 81-053, 81-029)
0 7 |
0 8 |

0 9 | E | E | 11 | E | 12 | F | 13 | E | N | G | I | N | E | 14 | Z | 15 | Z | 16 |
7 8 9 10 11 12 13 18 19 20
17 | LER RO REPORT NUMBER | 8 | 2 | 21 | 22 | - | 23 | 0 | 5 | 3 | 24 | 26 | / | 27 | 0 | 3 | 28 | 29 | L | 30 | - | 31 | 0 | 32 |
18 | ACTION TAKEN | A | 18 | F | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 22 | Y | 23 | Y | 24 | A | 25 | A | 1 | 5 | 2 | 26 |
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The failure of the hose was due to deterioration of the wall material; the natural
1 1 | end of the component life was involved. The hose was replaced, and the engine
1 2 | was satisfactorily tested. The engine was declared operable, and the action state-
1 3 | ment was terminated. A new type hose will be installed at the next refueling.
1 4 |

1 5 | E | 28 | 0 | 1 | 9 | 29 | N/A | 30 | B | 31 | Routine Surveillance | 32
7 8 9 10 12 13 44 45 46 80

1 6 | Z | 33 | Z | 34 | N/A | 35 | N/A | 36
7 8 9 10 11 44 45 80

1 7 | 0 | 0 | 0 | 37 | Z | 38 | N/A | 39
7 8 9 11 12 13 80

1 8 | 0 | 0 | 0 | 40 | N/A | 41
7 8 9 11 12 13 80

1 9 | Z | 42 | N/A | 43
7 8 9 10 12 80

2 0 | N | 44 | N/A | 45
7 8 9 10 80

8209020477 820818
PDR ADOCK 05000272
3 PDR

NRC USE ONLY

NAME OF PREPARER R. Frahm

PHONE: (609) 541-5900 629