

APPENDIX A

NOTICE OF VIOLATION

GPU Nuclear Corporation
Three Mile Island Unit 1

Docket No. 50-289
License No. DPR-50

As a result of the inspection conducted on May 25, 1982, through July 23, 1982, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 47 FR 9987 (March 9, 1982), the following violation was identified.

Technical Specifications, Appendix A, Section 6.11, requires that procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR 20 and shall be approved, maintained, and adhered to for all operations involving personnel radiation exposures.

Temporary Change Notice (TCN) No. 1-82-0062 to Radiological Control Procedure 1610.1, dated May 4, 1982, requires that a daily audit be made of keys kept in the high radiation area key locker, a key control log be maintained for each key transaction and that the Radiological Controls Foreman review and verify by signing the high radiation area control check sheet, the status of all high radiation areas daily.

Contrary to these requirements:

- Audits of the high radiation area key locker were not conducted during the period May 31, 1982 through June 3, 1982.
- The key control log contained several incomplete entries in which the key numbers issued, keys returned and purpose for entry into the locked high radiation area were not recorded, as required, on several occasions during May 1982.
- The Radiological Controls Foreman failed to review the high radiation area control check sheets for the period from May 4, 1982 through May 27, 1982 and on June 2, 1982.

This is a Severity Level V Violation (Supplement IV).

OFFICIAL RECORD COPY

8209020523 820818
PDR ADOCK 05000289
PDR

This notice is sent to you pursuant to the provisions of Section 2.201 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations. Although Section 2.201 requires you to submit to this office a written statement of explanation, we note that this violation was corrected prior to the completion of our inspection and therefore, no response with respect to this matter is required.

Dated _____

Original Signed By:

R. Keimig for

Richard W. Starostecki, Director
Division of Project and Resident
Programs