



General Electric Company  
175 Curtner Avenue, San Jose, CA 95125

February 9, 1994

Docket No. 52-001

Chet Poslusny, Senior Project Manager  
Standardization Project Directorate  
Associate Directorate for Advanced Reactors  
and License Renewal  
Office of the Nuclear Reactor Regulation

Subject: Submittal Supporting Accelerated ABWR Schedule - **MRBM**  
**Test in Subsection 14.2.12.2.6**

Dear Chet:

Enclosed is H. J. Yang's letter that concludes that the control rod withdrawal block function of the MRBM subsystem should not be included in Subsection 14.2.12.2.6. This letter provided the basis of the conference call between H. J. Yang and Frank Talbot on February 9, 1994. As a result of this call, it was agreed that Subsection 14.2.12.2.6 will not include the control rod withdrawal block function of the MRBM subsystem.

Please provide a copy of this transmittal to Frank Talbot.

Sincerely,

Jack Fox  
Advanced Reactor Programs

cc: Joe Quirk (GE)  
Alan Beard (GE)  
Norman Fletcher (DOE)  
H. J. Yang (GE)

180071