



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

August 26, 1982

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Secondary Containment Inoperability  
Reference: LER 82-030/03 L-0  
AECM-82/366

On August 2, 1982, it was determined that there was no documentation to verify secondary containment integrity on a 31 day basis as required by technical specifications. Attached is LER 82-030/03 L-0.

Yours truly,

*J.P. McGaughey Jr.*  
J.P. McGaughey J.R.

JPM:ac  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8209020561 820826  
PDR ADOCK 05000416 PDR  
S

Member Middle South Utilities System

OFFICIAL COPY

TE 22

02 AUG 30 1982  
REGION II  
ATLANTA, GEORGIA