NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

# LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | ILZIS1 (2) | 00-00000-00 (3) | 411 11 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05000295 (7) | 073082 (8) | 082782 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During power operations with Unit One at 100% power, S.I. Accumulator
03 Tanks 1B & 1D Level transmitters were found exceeding allowable loop
04 tolerance of ± 4.5% with a maximum error of minus 14%. The actual
05 levels in Tanks 1B & 1D could have exceeded maximum allowable level
06 (868.14 cu. ft.) by 8.27 cu. ft. & 4.13 cu. ft., respectively. Tanks
07 1A & 1C were within limits. Previous LER's 50-295/78-110,
08 50-304/78-73, 50-304/78-74.

09 SYSTEM CODE SF (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE T (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 — SEQUENTIAL REPORT NO. 024 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER L (25) | COMPONENT MANUFACTURER M040 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The x-mtrs (Magnetrol #82) were recalibrated and returned to service.
11 The exact cause for this drifting is unknown at this time. Modifica-
12 tions to calibration procedures and sightglass piping have failed to
13 correct the problem. Further Investigation will be conducted-Update
14 to follow.

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41) NA

8209030181 820827
PDR ADOCK 05000295
S PDR

19 LOSS OF OR DAMAGE TO FACILITY: TYPE Z (42) | DESCRIPTION (43) NA

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

NAME OF PREPARER P. F. Cantwell PHONE: (312) 746-2084, ext 507

GPO 917-926