

Appendix

NOTICE OF DEVIATION

Wisconsin Public Service
Corporation

Docket No. 50-305

Based on the inspection conducted on July 12-15, 1982, it appears that certain of your activities were not in accordance with commitments which you made in previous correspondence with the Commission.

1. In a letter to the Division of Licensing, NRR, dated April 23, 1982, you stated that procedures addressing sample collection and analysis for postaccident releases of airborne radioactive iodines and particulates would be developed by July 1, 1982.

Contrary to this, the procedures had not been developed as of July 15, 1982.

2. In letters to the Division of Licensing, NRR, dated December 18, 1981, and April 23, 1982, you indicated that a high range radiation monitor meeting the requirements of NUREG-0737, Item II.F.1.3 would be operational by May 30, 1982.

Contrary to this, as of July 15, 1982, the installed monitors were not operational due to electrical misconnections and failure to calibrate in accordance with the requirements of Table II.F.1-3 of NUREG-0737, Item II.F.1.3, clarification Item 1.

3. In a letter to the Division of Licensing, NRR, dated April 23, 1982, you stated that operating procedures for the Postaccident Sampling System (NUREG-0737, Task Action Item II.B.3) were expected to be completed by July 1, 1982.

Contrary to this, procedures concerning the transfer and analysis of containment air samples had not been developed as of July 15, 1982.