

SEP 02 1982

Docket No. 50-219  
LS05-82 -09-011

Mr. P. B. Fiedler, Vice President and Director  
Oyster Creek Nuclear Generating Station  
Post Office Box 388  
Forked River, New Jersey 08731

Dear Mr. Fiedler:

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION, SAFETY EVALUATION  
OF SEP TOPIC XV-19, RADIOLOGICAL CONSEQUENCES OF A LOSS OF  
COGLANT ACCIDENT

Enclosed is the staff's final evaluation of SEP Topic XV-19 for the Oyster Creek Plant. The evaluation has been revised from the draft evaluation sent to you on June 29, 1982, based on information supplied by you. The revised portions have been marked with a line in the right hand column to designate the changes. The staff now estimates that the 30 day low population zone (LPZ) doses could exceed the allowable specified in 10 CFR 100 by approximately 14% (341 vs. 300 rem) instead of 20% as in the draft evaluation. Since the activity leakage pathway that contributes over 95% (334 rem) of the estimated dose is still from the main steam isolation valve (MSIV) leakage the recommendations outlined in the draft evaluation are still valid. These are as follow:

1. Perform a more realistic analysis for MSIV doses factoring in the effects of drywell pressure vs. MSIV leakage rate as a function of time. The total MSIV leakage then should be lower than assumed by the staff.
2. Evaluate the merits of directing the turbine building ventilation exhaust through a charcoal filter system.
3. Evaluate the merits of installing MSIV leakage prevention systems.
4. Any other procedure or system modifications that will limit the total LOCA doses from all pathways to less than 300 rem.

SEO4  
DSU 456(51)

ADD:  
R. FELL

This evaluation will be a basic input to the integrated safety assessment for your facility unless you identify changes needed to reflect the as-built conditions at your facility. This assessment may be

8209030302 820902  
PDR ADOCK 05000219  
P PDR

OFFICE							
SURNAME							
DATE							

P. B. Fiedler

-2-

revised in the future if your facility design is changed or if NRC criteria relating to this subject is modified before the integrated assessment is completed.

Sincerely,

Dennis M. Crutchfield, Chief  
Operating Reactors Branch No. 5  
Division of Licensing

Enclosure:  
As stated

cc w/enclosure:  
See next page

OFFICE	SEP B:DL	SEP B:DL	SEP B:DL	SEP B:DL	ORB#5:PM	ORB#5:BC	AD:SA:DL
SURNAME	TMichaels:dk	RFell	CGrimes	WRussell	JLombardo	DCrutchfield	Tippolito
DATE	8/5/82	8/1/82	8/8/82	8/12/82	8/2/82	8/2/82	8/2/82

Mr. P. B. Fiedler

cc

G. F. Trowbridge, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Resident Inspector  
c/o U. S. NRC  
Post Office Box 445  
Forked River, New Jersey 08731

J. B. Lieberman, Esquire  
Berlack, Israels & Lieberman  
26 Broadway  
New York, New York 10004

Commissioner  
New Jersey Department of Energy  
101 Commerce Street  
Newark, New Jersey 07102

Ronald C. Haynes, Regional Administrator  
Nuclear Regulatory Commission, Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

J. Knubel  
BWR Licensing Manager  
GPU Nuclear  
100 Interplace Parkway  
Parsippany, New Jersey 07054

Deputy Attorney General  
State of New Jersey  
Department of Law and Public Safety  
36 West State Street - CN 112  
Trenton, New Jersey 08625

Mayor  
Lacey Township  
818 Lacey Road  
Forked River, New Jersey 08731

U. S. Environmental Protection  
Agency  
Region II Office  
ATTN: Regional Radiation Representative  
26 Federal Plaza  
New York, New York 10007

Licensing Supervisor  
Oyster Creek Nuclear Generating Station  
Post Office Box 388  
Forked River, New Jersey 08731

XV-19 LOSS-OF-COOLANT ACCIDENTS RESULTING FROM A SPECTRUM OF POSTULATED PIPING BREAKS WITHIN THE REACTOR COOLANT PRESSURE BOUNDARY (RADIOLOGICAL CONSEQUENCES) - OYSTER CREEK

I. INTRODUCTION

Loss-of-coolant accidents (LOCA's) are postulated breaks in the reactor coolant pressure boundary resulting in a loss of reactor coolant at a rate in excess of the capability of the reactor coolant makeup system. LOCA's result in excessive fuel damage or melt unless coolant is replenished. Excessive fuel damage can result in significant radiological consequences to the environment via leakage from the containment. SEP Topix XV-19 is intended to assure that the radiological consequences of a design basis LOCA from containment leakage, ESF leakage, containment purge and leakage through the main steam isolation valves (MSIV's) are within the exposure guideline values of 10 CFR Part 100.

II. REVIEW CRITERIA

Section 50.34 of 10 CFR Part 50 requires that each applicant for a construction permit or operating license provide an analysis and evaluation of the design and performance of structures, systems, and components of the facility with the objective of assessing the risk to public health and safety resulting from operation of the facility. The LOCA is one of the postulated accidents used to evaluate the adequacy of these structures, systems, and components with respect to the public health and safety.

In addition, 10 CFR Part 100.11 provides dose guideline values for reactor siting assessments.

### III. RELATED SAFETY TOPICS

Topic II-2.C, "Atmospheric Transport and Diffusion Characteristics for Accident Analysis" provides the meteorological data used to evaluate the offsite doses. Topic III-5.A, "Effects of Pipe Breaks on Structures, Systems and Components Inside Containment" ensures that the ability to achieve safe shutdown or to mitigate the consequences of an accident are maintained. Various other topics examine such areas as containment integrity and isolation, post accident chemistry, ESF systems, combustible gas control and control room habitability.

### IV. REVIEW GUIDELINES

The review of the radiological consequences of a LOCA was conducted in accordance with Appendices A, B, and D to Standard Review Plan 15.6.5 and Regulatory Guide 1.3. The plant is adequately designed against a LOCA and the dose mitigating features are acceptable only if the resulting doses at the exclusion area and low population zone boundaries are within the guideline values of 10 CFR Part 100.

### V. EVALUATION

In the licensee submittal to NRC, the licensee provided a full spectrum of loss-of-coolant accidents as a result of various primary system pipe break sizes. The submittal, however, did not provide sufficient detail to permit an independent analysis and questions were sent to the licensee on April 7, 1982 by teletype. Based on the licensee's response to the questions dated April 28, 1982 (in a letter from Drew G. Holland of GPU Nuclear to Robert Fell

of NRC), the staff performed an analysis of the radiological consequences according to the current NRC criteria.

The radiological consequences of this accident result from the following sources:

1. Containment Leakage: The licensee in his April 28, 1982 letter indicates that there is no containment leakage which bypasses the SGTS filters. (Because any bypass leakage paths can alter the conclusions reached in this evaluation, the licensee should confirm this statement by submitting the details on how each leakage path was considered in arriving at the conclusion that no containment leakage bypasses the area processed by the SGTS.) The calculated dose from containment leakage is derived solely from the 0.5% per day Technical Specification leakage limit from the primary containment, complete mixing in the secondary containment and then processing by the SGTS prior to release to the environment.

Based on information provided by the licensee on filter efficiencies, the staff has determined that an appropriate value for the filter efficiencies is 90%.

2. Main Steam Isolation Valve Leakage: Oyster Creek does not have a main steam isolation valve leakage control system (MSIV-LCS). In our analysis, we have assumed that the MSIV's leak at a rate of 11.5 scfh. The value of 11.5 scfh was determined from the acceptance criteria of the plant's test program for

these valves. The staff has estimated that a holdup of fission products will occur in the 100 foot section of main steam piping between the outboard isolation valve and the turbine stop valves. Leakage is assumed to occur at ground level.

The resulting 0-30 day LPZ doses based on the 11.5 scfh per MSIV is 334 rem for the thyroid and 0.2 rem whole body. The length of the main steam pipe section between the outboard main steam isolation valve and the turbine stop valves is critical to this conclusion. The estimated length of pipe (100 feet) was supplied by the licensee, and because of its importance to the calculation, should be verified by the licensee.

3. Post-LOCA Leakage from ESF Systems Outside Primary Containment: Because the ECCS leakage will be to the reactor building and the SGTS includes an ESF grade filtration system which filters the reactor building exhaust, we have not calculated the doses from passive failures (according to Appendix B to Standard Review Plan Section 15.4.5). We have calculated the doses resulting from anticipated operational leakage. No Technical Specification limit on the leakage from ESF systems outside containment exists. We have assumed one gpm total leakage in the calculation of the ESF component leakage contribution to the LOCA doses.
4. Containment Purge: The existing purge valves will close in about one minute from an initiating signal. The licensee in his April 28, 1982 letter indicates plans to replace these valves with ones that will close within 5 seconds. The licensee should submit confirmation of these plans and a schedule for their installation. The staff has evaluated the potential contribution to the LOCA dose from operation of the purge system during the

onset of an accident and has determined that the contribution is much less than 0.1 rem and, therefore, is negligible.

#### VI. CONCLUSION

The calculated doses and assumptions used to arrive at these doses are presented in Table XV-1 and XV-2, respectively. The evaluation indicates that the 0-30 day LPZ thyroid dose guideline is exceeded by approximately 14%. The staff notes that a major portion of this dose is attributed to MSIV leakage. As noted earlier, the licensee needs to provide information to support the statement (in the April 28, 1982 letter) that no containment leakage bypasses the area served by the SGTS.

The staff concludes that because of the uncertainties in the calculation of the doses and because the estimated thyroid doses exceed the 0-30 day 10 CFR 100 thyroid dose LPZ guideline value by only approximately 14%, any plant backfit considerations can be appropriately pursued during the integrated assessment.

TABLE XV-1

RADIOLOGICAL CONSEQUENCES OF A LOCA AT OYSTER CREEK

	<u>Duration</u>		<u>Exclusion Area Boundary</u>		<u>Low Population Zone</u>	
	<u>From Hrs.</u>	<u>To Hrs.</u>	<u>Thyroid Rem</u>	<u>Whole Body Rem</u>	<u>Thyroid Rem</u>	<u>Whole Body Rem</u>
CONTAINMENT LEAKAGE	0.0	2.0	3.8	0.1	1.4	0.1
	2.0	4.0	-	-	3.8	0.1
	4.0	8.0	-	-	0.3	0.1
	8.0	24.0	-	-	0.2	0.1
	24.0	96.0	-	-	1.0	0.2
	96.0	720.0	-	-	0.4	0.2
MSIV* LEAKAGE	37.5	96.0	-	-	170	0.1
	96.0	720.0	-	-	164	0.1
ESF LEAKAGE	0.0	2.0	<0.1	<0.1	-	-
	0.0	720.0	-	-	0.01	<0.01
Total LOCA doses			3.8	0.2	341	1.0

\* The leakage from this source is assumed to start 37.5 hours into the accident and, therefore, there is no contribution to the EAB dose.

TABLE XV-2

ASSUMPTIONS USED IN THE ANALYSIS OF THE RADIOLOGICAL CONSEQUENCES OF ALOCA AT OYSTER CREEK

1. Reactor stretch power (Mwt)	1934
2. Fission product release fractions (percent)	
a. Iodines	25
b. Noble gases	100
3. Primary containment volume (cubic feet)	180,000
4. Primary containment leak rate (%/day)	0.5
5. SGTS filter efficiency (percent) (all forms of iodine)	90
6. MSIV leak rate (scfh)	11.5
7. SGTS bypass leakage	0
8. ESF leakage into reactor building (gpm)	1.0
9. Purge system flow rate (cfm)	1000
10. Time required for purge system isolation (sec)	5
11. X/Q's (sec/cubic meters)	
Ground level release for MSIV leakage	
0-2 hour EAB* (414 m)	7.6 E-4***
0-8 hour LPZ** (1208 m)	6.5 E-5
8-24 hour " "	4.3 E-5
1-4 day " "	1.7 E-5
4-30 day " "	4.8 E-6
Elevated release used for containment leakage (fumigation conditions)	
0-2 hour EAB	1.1 E-4
0-4 hour LPZ	4.2 E-5
(non-fumigation conditions)	
4-8 hour LPZ	9.1 E-7
8-24 hour LPZ	2.5 E-7
1-4 day LPZ	1.7 E-7
4-30 day LPZ	2.5 E-7

\*Exclusion Area Boundary (10 CFR 100)

\*\*Outer boundary of Low Population Zone (10 CFR 100)

\*\*\*7.6 E-4 =  $7.6 \times 10^{-4}$  = .00076