AUG 3 0 1982

Docket No. 50-329 Docket No. 50-330

Consumers Power Company ATTN: Mr. James W. Cook Vice President Midland Project 1945 West Parnall Road Jackson, MI 49201

Gentlemen:

We have reviewed your response dated August 13, 1982, to our Inspection Report No. 50-329/82-07 and No. 50-330/82-07 dated July 15, 1982. While this response very clearly identifies the corrective actions you have taken or plan to take regarding the 55 defective hangers you identified in your overinspection, we have no confidence that the remaining hangers have been installed in accordance with the original drawings and specifications.

In our letter to you, dated July 15, 1982, we stated .."it is our view that you should reinspect all the supports and restraints installed and inspected in 1980 and perform sample reinspections of the components installed and inspected in 1981 and 1982." We would like to revise this position to clearly identify what will be expected.

It is our position that you shall reinspect all the supports and restraints installed prior to 1981 and perform sample reinspection of the components installed after 1981.

You are requested to submit to this office a schedule for the reinspection program within twenty-five (25) days from the date you receive this letter.

1EOI

## Consumers Power Company


The responses directed by this letter are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Sincerely,

3 W. D. Shafer

R. F. Warnick, Director Office of Special Cases

cc w/ltr/dtd 8/13/82: DMB/Document Control Desk (RIDS) Resident Inspector, RIII The Honorable Charles Bechhoofer, ASLB The Honorable Jerry Harbour, ASLB The Honorable Frederick P. Cowan, ASLB The Honorable Ralph S. Decker, ASLB Michael Miller Ronald Callen, Michigan Public Service Commission Myron M. Cherry Barbara Stamiris Mary Sinclair Wendell Marshall Colonel Steve J. Gadler (P.E.) I. Yin, RIII



2