

ATTACHMENT 3

PROPOSED TECHNICAL SPECIFICATIONS

Inserts

3.6.1.5 ACTION

...

- b. With both MS-PLCS divisions inoperable, restore one division to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

3.6.1.10 ACTION

...

- b. With both PVLCS divisions inoperable, restore one division to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

CONTAINMENT SYSTEMS

MAIN STEAM-POSITIVE LEAKAGE CONTROL SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.1.5 Two independent main steam positive leakage control system (MS-PLCS) divisions shall be OPERABLE.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2 and 3.

ACTION:

2. With one MS-PLCS division inoperable, restore the inoperable division to OPERABLE status within 30 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

6. INSERT

SURVEILLANCE REQUIREMENTS

4.6.1.5 Each MS-PLCS division shall be demonstrated OPERABLE:

- a. By performing Surveillance Requirement 4.6.1.10.a.
- b. At least once per 31 days by verifying compressor OPERABILITY by operating the compressor loaded for at least 15 minutes.
- c. During each COLD SHUTDOWN, if not performed within the previous 92 days, by cycling each motor-operated valve, including the Main Steam Shutoff Valves (MSSV), through at least one complete cycle of full travel.
- d. At least once per 18 months by performance of a functional test, which includes simulated actuation of the division throughout its operating sequence, and verifying that each automatic valve actuates to its correct position and that 8.5 ± 3 psid sealing pressure is established in each steam line.
- e. By verifying the operating instrumentation to be OPERABLE by performance of a:
 1. CHANNEL FUNCTIONAL TEST at least once per 31 days, and
 2. CHANNEL CALIBRATION at least once per 18 months.

CONTAINMENT SYSTEMS

PENETRATION VALVE LEAKAGE CONTROL SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.1.10 Two independent penetration valve leakage control system (PVLCS) divisions shall be OPERABLE.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

ACTION:

a. With one PVLCS ³⁰ division inoperable, restore the inoperable division to OPERABLE status within 30 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

b. INSERT

SURVEILLANCE REQUIREMENTS

4.6.1.10 Each PVLCS division shall be demonstrated OPERABLE:

- a. At least once per 24 hours by verifying division PVLCS accumulator pressure greater than or equal to 101 psig.
- b. During each COLD SHUTDOWN, if not performed within the previous 92 days, by cycling each motor-operated valve through at least one complete cycle of full travel.
- c. At least once per 18* months by performance of a functional test which includes simulated actuation of the system throughout its operating sequence, and verifying that each automatic valve actuates to its correct position and that a sealing pressure greater than or equal to 22 psig is established in each sealing valve.
- d. By verifying the operating instrumentation to be OPERABLE by performance of a:
 1. CHANNEL FUNCTIONAL TEST at least once per 31 days, and
 2. CHANNEL CALIBRATION at least once per 18 months.



*This frequency may be extended to coincide with the refueling outage for the first cycle, scheduled to begin 9-15-87.