

February 16, 1994

Docket No. 50-352

Mr. George A. Hunger, Jr.  
Director-Licensing, MC 52A-5  
PECO Energy Company  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box No. 195  
Wayne, Pennsylvania 19087-0195

Dear Mr. Hunger:

SUBJECT: EXEMPTION FROM 10 CFR PART 50, APPENDIX J, SECTION III.D.1.(a),  
LIMERICK GENERATING STATION, UNIT 1 (TAC NO. M88331)

The Commission has issued the enclosed exemption for the Limerick Generating Station, Unit 1, from a certain requirement of Appendix J to 10 CFR Part 50, in response to your letter dated November 30, 1993.

The exemption removes the requirement that the third Type A test (Containment Integrated Leak Rate Test, or CILRT) for the first 10-year service period be performed at the regular interval during the first 10-year service period. The one-time exemption would extend the third service period by approximately 15 months within the normal 10-year service period.

The exemption is enclosed. A copy of the exemption is being filed with the Office of the Federal Register for publication.

Sincerely,

/s/

Frank Rinaldi, Project Manager  
Project Directorate I-2  
Division of Reactor Projects- I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
Exemption

cc w/enclosure:  
See next page

9403010100 940216  
PDR ADOCK 05000352  
P PDR

DISTRIBUTION:

Docket File	MO'Brien(2)	RBarrett
NRC & Local PDRs	FRinaldi	
PDI-2 Reading	OGC	
TMurley/FMiraglia	EJordan	
Acting ADPR	GHill	
JLieberman	ACRS (10)	
SVarga	OPA	
JCalvo	OC/LFDCB	
CMiller	VMcCree, EDO	
EWenzinger, RGN-I	CAnderson, RGN-I	

NRC FILE CENTER COPY

220236

OFFICE:	LA:PDI-2	PM:PDI-2	D:PDI-2	OGC <i>g/b</i>	AD:RGI <i>nm</i>	D:DRPE
NAME:	MO'Brien	FRinaldi	CMiller	EHOLLER	JCalvo	ALainas
DATE:	2/1/94	2/1/94	2/16/94	2/7/94	2/16/94	2/16/94

DF01



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20565-0001

February 16, 1994

Docket No. 50-352

Mr. George A. Hunger, Jr.  
Director-Licensing, MC 52A-5  
PECO Energy Company  
Nuclear Group Headquarters  
Correspondence Control Desk  
P.O. Box No. 195  
Wayne, Pennsylvania 19087-0195

Dear Mr. Hunger:

SUBJECT: EXEMPTION FROM 10 CFR PART 50, APPENDIX J, SECTION III.D.1.(a),  
LIMERICK GENERATING STATION, UNIT 1 (TAC NO. M88331)

The Commission has issued the enclosed exemption for the Limerick Generating Station, Unit 1, from a certain requirement of Appendix J to 10 CFR Part 50, in response to your letter dated November 30, 1993.

The exemption removes the requirement that the third Type A test (Containment Integrated Leak Rate Test, or CILRT) for the first 10-year service period be performed at the regular interval during the first 10-year service period. The one-time exemption would extend the third service period by approximately 15 months within the normal 10-year service period.

The exemption is enclosed. A copy of the exemption is being filed with the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, appearing to read "Frank Rinaldi".

Frank Rinaldi, Project Manager  
Project Directorate I-2  
Division of Reactor Projects- I/II  
Office of Nuclear Reactor Regulation

Enclosure:  
Exemption

cc w/enclosure:  
See next page

Mr. George A. Hunger, Jr.  
PECO Energy Company

Limerick Generating Station,  
Units 1 & 2

cc:

J. W. Durham, Sr., Esquire  
Sr. V.P. & General Counsel  
PECO Energy Company  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Mr. William P. Dornsife, Director  
Bureau of Radiation Protection  
PA Dept. of Environmental Resources  
P. O. Box 8469  
Harrisburg, Pennsylvania 17105-8469

Mr. Rod Krich, 52A-5  
PECO Energy Company  
955 Chesterbrook Boulevard  
Wayne, Pennsylvania 19087-5691

Mr. James A. Muntz  
Superintendent-Technical  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. David R. Helwig, Vice President  
Limerick Generating Station  
Post Office Box A  
Sanatoga, Pennsylvania 19464

Mr. James L. Kantner  
Regulatory Engineer  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. Robert Boyce  
Plant Manager  
Limerick Generating Station  
P.O. Box A  
Sanatoga, Pennsylvania 19464

Library  
US Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Larry Hopkins  
Superintendent-Operations  
Limerick Generating Station  
P. O. Box A  
Sanatoga, Pennsylvania 19464

Mr. Neil S. Perry  
Senior Resident Inspector  
US Nuclear Regulatory Commission  
P. O. Box 596  
Pottstown, Pennsylvania 19464

Mr. John Doering, Chairman  
Nuclear Review Board  
PECO Energy Company  
955 Chesterbrook Boulevard  
Mail Code 63C-5  
Wayne, Pennsylvania 19087

Mr. Craig L. Adams  
Superintendent - Services  
Limerick Generating Station  
P.O. Box A  
Sanatoga, Pennsylvania 19464