

February 16, 1994

Mr. C. Randy Hutchinson
Vice President, Operations GGNS
Entergy Operations, Inc.
Post Office Box 756
Port Gibson, Mississippi 39150

Dear Mr. Hutchinson:

SUBJECT: GRAND GULF NUCLEAR STATION - NRC BULLETIN 90-01, SUPPLEMENT 1, LOSS OF FILL-OIL IN TRANSMITTERS MANUFACTURED BY ROSEMOUNT (TAC NO. M85392)

By letters dated March 5, 1993, and December 21, 1993, Entergy Operations, Inc., submitted responses to NRC Bulletin 90-01, Supplement 1, "Loss of Fill Oil in Transmitters Manufactured by Rosemount." These responses were reviewed by the NRC staff with the assistance of an NRC contractor, EG&G Idaho (EG&G), Inc. The enclosure to this letter contains our safety evaluation related to your responses. The attachment to the enclosure is the associated EG&G Technical Evaluation Report EGG-ERTP-10908, entitled "Evaluation of Utility Response to Supplement 1 to NRC Bulletin 90-01: Grand Gulf-1," dated October 1993.

Based on our review, we conclude that you have conformed to the requested actions of NRC Bulletin 90-01, Supplement 1, and have completed the reporting requirements. We find your response to the Bulletin to be acceptable. Your compliance and applicable Commission requirements may be the subject of NRC audits or inspections in the future. This action is completed as of the date of this letter with an implementation date of December 21, 1993.

Sincerely,

ORIGINAL SIGNED BY:

Paul W. O'Connor, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File	NRC & LPDRs	PD4-1 r/f	D. Spaulding
P. Noonan	E. Adensam	J. Roe	N. Le
W. Beckner	P. O'Connor	L. Reyes, RII	
ACRS(10)	OGC (15B18)	J. Wermiel	

OFC	LA:PD4-1 <i>W</i>	PM:PD4-1 <i>W</i>	D:PD4-1 <i>W</i>
NAME	PNoonan	PO'Connor	WBeckner
DATE	2/16/94	2/16/94	2/16/94
COPY	YES/NO	YES/NO	YES/NO

NRC FILE CENTER COPY

OFFICIAL RECORD COPY Document Name: GG85392.LTR

9403020006 940216
PDR ADOCK 05000416
PDR

DF01



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555-0001

February 16, 1994

Docket No. 50-416

Mr. C. Randy Hutchinson
Vice President, Operations GGNS
Entergy Operations, Inc.
Post Office Box 756
Port Gibson, Mississippi 39150

Dear Mr. Hutchinson:

SUBJECT: GRAND GULF NUCLEAR STATION - NRC BULLETIN 90-01, SUPPLEMENT 1, LOSS
OF FILL-OIL IN TRANSMITTERS MANUFACTURED BY ROSEMOUNT
(TAC NO. M85392)

By letters dated March 5, 1993, and December 21, 1993, Entergy Operations, Inc., submitted responses to NRC Bulletin 90-01, Supplement 1, "Loss of Fill Oil in Transmitters Manufactured by Rosemount." These responses were reviewed by the NRC staff with the assistance of an NRC contractor, EG&G Idaho (EG&G), Inc. The enclosure to this letter contains our safety evaluation related to your responses. The attachment to the enclosure is the associated EG&G Technical Evaluation Report EGG-ERTP-10908, entitled "Evaluation of Utility Response to Supplement 1 to NRC Bulletin 90-01: Grand Gulf-1," dated October 1993.

Based on our review, we conclude that you have conformed to the requested actions of NRC Bulletin 90-01, Supplement 1, and have completed the reporting requirements. We find your response to the Bulletin to be acceptable. Your compliance and applicable Commission requirements may be the subject of NRC audits or inspections in the future. This action is completed as of the date of this letter with an implementation date of December 21, 1993.

Sincerely,

A handwritten signature in cursive script that reads "Paul W. O'Connor".

Paul W. O'Connor, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. C. Randy Hutchinson
Entergy Operations, Inc.

Grand Gulf Nuclear Station

cc:

Mr. H. W. Keiser, Exec. Vice President
and Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286-1995

Mr. D. L. Pace
GGNS General Manager
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, Mississippi 39150

Robert B. McGehee, Esquire
Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, Mississippi 39205

The Honorable William J. Guste, Jr.
Attorney General
Department of Justice
State of Louisiana
P. O. Box 94005
Baton Rouge, Louisiana 70804-9005

Nicholas S. Reynolds, Esquire
Winston & Strawn
1400 L Street, N.W. - 12th Floor
Washington, D.C. 20005-3502

Dr. F. E. Thompson, Jr.
State Health Officer
State Board of Health
P. O. Box 1700
Jackson, Mississippi 39205

Mr. Sam Mabry, Director
Division of Solid Waste Management
Mississippi Department of Natural
Resources
P. O. Box 10385
Jackson, Mississippi 39209

Office of the Governor
State of Mississippi
Jackson, Mississippi 39201

President,
Claiborne County Board of Supervisors
Port Gibson, Mississippi 39150

Mike Moore, Attorney General
Frank Spencer, Asst. Attorney General
State of Mississippi
Post Office Box 22947
Jackson, Mississippi 39225

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., Suite 2900
Atlanta, Georgia 30323

Mr. Jerrold G. Dewease
Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, Mississippi 39286-1995

Mr. W. W. Watson
Project Manager
Bechtel Power Corporation
P.O. Box 808, 4600 W. Main
Russellville, Arkansas 72801

Mr. Michael J. Meisner
Director, Nuclear Safety
and Regulatory Affairs
Entergy Operations, Inc.
P.O. Box 756
Port Gibson, Mississippi 39150

Mr. K. G. Hess
Bechtel Power Corporation
P. O. Box 2166
Houston, Texas 77252-2166

Mr. Rudolph H. Bernhard
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Route 2, Box 399
Port Gibson, Mississippi 39150