



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038  
Hope Creek Operations

February 15, 1994

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

ANNUAL REPORT  
TECHNICAL SPECIFICATION 6.9.1.5  
HOPE CREEK GENERATING STATION  
DOCKET NO. 50-354

This annual report of challenges to Main Steam Line Safety/Relief Valves (SRVs) is being submitted pursuant to the requirements of Technical Specification 6.9.1.5 for the year of 1993.

On May 16, 1993, Safety/Relief Valves H and P lifted on lo-lo set actuation in response to a turbine control valve closure. The valves operated per design with no malfunctions noted. No additional unplanned challenges occurred in 1993.

Sincerely,

*James Clancy for R. J. Hovey*

R. J. Hovey  
General Manager  
Hope Creek Operations

LAA/

C: Distribution

240014

9403020077 940215  
PDR ADOCK 05000354  
R PDR

The Energy People

*ADD 1/0*