

# DOCUMENT/ PAGE PULLED

ANO. 8209080463

NO. OF PAGES 2

REASON

PAGE ILLEGIBLE

HARD COPY FILED AT. PDR CF

OTHER \_\_\_\_\_

BETTER COPY REQUESTED ON 1 1

PAGE TOO LARGE TO FILM

HARD COPY FILED AT. PDR CF

OTHER \_\_\_\_\_

FILMED ON APERTURE CARD NO 8209080463-01

THRU

8209080463-02

210.120

We have reviewed Specification No. CNS-1206.02-01-0001, 12/10/79, Revision 2, "Design Specification, ASME III, Class 2 and 3 Piping," Revision 4. Provide a data file for a Class 2 or 3 piping system which uses CNS-1206.02-01-0001 as the design specification. The piping line should have a run pipe of 12" diameter or larger and contain at least one branch connection.

Response:

A problem file for code 2/3 RNE, Revision 1 has been provided. This problem contains piping in the Nuclear Service Water System.

210.121

The staff has reviewed the Class 1 stress report on RCL drain lines (EDS Report No. 01-0093-1159).

Table 1.0-3 indicates a usage factor of 0.032 for "Joint Name" 142. Page E62, first line, shows "Cumul Usage" of 0.032, along with "Maximum  $S_{alt}$ " of 210,000 psi. From the Code Figure 1-9-2, the number of allowable design cycles for  $S_a = 210,000$  is about 130. The usage factor of 0.032 implies that the number of anticipated cycles associated with  $S_a = 210,000$  is about  $0.032 \times 130 = 4$  cycles. Provide the basis for assuming only 4 cycles for the fatigue analysis.

Please furnish a detailed description of how the usage factor of 0.032 was determined. The description should include, for each of the transients in Table 4.6-1:

- (a) The pressure range
- (b) Moment ranges due to thermal expansion and OBE (separately)
- (c) Fluid temperature changes as a function of time
- (d) Ranges of  $T_1$ ,  $T_2$ , and  $(T_a - T_b)$
- (e) Stress indices used in the evaluation. If not given in the Code, indicate their source.

Response:

See attached response.

Calculation of the fatigue usage factor for AWBW component at DCP 142: [REDACTED]

a) The input section of the superpipe program;

1. All load cases analysis including the transient loads were run prior to code compliance. They were combined to get proper gravity, thermal and seismic loads for steady state conditions or transient conditions as specified on page E44 of E67.
2. On page E45 of E67, the pressure distributions for all Class 1 pipe run were specified for pressure stress calculations.
3. The temperature distributions were input to find the allowable stresses for piping. See page E46 of E67.
4. The earthquake (OBE) cases were specified with the number of events and cycles per event on page E48 of E67.
5. The steady state load conditions of the transients in Table 4.6-1 were specified with following information shown on page E49 of E67.
  - a. Associated transient state
  - b. Number of occurrence
  - c. Pressure distribution for calculation of pressure stress
  - d. Temperature distribution for allowable stresses
  - e. Thermal load cases made up the steady state conditions
  - f. Load-state identifier to show each steady-state load with or without OBE load or thermal transient. The associated OBE load and thermal transients are defined in next two columns.

b) The output of the program;

1. The detailed fatigue damage calculation was provided. It shows the load pairs which have fatigue damage on the system. It also has the values for allowables ( $S_m$ ), the stress ratio of  $S_n$ , the stress ration for EQ.12 and EQ.13 when  $S_n > 3S_m$ , peak stress,  $K_e$ , alternate stress, number of cycles for each load pair and associated allowable cycles, usage factor of each load pair and the cumulative usage factor. See page 77.

REV	BY	DATE	CHECKED	DATE	eds nuclear	JOB NO	PAGE
						CALC NO	OF
TW	7/1/12						2

2. The summary of fatigue usage and break location only shows the highest values in each equation (EQ.10, 11, ... etc.). See page E62 of E67.

A hand calculation to check computer code compliance was done in the problem file and was provided here for information.

- c) The requested items can be found as follows:
- Pressure range from page E45 of E67. Example is at mid section of 2nd page of hand calculation.
  - Values of moments of each load cases are on the 1st page of hand calculation.
  - Fluid temperature - time history can be found from attached transient analyses. The envelope of thermal transients was also provided on pages D5, D6 and D7 of D8.
  - $\Delta T_1$ ,  $\Delta T_2$  and  $T_a - T_b$  terms are on page D8 of D8.
  - Stress indices are given in the 1974 ASME Code. Values used are on 1st page of hand calculation.

- d) Brief summary for the calculation;

The usage factor of 0.032 was calculated as shown on page 77. The computer calculation was verified by hand calculation for the worst load pair, N-1A-0-1 and U-03-1-1. Following is how every load pair gets the number of anticipated cycles. The worst load pair has OBE in each state and the OBE events were evenly used, that is, two cycles for 1st load pair. N-1A has 253 cycles left, U-03 has 78 cycles left and OBE has 1 event left. The 2nd load pair has OBE in U-3 only and OBE only has 1 event left, so 2nd pair load has one anticipated cycle. The third one was conservatively counted for OBE alone. Total number of cycles is the number of events times cycles per event. The Fourth load pair is N-1A and U-03 with transient. At this moment, N-1A has 252 left, OBE has zero event and U-03 has 77 cycles left, so the fourth one has 77 cycles. The fifth one was determined by U-7B's cycles, 20. Since the allowable cycles exceeds one million cycles, the computation stopped here.

REV	BY	DATE	CHECKED	DATE	eds nuclear	JOB NO CALC NO	PAGE OF
	TW	7/17/82					2 2

DUKE POWER COMPANY-CATAWBA STATION 1  
 EDS PROBLEM 0093-101-HC13 CODE COMPLIANCE REV. 0  
 2 IN RCL DRAIN-LINE FROM XOVER LEG ID TO OVERLAPPED PIPING OF MC12, MC10  
 THERMAL TRANSIENT AND CODE COMPLIANCE ANALYSES

LOAD CASE SPECIFICATION

CASE NAME	LOAD TYPE	COMB TYPE	RESULTS SET	SCALE FACTOR	DATE IDENT.	TIME IDENT.	TITLE
GRAY	GRAV		GRV1	1.000	80/05/16.	10.43.18.	GRAVITY ANALYSIS
OBE1	EQIN	ASUM	OBEA✓ RPVI✓	1.000 1.000	80/05/15. 80/05/19.	18.34.14. 17.06.55.	SEISMIC ANALYSIS SAM-RPV (PRIMARY) <span style="float: right;">(INERTIAL)</span>
OBE2	EQIN	ASUM	OBE1 RCLI✓ RB-1✓	1.000 1.000 1.000	EARLIER LOAD CASE 80/05/19. 80/05/19.	17.06.55. 17.06.55.	SAM-RCL (SECONDARY) REACTOR BUILDING SAM (SECONDARY)
SSE1	EQIN	ASUM	OBE1 LOCA	1.075 1.000	EARLIER LOAD CASE 80/05/19.	17.06.55.	LOCA
THR1	EXPN	DSUM	T957✓ THM3✓	1.000 1.000	80/09/23. 80/05/16.	10.35.55. 10.43.18.	SEGMENT 602 557F THE REST 2 70F FULL POWER THERMAL ANCHOR MOTION
THR2	EXPN	DSUM	T456✓ THM3✓	1.000 1.000	80/09/23. 80/05/16.	10.35.55. 10.43.18.	SEGMENT 60 2 456F THE REST 2 70F FULL POWER THERMAL ANCHOR MOTION
THR3	EXPN		THM1✓	.000	80/05/16.	10.43.18.	NORMAL FULL POWER
U-03	TRNS		U-03 ✓	1.000	80/09/24.	16.38.38.	LOSS OF FLOW IN ONE LOOP.

DUKE POWER COMPANY-CATANBAA STATION 1  
 EDS PROBLEM 0093-101-HC13 CODE COMPLIANCE REV. 0  
 2 IN RCL DRAIN-LINE FROM XOVER LEG 1D TO OVERLAPPED PIPING OF HC12, HC10  
 THERMAL TRANSIENT AND CODE COMPLIANCE ANALYSES

PRESSURE DISTRIBUTIONS FOR PRESSURE STRESSES

DISTRIBUTION NAME	RUN NAME	FIRST DCP	LAST DCP	PRESSURE (PSI)	DISTRIBUTION TITLE
PRE0	ALL RUNS			2485.000	DESIGN PRESSURE
PRE1	ALL RUNS			*.000	0/0
PRE2	RUN1 RUN1 RUN3	140 151 COMPLETE RUN	151 157 COMPLETE RUN	22235.000 *000 *.000	22235/0 USE D /N U-3
PRE3	RUN1 RUN1 RUN3	140 151 COMPLETE RUN	151 157 COMPLETE RUN	360.000 *.000 *.000	360/0
PRE4	RUN1 RUN1 RUN3	140 151 COMPLETE RUN	157 157 COMPLETE RUN	3107.000 *.000 *.000	3107/0

TABLE E- 3 CONT'D

DUKE POWER COMPANY-CATAWBA STATION 1  
 EDS PROBLEM 0093-101-NC13 CODE COMPLIANCE REV. 0  
 2 IN RCL DRAIN-LINE FROM XOVER LEG 10 TO OVERLAPPED PIPING OF NC12, NC10  
 THERMAL TRANSIENT AND CODE COMPLIANCE ANALYSES

TEMPERATURE DISTRIBUTIONS FOR ALLOWABLE STRESSES

DISTRIBUTION NAME	RUN NAME	FIRST DCP	LAST DCP	TEMPERATURE (F)	DISTRIBUTION TITLE
ITEMD					
	ALL RUNS			650.000	DESIGN TEMPERATURE
ITEMI					
	ALL RUNS			70.000	70/70
ITEM2					
	RUN1	140	151	557.000	
	RUN1	151	157	70.000	
	RUN3	COMPLETE RUN		70.000	
ITEM3					
	RUN1	140	151	456.000	
	RUN1	151	157	70.000	
	RUN3	COMPLETE RUN		70.000	

TABLE E-3 CONT'D

DUKE POWER COMPANY-CATAWBA STATION 1  
EDS PROBLEM 0093-101-NC13 CODE COMPLIANCE REV. 0  
2 IN RCL DRAIN-LINE FROM XOVER LEG 1D TO OVERLAPPED PIPING OF NC12, NC10  
THERMAL TRANSIENT AND CODE COMPLIANCE ANALYSES

CONTROL INFORMATION FOR NORMAL CONDITION LOAD STATES

NO. OF EARTHQUAKE CASES = 1  
FATIGUE DAMAGE FOR BREAK LOCATION FLAG = .100  
SN/SM RATIO FOR BREAK LOCATION FLAG = 2.400  
NO. OF HIGHEST SALT VALUES = 0  
STRESS FACTOR FOR EQNS 10,12,13 = 3.000

EARTHQUAKE CASES

CASE NAME	NO. OF EVENTS	CYCLES PER EVENT
OBE2	5	40

WARNING NO. 322      ITEM 1 = OBE2      ITEM 2 = EQIN

SEISMIC OBE

DUKE POWER COMPANY-CATAWBA STATION 1  
 EDS PROBLEM 0093-101-NC13 CODE COMPLIANCE REV. 0  
 2 IN RCL DRAIN-LINE FROM XOVER-LEG 1D TO OVERLAPPED PIPING OF NC12, NC10  
 THERMAL TRANSIENT AND CODE COMPLIANCE ANALYSES

LOAD-STATES FOR NORMAL CONDITIONS

STEADY STATE	TRANS STATE	NO. OF OCCUR.	EQKE SUPPRESS	PRES DIST	TEMP DIST	STST TRNS	STEADY-STATE LOAD CASES	LOAD-STATE IDENTIFIER	EQKE CASE	THR M TRANS	DYN U CASE	TRANSIENT CASES	TITLE
			1 2 3										
N-1A		255		PRE1 PRE1	TEM1 TEM1		THR3 ✓	N-1A- 0-0 N-1A- 0-1	0BE2				
N-06		999999		PRE2 PRE2	TEM2 TEM2		THR1	N-06- 0-0 N-06- 0-1	0BE2				
U-03		80		PRE2 PRE2	TEM2 TEM2		THR1	U-03- 0-0 U-03- 0-1	0BE2				
	1	80		PRE PRE	TEM2 TEM2		THR1	U-03- 1-0 U-03- 1-1	0BE2	U-03	U-03		
U-78		20		PRE3 PRE3	TEM3 TEM3		THR2	U-78- 0-0 U-78- 0-1	0BE2				
T-28		55		PRE4 PRE4	TEM1 TEM1		THR3	T-28- 0-0 T-28- 0-1	0BE2				
				1	↑								
				VALUES PROVIDED ON PG. E45	VALUES PROVIDED ON PG. E46.		DEFINITION ON PG. E44						

SUPERFIRE FCRD-1A/AD/74

80/09/24 16.38.38.

CASE 77

DUKE POWER COMPANY-CATAWBA STATION 1  
EDS PROBLEM 0093-101-NC13 CODE COMPLIANCE REV. 0  
2 IN RCL DRAIN-LINE FROM XOVER LEG 1D TO OVERLAPPED PIPING OF NC12, NC10  
THERMAL TRANSIENT AND CODE COMPLIANCE ANALYSES

FATIGUE DAMAGE COMPUTATION, SOP NO. 3W

RUN	DCP	COMP	COMP	SECTION	MATERIAL
NAME	NAME	NAME	TYPE	NAME	NAME

RUN1 142 AWBW AWBW SA376 TP304

(MATERIAL DEFAULTS TO ADJACENT COMPONENTS)

STATE	STATE	SM	SN/(1)SM (PSI)	SE/(1)SM (EQ10)	S/(1)SM (EQ12)	SP	KE	S-ALT (PSI)	NO. OF CYCLES ALLOWED	CYCLES	USAGE	CUMUL
A	B					(PSI)					FACTOR	USAGE
N-1A- 0-1	U-03- 1-1	16830.00	4.306**	.780	.839	171617.72	2.45	210292.96	2	148	.014	.014
N-1A- 0-0	U-03- 1-1	16830.00	2.969**			115365.43	1.00	57682.72	1	10162	.000	.014
	OBE2			16830.00	2.690**			113199.86	1.00	56599.93		
N-1A- 0-0	U-03- 1-0	16830.00	1.661			60330.38	1.00	30165.19	200	10995	.018	.032
U-7B- 0-0	T-28- 0-0	17972.00	1.302			50547.09	1.00	25273.54	77	309356	.000	.032
									20	1000000	0.000	

DETAILED CALC. FOR  
NO. OF CYCLES &  
USAGE FACTOR.

FATIGUE DAMAGE COMPUTATION, SOP NO. 3R

RUN	DCP	COMP	COMP	SECTION	MATERIAL
NAME	NAME	NAME	TYPE	NAME	NAME

RUN1 142 97 STRP 2S160IN SA376 TP304

THIS WAS  
CHECKED BY  
HAND CALCS.

STATE	STATE	SM	SN/(1)SM (PSI)	SE/(1)SM (EQ10)	S/(1)SM (EQ12)	SP	KE	S-ALT (PSI)	NO. OF CYCLES ALLOWED	CYCLES	USAGE	CUMUL
A	B					(PSI)					FACTOR	USAGE
N-1A- 0-1	U-03- 1-1	16830.00	3.281**	.557	.698	59786.45	1.31	39225.24				
N-1A- 0-0	U-03- 1-1	16830.00	2.326			43714.37	1.00	21857.19	2	61454	.000	.000
									1	1000000	0.000	

FATIGUE DAMAGE COMPUTATION, SOP NO. 4L

RUN	DCP	COMP	COMP	SECTION	MATERIAL
NAME	NAME	NAME	TYPE	NAME	NAME

RUN1 143 97 STRP 2S160IN SA376 TP304

STATE	STATE	SM	SN/(1)SM (PSI)	SE/(1)SM (EQ10)	S/(1)SM (EQ12)	SP	KE	S-ALT (PSI)	NO. OF CYCLES ALLOWED	CYCLES	USAGE	CUMUL
A	B					(PSI)						

## FATIGUE USAGE AND BREAK LOCATION SUMMARY

RUN NAME • RUN#	SUP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	MAX E10 SN/115M	BREAK LOC. SE/115M	MAX E12 SN/115M	MAX E13 SN/115M	MAX SP (PSI)	MAXIMUM SALT USAGE (PSI)	CUMUL USAGE	BREAK LOC.	
<u>SUMMARY</u>															
3W	142	AWBW	AWBW	STRP	25160IN	SA376 TP304	4.306	***	*780	*852	171617.72	210292.96	*032		
3R	142	97	STRP	25160IN	SA376 TP304	3.281	***	*557	*698	59786.45	39225.24	*000			
4L	143	97	STRP	25160IN	SA376 TP304	3.072	***	*552	*690	56277.28	30403.90	*000			
4R	143	C35	CRVP	25160IN	SA376 TP304	4.388	***	*871	*864	107595.85	10641.42	*002			
5L	144	C35	CRVP	25160IN	SA376 TP304	2.635	***	*028	*055	84641.42	55130.78	27565.39	*000		
5R	144	98	STRP	25160IN	SA376 TP304	1.916				36817.10	18409.05	0.000			
6L	144A	98	STRP	25160IN	SA376 TP304	1.658				32464.28	16232.14	0.000			
6W	144A	AWBW	AWBW	STRP	25160IN	SA376 TP304	1.658				65112.99	32556.49	*000		
6R	144A	98A	STRP	25160IN	SA376 TP304	1.283				25146.64	12573.32	0.000			
7L	145	98A	STRP	25160IN	SA376 TP304	2.170	***	*217	*727	41202.39	20601.20	0.000			
7R	145	C36	CRVP	25160IN	SA376 TP304	3.051				61769.45	30884.72	*000			
8L	146	C36	CRVP	25160IN	SA376 TP304	1.811				42153.37					
8R	146	99	STRP	25160IN	SA376 TP304	1.344				28125.00	21076.68	0.000			
9L	146A	99	STRP	25160IN	SA276 TP304	*977				21786.49	14062.50	0.000			
10L	146B	99	STRP	25160IN	SA276 TP304	*863				21093.25	0.000				
10W	146B	AWBW	AWBW	STRP	25160IN	SA276 TP304	1.062				19687.30	9843.65	0.000		
11L	146C	99A	STRP	25160IN	SA276 TP304	*761				40970.31	20485.15	0.000			
12L	147	99A	STRP	25160IN	SA376 TP304	*879				17739.80	8869.90	0.000			
12R	147	C37	CRVP	25160IN	SA376 TP304	1.101	***			20118.08	10059.04	0.000			
13L	147A	C37	CRVP	25160IN	SA376 TP304	2.405				30142.99	15071.49	0.000			
13R	147A	100A	STRP	25160IN	SA376 TP304	1.739				50824.26	25412.13	0.000			
14L	147B	100A	STRP	25160IN	SA376 TP304	1.128				33905.60	16952.80	0.000			
14W	147B	AWBW	AWBW	STRP	25160IN	SA376 TP304	1.433				22661.50	11330.75	0.000		
15L	147C	1001	STRP	25160IN	SA376 TP304	*832				56415.00	28207.50	*000			
16L	148	1001	STRP	25160IN	SA376 TP304	1.016				17328.90	86664.45	0.000			
16R	148	C38A	CRVP	25160IN	SA376 TP304	1.306				20636.65	10318.32	0.000			
17L	148A	C38A	CRVP	25160IN	SA376 TP304	2.051				30926.99	15463.49	0.000			
17R	148A	100	STRP	25160IN	SA376 TP304	1.503				43927.26	21963.63	0.000			
18L	148B	100	STRP	25160IN	SA376 TP304	1.221				29303.50	14651.75	0.000			
18W	148B	AWBW	AWBW	STRP	25160IN	SA376 TP304	1.563				24331.13	12165.56	0.000		
19L	148C	1002	STRP	25160IN	SA376 TP304	*923				62258.68	31129.34	*000			
19W	148C	AWBW	AWBW	STRP	25160IN	SA376 TP304	1.145				18971.87	9485.94	0.000		
20L	149	1002	STRP	25160IN	SA376 TP304	1.107				43501.30	21750.65	0.000			
20R	149	C38B	CRVP	25160IN	SA376 TP304	1.443				22281.94	11140.97	0.000			
21L	149A	C38B	CRVP	25160IN	SA376 TP304	1.090				33394.93	16697.47	0.000			
21R	149A	1008	STRP	25160IN	SA376 TP304	*871				27036.23	13518.11	0.000			
22L	149B	1008	STRP	25160IN	SA376 TP304	*992				18042.81	9021.40	0.000			
23L	149C	1008	STRP	25160IN	SA376 TP304	*897				20218.04	10109.02	0.000			
23W	149C	AWBW	AWBW	STRP	25160IN	SA376 TP304	1.111				18508.40	9254.20	0.000		
24L	150	1003	STRP	25160IN	SA376 TP304	*882				41879.13	20939.56	0.000			
24R	150	C39	CRVP	25160IN	SA376 TP304	1.119				19534.64	9767.32	0.000			
										29267.82	14633.91	0.000			

TABLE E- 3 CONT'D

HAND CALCULATION TO  
CHECK COMPUTER CODE COMPLIANCE:

\* DATA POINT 142 : AWBW AT NOZZLE, 2" SCH 760.

- OD       $T_s$        $B_1$        $C_1$        $K_1$        $F_{IA}$        $B_2$        $C_2$        $K_2$        $K_3$        $C_3$        $C'_3$   
 2.375      0.343      .50      1.10      1.20      1.40      1.0      1.40      2.50      1.7      1.0      .50

- LOAD CASE MOMENTS       $M_x$  (FT-LB)       $M_y$  (FT-LB)       $M_z$  (FT-LB)  
 GRAVITY      -42.56      -4.03      89.11

SEISMIC      54.39      31.66      52.37

SAM RPV      108.49      -144.14      37.63

SAM RCL      586.79      -798.77      214.18

SAM RB      27.06      -43.26      12.94

LOFA      390.30      -525.74      139.02

(THERM)      THM3       $E_c/E_H = 1.127$       -727.17      361.09      59.48

"      T557       $E_c/E_H = 1.101$       165.28      13.30      -34.16

"      TA56       $E_c/E_H = 1.075$       131.64      11.02      -27.31

- DESIGN PRESSURE = 2485 PSIG =  $P_o$       -  $I = 1.163 \text{ in}^4$

- DESIGN TEMPERATURE = 650°F.

- CHECKING FOR DESIGN & FAULTED CONDITIONS Eq. 9 & 9F.

$$\text{Eq. 9} : S = B_1 \frac{P_o D_o}{2t} + B_2 \frac{D_o M_i}{2t} \quad \left\{ M_i = \text{GRAV} + \text{SEIS} + \text{SAM RPV} \right.$$

$$M_i = (205.44^2 + 179.83^2 + 179.11^2)^{1/2} = 326.53 \text{ ft-lbs.}$$

$$S = .5 \times \frac{2485 \times 2.375}{2 \times 0.343} + 1.0 \times \frac{2.375 \times 326.53 \times 12}{2 \times 1.163}$$

$$= 4301.66 + 4000.90 = 8302.56 \text{ psi. } \checkmark$$

COMPUTER SHOWED: 8304.98 psi OK

0	10/10/80	10/10/80	10/17/80	

eds nuclear

DUKE/CATANBP #1

JOB NO CO 93-101

CALC NO

NC-13

PAGE  
1  
OF  
3

$$EQ. 9F : S = P_1 \frac{P_o D_o}{2t} + P_2 \frac{D_o M_i}{2I} \quad \left\{ M_i = G R A V + S S E (\text{SEISMIC + SAMPLER}) + \text{LOAD} \right.$$

$$M_i = (738.26^2 + 859.40^2 + 396.88^2)^{1/2} = 1800.46 \text{ ft-lbs}$$

$$S = .5 \times \frac{2485 \times 2.375}{2 \times 0.343} + 1.0 \times \frac{2.375 \times 1800.46 \times 12}{2 \times 1.163}$$

$$= 4301.66 + 14708.97 = 19010.63 \text{ Psi}$$

COMPUTER SHOWED 19019.27 Psi OK

CHECKING FOR NORMAL & UPSET CONDITIONS :

$$EQ. 10 : S_n = G \frac{P_o D_o}{2t} + C_2 \frac{M_i D_o}{2I} \frac{1}{\omega(1-\nu)} E \Delta T_i + C_3 E \alpha \sqrt{T_a - T_b}$$

CHECK RANGE OF STEADY STATES N-1A-01 AND U-03-1-1

PRESSURE RANGE : 2835 Psi ✓

THERMAL RANGE : ( $T_{E57} + T_{Hm3}$ ) — ZERO

$\Delta T_i$  RANGE :  $21.87 + 12.35 = 34.22^\circ\text{F}$  ✓

$$M_i = (2191.01^2 + 2457.25^2 + 663.66^2)^{1/2} = 3358.43 \text{ ft-lbs}$$

$$S_n = 1.1 \times \frac{2835 \times 2.375}{2 \times 0.343} + 1.4 \times \frac{3358.43 \times 12 \times 2.375}{2 \times 1.163} + \frac{1}{1.4} \times 257.8 \times 34.22$$

$$= 8511.57 + 57610.21 + 6301.61 = 72423.39$$

COMPUTER SHOWED:  $4.306 \times 16830 = 72469.98$  OK

$$EQ. 12 : S_c = C_2 \frac{M_i D_o}{2I} \quad \left\{ M_i = \text{THERMAL RANGE} \right.$$

$$M_i = (637.55^2 + 421.59^2 + 29.42^2)^{1/2} = 764.90 \text{ ft-lbs}$$

$$S_c = 1.4 \times \frac{764.9 \times 12 \times 2.375}{2 \times 1.163} = 13121.05 \text{ Psi}$$

COMPUTER SHOWED 13127.40 Psi OK

0	TM10101	10/10/80	ME/AS	10/17/80		DUCIE / LPTAWA # 1
						JOB NO 0093-101
						CALC NO
REV	BY	DATE	CHECKED	DATE	eids  nuclear	PAGE 5 OF 3

$$\rightarrow \text{EQ. 13: } S = C_1 \frac{P_D}{2I} + C_2 \frac{In_D}{2I} + C_3 \frac{Ex}{T_a - T_b} \left|_{max}^0 \right.$$

$$M_i = \text{EQ. 9 } m_i = 326.53 \text{ ft-lbs.}$$

$$S = 1.1 \times \frac{8235 \times 2.375}{2 \times 0.343} + 1.4 \times \frac{326.53 \times 12 \times 2.375}{2 \times 1.163} \\ = 8511.57 + 5601.27 = 14112.84 \text{ Psi.}$$

COMPUTER SHOWED : 14120.37 Psi OK

$$\text{EQ. 11 } S_p = k_1 C_1 \frac{P_D}{2I} + k_2 C_2 \frac{In_D}{2I} + \frac{k_3}{2(1-\nu)} Ex \Delta T_1 + \frac{1}{1-\nu} Ex \Delta T_2$$

$$M_i = M_i \text{ EQ. 10} = 3358.43 \text{ ft-lbs} / \Delta T_2 = 6.73^\circ\text{F} /$$

$$S_p = 1.1 \times 1.63 \times \frac{8235 \times 2.375}{2 \times 0.343} + 1.4 \times 0.5 \times \frac{3358.43 \times 12 \times 2.375}{2 \times 1.163} \\ + 1.7 \times \frac{257.81}{1.4} \times 34.22 + \frac{1}{0.7} \times 257.81 \times 6.73 \\ = 14299.44 + 14112.27 + 10712.74 + 2478.66 \\ = 171603.11 \text{ Psi.}$$

COMPUTER SHOWED 171617.72 Psi OK

$$\text{EQ. 14: } S_{ALT} = k_c \frac{S_p}{2}$$

$$k_c = 1 + \frac{1-n}{n(m-1)} \left( \frac{S_n}{S_m} - 1 \right)$$

$$= 1 + \frac{1}{3} \left( \frac{72423.37}{3 \times 16830} - 1 \right) = 2.448$$

$$S_{ALT} = 2.448 \times \frac{171603.11}{2} = 210292.21 \text{ Psi.}$$

COMPUTER SHOWED : 210292.96 Psi. OK


REF: NC-13 LOAD CASE REV.2

NC-13 CODE COMPLIANCE REV.0 80/09/24 12.38.38 . + THERMPL: 80/09/23 10.35.55

0	FINISHED	10/10/80	VERIFIED	10/17/80	DUKE/CATAWBA I		
					JOB NO 0093-101		
					CALC NO		
REV	BY	DATE	CHECKED	DATE	eds	nuclear	NC-13

## THERMAL TRANSIENTS

Sheet 1 of 7

REACTOR COOLANT DRAIN LINES

Sheet 2 of 7

POINT IDENTIFICATION

<u>POINTS</u>	<u>AREA CONSIDERED</u>
PLC P fw { 60 13. } 61	From crossover leg connection to first drain line isolation valve
	Line between two drain line iso- lation valves.

PROJECT DAVY-FENT Program -2 Analysis												BY PCB
TITLE Reactor Coolant - Drain Lines												DATE 8/1/72
Computation No. DS-2-2 3-17												CHIEF T. H. C. P.

NORMAL CONDITIONS													REV. O
N-1 HEATUP													N-3
N-2 COOLDOWN													STEP LOAD INCREASE OF 10% OF FULL POWER
EVENTS	200												
P	0	10	8280	17532	0	9000	17532	17542	0	50	100	300	
60	AMS	285	385	2235	2235	385	385	AMS	2235	2170	2295	2255	
T	0			17532	0				0	50		300	
F	70			557	557			70	558	544		561	
	O				O				O				O
N-4													N-6
STEP LOAD DECREASE OF 10% OF FULL POWER													STEADY STATE FLUCTUATIONS
EVENTS	2,000												
P	0	30	150	300	0	50	75	450, 1200	0	40	100		
60	2235	2310	2160	2235	2235	2375	2160	1960, 2195	2165	2295	2185		
T	558	572	500	556	558	571		1200	0	60	100		
F	O				O			546	555	561	555		
N-7													N-8
UNIT LOADING AT 5% PER MINUTE													
EVENTS	18,300												
P	2235				2235								
60	0	1020			0	1020							
T	557	558			558	557							
F	O				O								

PROJECT	CANDU-6 Reactor Coolant Pressure Test										ECB
TITLE	Reactor Coolant Design Limits										DATE 6/1/73
--	Calculation No. 05-22 4-6-7										7400 3700

		UPSET CONDITIONS						REV. O				
		U-1			U-2			U-3				
		REACTOR TRIP FROM FULL POWER			LOSS OF LOAD WITHOUT IMMEDIATE TURBINE OR REACTOR TRIP			LOSS OF FLOW IN ONE LOOP (TEMPS FOR THE LOOP THAT LOST FLOW)				
EVENTS		400			60			60 (NOTE 4)				
P	60	2235	°	1855	60	100	0	9	31	54	100	0
G0	T	558	561	518	2435	2435	2235	2435	1765	1585	2235	11425 1885 1620
F		548	548	548	558	590	558	57	31	100	560	558 513 558 546 546
		O		O			O				O	
		U-4						U-5				
		LOSS OF FLOW IN ONE LOOP (AVG MIXED TEMPS OF ALL LOOPS)						LOSS OF POWER (BLACKOUT WITH NATURAL CIRCULATION)				
EVENTS		20 (NOTE 4)			60							
P	60	2235	°	1855	35	75	120	1800	3000	600	9900	2235
T		558	561	518	1855	1855	2055	2435	2435	2535	2235	9900
F		574	574	573	574	548	570	50	570	556	556	
		O		O			O				O	
		TEST CONDITIONS										
		T-1			T-2			T-3				
		TURBINE ROLL TEST			PRIMARY SIDE HYDROSTATIC TEST			PRIMARY SIDE LEAK TEST				
EVENTS		10			5			50				
P	60	2235	°	1680	•	3107	•	AMB	3485			
T		557	°	1905				AMB		AMB		
F		O		475			O			O		

PROJECT	INITIATOR PROVOKED ANALYSIS	ECB
TITLE	PROVOKED COOLANT DRAIN LINES	DATE 8/4/78
	CALCULATION NO 05-20 5-27	CHARTS 8/11/78

U-10 UPSET CONDITIONS U-7 <sup>REV 2</sup>

EVENTS	REACTOR TRIP WITH COOLDOWN AND INADVERTENT SI ACTUATION				INADVERTENT RCS DEPRESSURIZATION			
	10	100	1000	20	100	1000	10000	6000
P	2235	1280	2235	2235	2235	1455	1175	791
60 T	558	523	498	488	558	564	555	456
F	-	0	-	-	-	0	-	-

INFORMATION BELOW VOIDED BY REVISION 1

EVENTS	<del>EMERGENCY CONDITIONS</del>			
	<del>SMALL STEAM BREAK</del>	<del>SMALL LOCA</del>	<del>5</del>	<del>5</del>
P	2235	1845	2235	2235
60 T	558	423	378	318
F	-	-	0	(NOTE 2)

REV 1 By: ECBay 2/2/79

Checked: M/Kenning 2/13/79

FAULTED CONDITIONS

EVENTS	LARGE STEAM BREAK				LARGE LOCA			
	1	1	1	1	1	1	1	1
P	2235	773	773	2985	2235	1200	260	45
60 T	557	415	376	270	260	212	558	100
F	-	-	0	-	-	-	0	-

Reactor Coolant Drain Lines  
Transient Analysis  
Calculation No. 05-8.0.0, Rev. C

Sheet 6 of 7

REV 1

By : RC2Aug 2/12

checked : RLH 2/12

General

- a. All pressure valves are PSIG; time is in seconds, flow is gpm, temperature is °F.
- b. All upset conditions (plus the turbine roll test and heatup) are followed by a return to hot shutdown conditions: P returns to 2235 psig at a rate consistent with Tsat returning to 653 F at 100 F/hr. (Except for Loss of Power: P returns at a rate consistent with Tsat returning to 653 @ 200 F/hr).

Specific Notes

1. Point 61 is at ambient temperature and pressure with no flow for all plant conditions considered.

2. Following the small steam break, the plant is returned toward the cold shutdown conditions as follows:

P	4000	11761	25204	25214
	2335	385	365	0
T	4000	12208		
	298	70		

3. Following the small LOCA, the plant is returned toward the cold shutdown condition as follows:

P	3000	15960	15970
	345	345	AMB
T	3000	15944	
	374	70	

NOTES 2 & 3 DELETED  
PER REVISION 1

4. The total number of occurrences of loss of flow in one loop is 80, i.e. the 80 occurrence for the two cases of loss of flow are one in the same. The more limiting of the conditions should be used for each individual line segment.

Load State	Seg. 60		Seg. 61		Seg.		Seg.		No. of Occur.	Trans. Data	Remarks
	Press.	Temp.	Press.	Temp.	Press.	Temp.	Press.	Temp.			
N-1A	0	70	0	70					200	None	Run this Case
N-1B	2235	557	0	70					200	"	Envl. by N-06
N-2A	2235	557	0	70					200	"	Same as N-1B.
N-2B	0	70	0	70					200	"	Same as N-1A.
N-03	2235	557	0	70					2000	"	Envl. by N-06
N-04	2235	557	0	70					2000	"	Envl. by N-06
N-05	2235	558	0	70					200	"	Envl. by N-06
N-06	2185	555	0	70					80	"	Run this Case
N-07	2235	557	0	70					18300	"	Envl. by N-06.
N-08	2235	557	0	70					18300	"	Envl. by N-06.
U-01	2235	558	0	70					400	"	Envl. by N-06.
U-2A	2235	558	0	70					80	"	Envl. by N-06.

**TRANSIENT EVENT IDENTIFICATION**

**TABLE D-3-1  
(Problems NC-10, -11, -13)**

Catawba Nuclear Station, Unit 1

RCL DRAIN LINES

ASME BPVC SECTION III  
CLASS 1 STRESS REPORT

eds<sup>4</sup>nuclear

NOTES:

EDS Report No.  
01-0093-1159

Revision: 0  
Page D 5 of D 8

Load State	Seg. 60		Seg. 61		Seg.		Seq.	Press.	Temp.	Press.	Temp.	Seq.	Press.	Temp.	No. of occur.	Trans. Data	Remarks	
	Press.	Temp.	Press.	Temp.	Press.	Temp.												
U-2B	1585	560	0	70												80	None	Envl. by N-06
U-03	2235	558	0	70												80	U-03	Run this Case.
U-04	2235	558	0	70												80	None	Envl. by N-06
U-0	2235	558	0	70												40	"	Envl. by N-06
U-06	2235	558	0	70												10	"	Envl. by N-06
U-7A	2235	558	0	70												20	"	Envl. by N-05
U-7B	560	456	0	70												20	"	Run this Case.
T-01	2235	557	0	70												10	"	Envl. by N-06
T-2A	0	70	0	70												5	"	Envl. by N-1A
T-2B	3107	70	0	70												5	"	Run this Case.
T-3A	0	70	0	70												50	"	Envl. by N-1A
T-3B	2485	70	0	70												50	"	Envl. by T-2B

NOTES: Segment 61 is always at ambient for all plant conditions.

#### TRANSIENT EVENT IDENTIFICATION

TABLE D-3-1 (cont'd)  
(Problems NC-10, -11, -13)

Catawba Nuclear  
Station, Unit 1

RCL DRAIN LINES

eds nuclear

ASME BPVC SECTION III  
CLASS 1 STRESS REPORT

EDS Report No  
01-0093-1159

Revision: 0  
Page D6 of D8

Load State	Seq. 60		Seq. 61		Seq.		Seq.	No. of occur.	Trans. data	Remarks
	Press.	Temp.	Press.	Temp.	Press.	Temp.				
U-2B	1585	560	0	70				80	None	Envl. by N-06
U-03	2235	558	0	70				80	U-03	Run this Case.
U-04	2235	558	0	70				80	None	Envl. by N-06
U-05	2235	558	0	70				40	"	Envl. by N-06
U-06	2235	558	0	70				10	"	Envl. by N-06
U-7A	2235	558	0	70				20	"	Envl. by N-06
U-7B	560	456	0	70				20	"	Run this Case.
T-01	2235	557	0	70				10	"	Envl. by N-06
T-2A	0	70	0	70				5	"	Envl. by N-1A
T-2B	3107	70	0	70				5	"	Run this Case.
T-3A	0	70	0	70				50	"	Envl. by N-1A
T-3B	2485	70	0	70				50	"	Envl. by T-2B

NOTE: Segment 61 is always at ambient for all plant conditions.

#### TRANSIENT EVENT IDENTIFICATION

TABLE D-3-1 (cont'd)  
(Problems NC-10, -11, -13)

Catawba Nuclear  
Station, Unit 1

RCL DRAIN LINES

eds nuclear

ASME BPVC SECTION III  
CLASS 1 STRESS REPORT

EDS Report No.  
01-0093-1159

Revision: 0  
Page D6 of D8

NOTES:

This is the envelope of all the load states for NC-10, -11, and -13.

\*NC-10 conservatively used 455 cycles including 200 cycles from transient event N-2B

## SIGNIFICANT TRANSIENT EVENTS

TABLE D-3-2  
(Problems NC-10, -11, -13)

Catawba Nuclear  
Station, Unit 1

#### RCL DRAIN LINES

EDS Report No.  
01-0093-1159

eds  nuclear

ASME BPVC SECTION III  
CLASS 1 STRESS REPORT

Revision: 0  
Page D7 of D8

Item(d)

Table: THERMAL TRANSIENT RESULTS  
 Loading: U-3 (Loss of flow in one loop, temperature for loop that lost flow)  
 Segment 60

Section Name	Indices		Time (sec)	$\Delta T_1$ (°F)	$\Delta T_2$ (°F)	$T_{avg}$ T <sub>a</sub>	(°F)	T <sub>b</sub>	Stres: (PSI)
	C <sub>3</sub>	K <sub>3</sub>							
1. 2" Schl60 Butt-Welded Nozzle	1.0	1.7	15.0	21.87	4.35				Sa 4358
(1-1)			15.0	21.87	4.35				Sn 4155
			45.0	12.35	-2.38				Sa 2445
			45.0	12.35	-2.38				Sn 2345
2. 2" Schl60 Strp.	1.0	1.0	15.0	21.87	4.35				Sa 2904
(1-1)			15.0	21.87	4.35				Sn 4155
			45.0	12.35	-2.38				Sa 1624
			45.0	12.35	-2.38				Sn 2345
3. 2" Schl60 5-D Bend	1.0	1.0	15.0	31.63	7.72				Sa 4471
(1-2)			15.5	31.72	6.66				Sn 6025
			45.0	16.22	-3.92				Sa 2286
			45.5	16.34	-3.53				Sn 3104
	Max (T <sub>a</sub> -T <sub>b</sub> )								Sa
	Max (T <sub>a</sub> -T <sub>b</sub> )								Sn
	Max (T <sub>a</sub> -T <sub>b</sub> )								Sa
	Max (T <sub>a</sub> -T <sub>b</sub> )								Sn
	Max (T <sub>a</sub> -T <sub>b</sub> )								Sa
	Max (T <sub>a</sub> -T <sub>b</sub> )								Sn
Ref. Computer	1. AAWQAIG	2. <del>AAWQAIG</del>	3. <del>AAWQAIG</del>	4. <del>AAWQAIG</del>	5. <del>AAWQAIG</del>	6. <del>AAWQAIG</del>			
Seq. Number	7. <del>AAWQAIG</del>	8. <del>AAWQAIG</del>							

NOTES: StrP = Straight Pipe

\* OUTPUT OF TRANSZA PROGRAM.

TABLE D-4  
(Problems NC-10,-11,-13)

## TRANSIENT RESULTS

Catawba Nuclear  
Station, Unit 1

RCL DRAIN LINES

ASME BPVC SECTION III  
CLASS 1 STRESS REPORTEDS Report No.  
01-0093-1159Revision: 0  
Page D8 of D8eds<sup>4</sup>nuclear

#### 4.6 Analysis Combination of Conditions

For analysis purposes, the defined normal, upset, and testing conditions are enveloped by specific combinations of steady-state conditions of temperatures and pressures, transient conditions of rapid temperature changes, and seismic (OBE) effects. These load states are chosen to represent all significant stress cycles. A load fluctuation is considered significant when the total excursion of load stress intensity exceeds the value of the alternating stress intensity obtained from the applicable design fatigue curve for 10<sup>6</sup> cycles. A summary of the enveloped load states is shown below in Table 4.6-1.

TABLE 4.6-1  
CONDITIONS ANALYZED

Transient Event Name	Transient Event Description	Equivalent No. of Occurrences
N-1A	Heatup	255
N-06	Steady-State Fluctuations	(See Note 1)
U-03	Loss of Flow in One Loop	infinite
U-7B	Inadvertent RCS Depressurization	80
T-2B	Primary Side Hydrostatic Test	20
		55

NOTES:

1. For problem NC-10, 455 cycles were used conservatively including 200 cycles from transient event N-2B.

Catawba Nuclear Station, Unit 1

RCL DRAIN LINES

eds nuclear

ASME BPVC SECTION III  
CLASS 1 STRESS REPORT

EDS Report No.  
01-0093-1159

Revision: 0  
Page 13 of 25