



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

August 31, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

20002 P12:38

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Secondary Containment Valve
Inoperable
Reference: LER 82-035/03 L-0
AECM-82/374

On August 3, 1982, during normal operations, plant service water was lost due to closure of a secondary containment isolation valve which did not properly indicate its status in the control room. Attached is LER 82-035/03 L-0.

Yours truly,

J.P. McGaughy
for J.P. McGaughy

JPM:lm
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Document Control Desk (w/a)
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

~~OFFICIAL COPY~~

8209080470 820831
PDR ADOCK 05000416
S PDR

AE1N3

1E22