LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | TNSNP1 (2) | 00-00000-00 (3) | 41111 (4) | (5)

LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT 58

CON'T 01 | REPORT SOURCE L (6) | 05000327 (7) | 080582 (8) | 083182 (9)

DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With unit 1 in mode 1 (Rx at 100% power) at 2109 CST on 08/05/82, one neutron
03 instrumentation power range channel (N41) was declared inoperable due to failing
04 low. This event required entry into action statement 2 of LCO 3.3.1.1. There
05 was no effect upon public health and safety. Previous occurrences - two
06 (SQRO-50-327/82039 and 82059).
07
08

09 SYSTEM CODE IA (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE P (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 — SEQUENTIAL REPORT NO. 101 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN C (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER L (25) | COMPONENT MANUFACTURER P323

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Upon investigation it was found that the power range channel high range power
11 supply (Power Design Model UPM5-X54W) was defective. The power supply was
12 replaced and the channel returned to service at 2345 CST on 08/05/82.
13
14

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Operator observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY: TYPE Z (42) | DESCRIPTION (43) NA

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

8209080554 820831
PDR ADOCK 05000327
S PDR

NRC USE ONLY

Name of Preparer: H. R. Rogers /M. R. Harding Phone: (615) 751-0349