

ATTACHMENT A

Byron Technical Specification Page 3/4 7-22
and
Insert A

k:\nia\brdwd\anubcor\3

9403030147 940221
PDR ADOCK 05000454
P PDR

PLANT SYSTEMS

3/4.7.8 SNUBBERS

LIMITING CONDITION FOR OPERATION

3.7.8 All snubbers shall be OPERABLE. Snubbers excluded from this requirement are those installed on nonsafety-related systems and then only if their failure or failure of the system on which they are installed would have no adverse effect on any safety-related system.

APPLICABILITY: MODES 1, 2, 3, and 4. MODES 5 and 6 for snubbers located on systems required OPERABLE in those MODES.

ACTION:

With one or more snubbers inoperable, within 72 hours replace or restore the inoperable snubber(s) to OPERABLE status and perform an engineering evaluation per Specification 4.7.8g. on the attached component or declare the attached system inoperable and follow the appropriate ACTION statement for that system.

SURVEILLANCE REQUIREMENTS

4.7.8 Each snubber shall be demonstrated OPERABLE by performance of the following augmented inservice inspection program and the requirements of Specification 4.0.5.

a. Inspection Types

As used in this specification, type of snubber shall mean snubbers of the same design and manufacturer, irrespective of capacity.

b. Visual Inspections

Categories

Snubbers are categorized as inaccessible or accessible during reactor operation. Each of these ~~groups~~ ^{Categories} (inaccessible and accessible) may be inspected independently according to the schedule below. ~~The first inservice visual inspection of each type of snubber shall be performed after 4 months but within 10 months of commencing POWER OPERATION and shall include all hydraulic and mechanical snubbers. If all snubbers of each type are found OPERABLE during the first inservice visual inspection, the second inservice visual inspection of that type shall be performed at the first refueling outage. Otherwise, subsequent visual inspections of a given type shall be performed in accordance with the following schedule.*~~

INSERT A

~~*The visual inspection of the inaccessible snubbers for Unit 1, Cycle 3 must be completed by January 24, 1990.*~~

type

INSERT A

determined by Table 4.7-2. The visual inspection interval for each ~~category~~ shall be determined based upon the criteria provided in Table 4.7-2 and the first inspection interval determined using this criteria shall be based upon the previous inspection interval as established by the requirements in effect prior to amendment (*).

* NRC will include the number of the license amendment that implements this change.