



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

82 SEP 3 4 44
August 27, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
ECCS Shutdown - Initiation of
HPCS System
Reference: LER 82-034/01 T-0
AECM-82/369

On August 14, 1982, automatic initiation of HPCS and racking out of RHR/HPCS pump breakers resulted in a Limiting Condition for Operation. Attached is LER 82-034/01 T-0 with supplementary information.

Yours truly,

JPM:lm
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Document Control Desk (w/a)
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

8209080663 820827
PDR ADOCK 05000416
S PDR

AE1N1

Member Middle South Utilities System

OFFICIAL COPY

10 22