

Detroit
Edison

Donald A. Wells
Manager-Quality Assurance
(313) 237-9657

2000 Second Avenue
Detroit, Michigan 48226
(313) 237-8000

50-341

August 27, 1982
EF2-59392

Mr. James G. Keppler, Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Subject: Interim Report of 10CFR50.55(e) Item on Core Spray Pump Motor
Damage (#66)

Dear Mr. Keppler:

This additional interim report on the Core Spray Pump Motor damage problem has been prepared to provide you with the current status of this problem.


This item was originally reported to Mr. J. Konklin of NRC Region III by Project Quality Assurance's Mr. E.L. Thompson, Acting Supervisor-Construction Quality Assurance, on April 1, 1982.

This item deals with a gouge discovered in the shaft of a core spray pump motor. Because of the size and depth of the gouge, Edison Engineering decided that the possibility of internal damage existed, and the motor was shipped off-site to a General Electric repair shop.

The motor was returned to the site, on May 20, 1982. It was conditionally released pending receipt of required documentation as outlined in Purchase Order 059136, and subsequently installed by Edison Maintenance. Based on investigation to date, probable cause of the gouge is assigned to handling equipment on site (fork lift).

Another report on this item, either interim or final, is scheduled to be sent to you on or before December 23, 1982. If you have questions concerning this matter, please contact Mr. G.M. Trahey, Assistant Director-Project Quality Assurance.

Very truly yours,



DAW/DF/cp

8209090091 820827
PDR ADOCK 05000341
S PDR

SEP 7 1982
4827

Mr. James G. Keppler, Regional Administrator
Page Two

August 27, 1982
EF2-59392

cc: Mr. Richard DeYoung, Director
Office of Inspection and Enforcement
Division of Reactor Inspection Programs
Washington, D.C. 20555

Mr. Bruce Little, Resident Inspector
U.S. Nuclear Regulatory Commission
6450 North Dixie Highway
Newport, Michigan 48166

Mr. James G. Keppler, Regional Administrator
Page Three

August 27, 1982
EF2-59392

bcc: T.A. Alessi
J.C. Ard, Jr.
C.R. Bacon
W.F. Colbert
W.M. Everett
W.J. Fahrner
D. Ferencz
E.P. Griffing
C.M. Heidel
W.H. Jens
E. Lusic
P.A. Marquardt/Docket File (2)
E.H. Newton
S.H. Noetzel
J.W. Nunley
J.D. Ryan
L.E. Schuerman
H. Tauber
G.M. Trahey
R.A. Vance/L.E. Eix
A.E. Wegele
Site Document Control
NRC Follow-Up Book/NRC File
Chron File