



February 23, 1994

2CAN029405

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 2  
Docket No. 50-368  
License No. NPF-6  
Annual Diesel Generator Data Report - 1993

Gentlemen:

Arkansas Nuclear One, Unit 2 (ANO-2) Technical Specification 6.9.1.5.g requires an annual submittal of a diesel generator data report for the previous calendar year. This report provides the number of valid tests and the number of valid failures for each diesel generator. The purpose of this letter is to provide this information for 1993.

Fifteen (15) valid tests were conducted on the 2K-4A diesel generator with no valid failures. Fourteen (14) valid tests were conducted on the 2K-4B diesel generator with no valid failures.

This letter completes the reporting requirements for Technical Specification 6.9.1.5.d. Should you have any questions regarding this submittal, please contact me.

Very truly yours,

*Dwight C. Mims*  
Dwight C. Mims  
Director, Licensing

DCM/dwb

940307022B 940223  
PDR ADDCK 0500036B  
R PDR

ADD 1/0

cc: Mr. Leonard J. Callan  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

NRC Senior Resident Inspector  
Arkansas Nuclear One - ANO-1 & 2  
Number 1, Nuclear Plant Road  
Russellville, AR 72801

Mr. George Kalman  
NRR Project Manager Region IV/ANO-1  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 13-H-3  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852

Mr. Thomas W. Alexion  
NRR Project Manager, Region IV/ANO-2  
U. S. Nuclear Regulatory Commission  
NRR Mail Stop 13-H-3  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852