LICENSEE EVENT REPORT
CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 A L J M F 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 6 57 CAT 58
O 1 SOURCE L 6 0 5 0 0 0 3 4 8 7 0 8 0 5 8 2 0 8 3 1 8 2 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 At 1525 on 8/05/82, during the performance of FNP-1-STP-23.8 (Component Cooling Water)
Valve Inservice Test), containment isolation valve CCW-MOV-3052 (CCW to RCP coolers)
[0]4] was declared inoperable when the valve's position indication light was not illuminated.
Tech. Spec. 3.6.3, in part, requires this isolation valve to be operable. Tech. Spec.
[0] [3.6.3 action statement requirements were met. Health/Safety of the public was not
oli affected. A similar occurrence was reported in LER 82-022/03L-0.
[0]8]
SYSTEM CAUSE SUBCODE COMPONENT CODE SUBCODE SU
SEQUENTIAL REPORT NO. 17 PEPORT 8 2
TAKEN ACTION ON PLANT METHOD HOURS (22) SUBMITTED FORM SUB SUPPLIER MANUFACTURER A 18 Z 19 Z 20 Z 21 0 0 0 0 0 N 23 N 24 N 25 W 1 2 0 GAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
This event was caused by a blown fuse in the control circuit. The fuse was replaced
and containment isolation valve CCW-MOV-3052 was declared operable at 1615 on 8/05/82.
T3 L
7 8 9
FACILITY STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 1 5 E 22 1 0 0 29 NA B 31 Surveillance Test 7 2 3 3 44 45 46 80
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 NA
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 1 7 0 0 0 3 Z 38 NA
PERSONNEL INJURIES NUMBER DESCRIPTION (41)
NA NA NA
TYPE DESCRIPTION NA
PUBLICITY B209090187 820831 NRC USE ONLY PDR ADDCK 05000348
S PDR NA 68 69 80
NAME OF PREPARER W. G. Hairston III PHONE (205) 899-5156