

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION!)

0 1 | A | L | J | M | F | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 0 14 15 20 26 30 37 38 58

CON'T
0 1 | I | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 4 | 8 | 7 | 0 | 8 | 0 | 4 | 8 | 2 | 3 | 0 | 8 | 3 | 1 | 8 | 2 | 9
7 8 9 0 14 15 20 26 30 37 38 58 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 0541 on 8/4/82 the instrumentation loop associated with Turbine Impulse
0 3 | Pressure Transmitter PT-447 was declared inoperable when the pressure transmitter
0 4 | failed low. Tech. Spec. 3.3.2, in part, requires this instrumentation loop to be
0 5 | operable. Tech. Spec. 3.3.2 action statement requirements were met. Health/Safety
0 6 | of the public was not affected.
0 7 |
0 8 |

0 9 | C | D | 11 | E | 12 | G | 13 | I | N | S | T | R | U | 14 | T | 15 | Z | 16
7 8 9 10 11 12 13 18 19 20

17 | LEP-RO REPORT NUMBER | 8 | 2 | 21 22 | - | 23 | 0 | 4 | 3 | 24 26 | / | 27 | 0 | 3 | 28 29 | L | 30 | - | 31 | 0 | 32

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NRPD-4 FORMS USE | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
18 | Z | 19 | Z | 20 | 0 | 0 | 0 | 0 | 22 | N | 23 | N | 24 | N | 25 | W | 1 | 2 | 0 | 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event was caused by a faulty power supply card. Following the replacement of
1 1 | the card, the PT-447 instrumentation loop was declared operable at 0715 on 8/04/82
1 2 |
1 3 |
1 4 |

1 5 | F | 28 | 0 | 9 | 1 | 29 | NA | 30 | A | 31 | Operational Event | 32
7 8 9 10 12 13 44 45 46 60

1 6 | Z | 33 | Z | 34 | NA | 35 | NA | 36
7 8 9 10 11 44 45 60

1 7 | 0 | 0 | 0 | 3 | 7 | Z | 38 | NA | 39
7 8 9 11 12 13 60

1 8 | 0 | 0 | 0 | 40 | NA | 41
7 8 9 11 12 60

1 9 | Z | 42 | NA | 43
7 8 9 10 60

2 0 | N | 44 | 8209090191 820831 | PDR ADOCK 05000348 | S | PDR | NRC USE ONLY
7 8 9 10 68 69 80

NAME OF PREPARER: W. G. Hairston, III PHONE: (205) 899-5156