

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

February 23, 1994

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Serial No. 94- 078
NAPS/JHL/GSS
Docket Nos. 50-338
50-339
License Nos. NPF-4
NPF-7


Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT NOS. 1 AND 2
ANNUAL SPECIFIC ACTIVITY REPORT

The results of specific activity analysis in which the primary coolant exceeded the limits of Technical Specification 3.4.8 are to be submitted on an annual basis pursuant to Technical Specification 6.9.1.5.c. There were no instances where the primary coolant exceeded 1.0 $\mu\text{Ci}/\text{gram}$ Dose Equivalent Iodine-131 or 100/E-bar $\mu\text{Ci}/\text{gram}$ during 1993.

If you have any questions or require additional information, please contact us.

Very truly yours,



M. L. Bowling, Manager
Nuclear Licensing and Programs

cc: U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Suite 2900
Atlanta, Georgia 30323

Mr. R. D. McWhorter
NRC Senior Resident Inspector
North Anna Power Station

9403070319 940223
PDR ADDCK 05000338
R PDR

280144

ADD 1/0