PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-III-82- 84 Date: September 3, 1982

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the staff on this date.

Facility:	Consumers Power Company	Licensee Emergency Classification:		
	Palisades Nuclear Power Station	Notification of Unusual Event		
	Docket No. 50-255	Alert		
Covert, MI 49043		Site Area Emergency		
		General Emergency		
		XX Not Applicable		

Subject: RETURN TO OPERATIONS AFTER SIX-WEEK OUTAGE

The reactor was made critical at 10:25 a.m., September 2, 1982, ending an outage which began July 12, 1982, for repair of both cooling tower pumps. Additional maintenance and modification work was completed during the outage.

The modification design for the electrical load sequencer is still being developed (see PNO-III-82-81), and procedures have been prepared in the interim which call for operator action to restart the sequencer in the event of a loss-of-off-site power if followed by a loss of coolant accident. Because of a design deficiency, the sequencer would not automatically provide power from the diesel generator to emergency core cooling system equipment if the ECCS equipment was needed after a loss of off-site power.

The procedures were tested by the licensee September 1, 1982, prior to being authorized by the Office of Nuclear Reactor Regulation to start up. The Resident Inspectors observed the test and were in the control room during startup activities.

The licensee normally reports changes in the Palisades operating status to the news media. Region III (Chicago) does not plan to issue a news announcement.

The State of Michigan will be notified.

Region III was notified of the plant's return to service on September 2, 1982, by the resident inspectors. This information is current as of 8 a.m., September 3, 1982.

Contact: K. Reyes J. Etreeter R. Spessard 384-2540 384-2541 384-2552

DISTR	IBUTION:				
H. St. 1007 MNBB 10 30		Phillips/006	E/W 1001	Willste 1008	
Chairman Palladino EDO			NRR	IE	NMSS
Comm.	Gilinsky	PA		OIA	RES
Comm.	Ahearne	MPA		AEOD	
Comm.	Roberts	ELD	Air Rights 1043		MAIL:
Comm.	Asselstine		SP	INPO /0/8	ADM: DMB
SECY ACRS CA	PDR 1	90220 820903 1&E 11-82-084 PD		NSAC 1010	DOT: Trans Only
PDR	Regions I 1130	, II 1020 , IV	1014, V 1014 Lie	censee (Corpora	ate Office) 1040

QE34 Rev. 5/28/82