## LICENSEE EVENT REPORT

	LIGHTSEL EVENT HEI ONT
•	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	N C B E P 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 57 CAT 58 5
O 1 8	REPORT L 6 0 5 0 - 0 3 2 5 7 0 8 0 9 8 2 8 0 9 0 3 8 2 9  EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
0 2	While reviewing plant procedures to ensure their compliance with technical specifica-
0 3	tions, it was determined that the listing of fire protection detectors in Technical
0 4	Specification Table 3.3.5.7-1 did not reflect actual plant design and configuration.
0 5	[Required surveillance testing of the detectors was being performed in accordance
0 6	with what the technical specification should show (most conservative). This event
0 7	did not affect the health or safety of the public.
0 8	Technical Specification 3.3.5.7, 6.9.1.9c
0 9	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC
7 8	9 10 11 12 13 18 19 20    CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)   10 10 11 12 13 18 19 20   10 11 12 13   18 19 20   18 19 2
110	Due to a personnel oversight, a request for a technical specification change to
	reflect the increased number of detectors, due to a plant modification, was not sub-
1 2	mitted to the Commission. The required change request is currently being processed
13	and will be submitted by September, 1982. A procedure will also be developed to
7 8	provide better control of developing and assuring submittals are made punctually.  9 METHOD OF
1 5	FACILITY STATUS SPOWER OTHER STATUS (30) METHOD OF DISCOVERY DESCRIPTION (32)  [G] (28) [O]
	ACTIVITY CONTENT RELEASE OF RELEASE AMOUNT OF ACTIVITY (35)  Z 3 3 Z 34 NA
	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
7 8	9 PERSONNEL INJURIES (41)
1 8	NUMBER DESCRIPTION (41)  NA
7 8	9 11 12 80  LOSS OF OR DAMAGE TO FACILITY 43  TYPE DESCRIPTION 43
1 9	Z 42 NA 80
2 0	PUBLICITY ISSUED DESCRIPTION 45  PDR ADDCK 05000325 S PDR  NRC USE ONLY  NRC USE ONLY  NRC USE ONLY  8 68 69 80 5
	M I PASTVA IR BUONE 919-457-9521