

JCS

FEB 25 1994

Docket Nos. 50-220  
50-410

Mr. B. Ralph Sylvia  
Executive Vice President - Nuclear  
Niagara Mohawk Power Corporation  
301 Plainfield Road  
Syracuse, New York 13212

Dear Mr. Sylvia:

SUBJECT: COMBINED INSPECTION REPORT NOS. 50-220/94-02 AND 50-410/94-02

This letter refers to the announced inspection conducted by Ms. L. Kay of this office on January 24-28, 1994, at the plant site in Scriba, New York. The inspection included a review of activities authorized for Nine Mile Point Nuclear Station, Units 1 and 2. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed report.

The inspection was directed toward areas important to public health and safety to determine whether activities authorized by the licenses were conducted safely and in accordance with NRC requirements. Within these areas, the inspection consisted of selected examinations of procedures and records, interviews with personnel, and observations by the inspector.

The areas examined during this inspection focused on review of the overall adequacy and implementation of your fire protection program. The inspector reviewed administrative controls governing combustibles, fire risk maintenance evolutions, and fire control capabilities including fire detection and suppression systems.

During this inspection, an unresolved item was identified regarding future assignment of fire brigade members. This item requires further NRC review following implementation of organizational staff changes to verify full brigade response to alarms and no responsibility conflicts exist between the emergency plan for Nine Mile and brigade member duties.

070001

9403080063 940225  
PDR ADOCK 05000220  
G PDR

JED

FEB 25 1994

Niagara Mohawk Power Corporation

2

Your cooperation with us is appreciated. No written response to this letter is required.

Sincerely,

Original Signed by f

William H. Ruland, Chief  
Electrical Section  
Engineering Branch  
Division of Reactor Safety

Enclosure: NRC Region I Inspection Report Nos. 50-220/94-02 and 50-410/94-02

cc w/encl:

C. Terry, Vice President - Nuclear Engineering  
M. McCormick, General Manager, Safety Assessment, Licensing & Training  
R. Abbott, Unit 1 Plant Manager  
J. Mueller, Unit 2 Plant Manager  
D. Greene, Manager, Licensing  
J. Warden, New York Consumer Protection Branch  
G. Wilson, Senior Attorney  
M. Wetterhahn, Winston and Strawn  
Director, Energy & Water Division, Department of Public Service, State of New York  
C. Donaldson, Esquire, Assistant Attorney General, New York Department of Law  
K. Abraham, PAO (2)  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of New York, SLO Designee

FEB 25 1994

Niagara Mohawk Power Corporation

3

bcc w/encl:

Region I Docket Room (with concurrences)

C. Cowgill, DRP

L. Nicholson, DRP

R. Fuhrmeister, DRP

D. Vito

bcc w/encl: (VIA E-MAIL)

M. Shannon, NRR (MXS1)

V. McCree, OEDO

R. Capra, NRR

J. Menning, NRR

D. Brinkman, NRR

RI:DRS

Kay  
*Kay*  
2/24/94

RI:DRS

Ruland  
*Ruland*  
2/25/94

OFFICIAL RECORD COPY  
A:NM940202.INS