

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

September 7, 1982

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET
NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE OCCURRENCE
REPORT BFRO-50-296/82037

The enclosed report provides details concerning the calibration valve for
the suppression chamber high-level switches being found open during routine
surveillance testing. This report is submitted in accordance with Browns
Ferry unit 3 Technical Specification 6.7.2.a(6).

Very truly yours,

TENNESSEE VALLEY AUTHORITY


H. J. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Records Center
Institute of Nuclear Power Operations
1820 Water Place
Atlanta, Georgia 30339

NRC Inspector, Browns Ferry

OFFICIAL COPY

IE 12

8209160098 820907
PDR ADOCK 05000296
S PDR