

APPENDIX A
NOTICE OF VIOLATION

Georgia Institute of Technology
GTTR

Docket No. 50-160
License No. R-97

As a result of the inspection conducted on June 29 - July 2, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

Technical Specification 4.2.b requires that a channel check of the power trip channels and pico-ammeter channels, comparing the channel checks to a heat balance, shall be made weekly when the reactor is operated at a power level at or above one Mw.

Contrary to the above, channel checks and comparisons were not made in that no heat balance calibration checks were made between March 30, 1982 and April 29, 1982 although the reactor was operated at or above one Mw on April 14, 16, and 20, 1982. Additional occurrences of failure to meet TS 4.2.b occurred between May 10 and May 25, 1982 and May 30 to June 17, 1982.

This is a Severity Level IV Violation (Supplement I.D.).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Date: JUL 30 1982