

APPENDIX A

NOTICE OF VIOLATION

Philadelphia Electric Company
Peach Bottom Atomic Power Station
Units 2 and 3
Delta, Pennsylvania

Docket Nos. 50-277
50-278
License Nos. DPR-44
DPR-56

As a result of the inspection conducted on February 2 to 5, 1982, and in accordance with the NRC Enforcement Policy, 10 CFR 2 Appendix C, the following violation was identified:

10 CFR 20.203(e) requires each area in which licensed material is stored in excess of a specified amount to be conspicuously posted with the radiation caution symbol and the words "CAUTION (or DANGER) RADIOACTIVE MATERIAL(S)".

Contrary to the above, on February 3, 1982, licensed material in excess of the amounts specified in 10 CFR 20.203(e) was stored outside of the Unit 2 Reactor Building, and was not properly posted.

This is a Severity Level V violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, Philadelphia Electric Company is hereby required to submit to this office within thirty days of the date of the letter that transmits this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

OFFICIAL RECORD COPY