

APPENDIX A

NOTICE OF VIOLATION

Philadelphia Electric Company  
Peach Bottom Unit 3

Docket/License: 50-278/DPR-56

During inspection on July 1 - August 6, 1982, the following violation was identified under the NRC Enforcement Policy (10CFR2 Appendix C), 47FR9987 (March 9, 1982).

Technical Specification 6.13, High Radiation Area, requires high radiation areas where the intensity of radiation is greater than 1000 millirem per hour to be provided with locked doors to prevent unauthorized entry.

Contrary to the above, about 3:45 p.m. on July 8, 1982, the intensity of radiation exceeded 1000 millirem per hour in the 3B Mechanical Compressor Room and the door to the room was not locked.

This is a Severity Level IV Violation (Supplement IV).

Pursuant to 10CFR2.201, Philadelphia Electric Company is hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply including the corrective steps which have been taken and results achieved, corrective steps which will be taken to avoid further violations, and the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending your response time.