

APPENDIX A  
NOTICE OF VIOLATION

Northeast Nuclear Energy Co.  
Millstone Nuclear Energy Station Unit 3

Docket No. 50-423  
License No. CPPR-113

As a result of the inspection conducted July 12-16, 1982, and in accordance with the NRC Enforcement Policy, 10 CFR 2, Appendix C, 47 FR 9987 (March 9, 1982), the following violation was identified:

- A. 10 CFR 50, Appendix B, Criteria V and Northeast Utilities' QA Program Topical Report, Section 5, states that activities affecting quality shall be accomplished in accordance with (the prescribed) instructions, procedures, or drawings. Stone and Webster Job Specification No. C-999, "Placing Concrete and Reinforcing Steel", states, that water stops shall be placed in accordance with the Engineers' detail drawings.

Contrary to the above, on July 13, 1982, the water stops placed in concrete construction joint keyways of the circulating water discharge tunnel were not installed in accordance with the Engineers' detail drawings number EC-16 C and D in that they were located at the center of the keyway.


This is Severity Level V Violation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, Northeast Nuclear Energy Company is hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation. Where good cause is shown, consideration will be given to extending your response time.

The responses directed by this Notice are not subject to the clearance procedures of, the Office of Management and Budget as required by the Paper work Reduction Act of 1980, PL 96-511.

Dated \_\_\_\_\_

SEP 01 1982

  
\_\_\_\_\_  
Thomas T. Martin, Director  
for Division of Engineering and  
Technical Programs