

*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION  
P.O. BOX 128  
SAN CLEMENTE, CALIFORNIA 92672

RECEIVED  
SEP 7 11 12 82

SCE

H. B. RAY  
STATION MANAGER

TELEPHONE  
(714) 492-7700

September 2, 1982

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-206  
14-Day Follow-Up Report  
Licensee Event Report (LER) No. 82-022  
San Onofre Nuclear Generating Station, Unit 1

Reference: Letter, H.B. Ray (SCE) to R.H. Engelken (NRC),  
Confirmation Letter, LER No. 82-022,  
dated August 20, 1982

The reference provided written confirmation of a prompt reportable occurrence involving the Salt Water Cooling System (SWCS) at San Onofre Unit 1. This submittal provides the required 14-day follow-up report in accordance with Appendix A Technical Specification 6.9.2.a of Provisional Operating License DPR-13. Licensee Event Report No. 82-022 is attached.

With the plant in Mode 5 at approximately 0530 on August 19, 1982, the North Salt Water Cooling Pump (NSWCP) was secured due to degraded motor bearings. The motor bearing problems resulted, in part, from salt water intrusion permitted by a pump packing leak. Since the South Salt Water Cooling Pump (SSWCP) was out of service for maintenance at the time, the Auxiliary Salt Water Cooling Pump was put in service to provide the necessary heat removal capability. The pump transfer was accomplished without reduction of salt water cooling flow. A reconditioned motor was installed on the NSWCP and the pump was subsequently returned to service at approximately 1300 on August 19, 1982.

8209200033 820902  
PDR ADOCK 05000206  
S PDR


IE-29  
82-366

September 2, 1982

Since adequate salt water cooling flow was maintained throughout the period of this report, there was no adverse effect on public health or safety.

If you have any questions or if we can provide additional information, please let me know.

Sincerely,



Enclosure: LER 82-022

cc: L. F. Miller (USNRC Resident Inspector, San Onofre Unit 1)

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission  
Office of Management Information and Program Control

Institute of Nuclear Power Operations