

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

RECEIVED
NRC

1982 SEP -9 PM 12:24

SCE

REGIONAL

TELEPHONE
(714) 492-7700

H. B. RAY
STATION MANAGER

September 7, 1982

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
30-Day Report
Licensee Event Report No. 82-093
San Onofre Nuclear Generating Station, Unit 2

This submittal is in accordance with the reporting requirements of Section 6.9.1.13b of Appendix A to Facility Operating License, NPF-10. It describes a reportable condition involving Limiting Condition for Operation (LCO) 3.3.2 associated with the Toxic Gas Isolation System (TGIS). A completed copy of LER 82-093 is enclosed.

On August 8, 1982, while in Mode 3 during routine shift surveillance, Channel B butane analyzer was found to be malfunctioning. The analyzer was declared inoperable at 0800 and LCO 3.3.2, Table 3.3-3 - Action 14 was initiated.

Subsequent investigation revealed that analyzer malfunctioning was due to a faulty pressure regulator. This regulator was replaced and the analyzer was returned to service at 1658 on August 8, 1982.

Since the redundant analyzer remained operable throughout the event, there was no impact on the health and safety of plant personnel or the public.

8209200086 820907
PDR ADOCK 05000361
S PDR

IE-29
82-321

R. H. Engelken

-2-

September 7, 1982

If there are any questions regarding the above, please contact me.

Sincerely,

HB Pay / RLM

Enclosure: 82-093

cc: A. E. Chaffee (USNRC Resident Inspector, San Onofre Unit 2)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Office of Management Information & Program Control

Institute of Nuclear Power Operations