

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)01 P A S E S I 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 58

CONT

01 REPORT SOURCE L 6 0 5 0 0 0 3 8 7 7 0 8 2 3 8 2 8 0 9 1 0 8 2 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During preoperational testing, new breaker settings were applied to 9 breakers  
03 listed in Table 3.8.4.1-1 without proper review. Therefore, the settings were  
04 not within the required limits. Although the breakers are required in modes 1,  
05 2, and 3, and the station was in mode 5 at the time, the event is deemed  
06 reportable per 6.9.1.9.c. Because the breakers were not required, no adverse  
07 consequences occurred.

08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
E B 11 D 12 Z 13 C K T B R K 14 A 15 Z 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER 8 2 21 22  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER 26  
E 18 G 19 Z 20 Z 21 0 0 0 0 N 23 N 24 A 25 W 1 2 0  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The breakers were set at the new values without a review of the applicable  
11 Technical Specifications. The breakers were reset to Technical Specification  
12 values. To prevent recurrence of the event, the breaker test procedure was  
13 revised to ensure Technical Specification review, and no setting will be  
14 changed unless controlled by procedure.

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32  
B 28 0 0 0 29 n/a Z 31 n/a  
7 8 9 10 11 12 13 14 15 16 17 18 19 2016 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
Z 33 Z 34 n/a n/a  
7 8 9 10 11 12 13 14 15 16 17 18 19 2017 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39  
0 0 0 37 Z 38 n/a  
7 8 9 10 11 12 13 14 15 16 17 18 19 2018 PERSONNEL INJURIES NUMBER DESCRIPTION 41  
0 0 0 40 n/a  
7 8 9 10 11 12 13 14 15 16 17 18 19 2019 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43  
Z 42 n/a  
7 8 9 10 11 12 13 14 15 16 17 18 19 2020 PUBLICITY ISSUED DESCRIPTION 45  
N 44 n/a  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

NAME OF PREPARER D.G. Mitchell

PHONE: (717) 542-2181 X524

8209200346 820910  
PDR ADDCK 05000387  
S PDR

NRC USE ONLY