



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

ACTION - Michelson
Cys: Dircks
Rehm
Crooks/Bobe
GCunningham
Philips
DeYoung
Denton
Minogue
Davis

July 21, 1982

OFFICE OF THE
SECRETARY

MEMORANDUM FOR: William J. Dircks, Executive Director
for Operations
FROM: Samuel J. Chirk, Secretary
SUBJECT: SECY-82-255 - ABNORMAL OCCURRENCE
RECOMMENDATION - PRESSURE TRANSIENTS
DURING SHUTDOWN AT A NUCLEAR POWER PLANT

dd: DJH
em
KS
P.R.
J.d.

This is to advise you that the Commission (with all Commissioners agreeing) has approved the proposed abnormal occurrence and the associated Federal Register Notice subject to:

1. Modifying lines 6 and 7 of page 3 to read "...which close at 465 psig to prevent over pressurizing the RHR system. The RHR system..."; and
2. the inclusion of a diagram.

You should also reexamine the statement on the first line of page 6 which states that a pressure increase of "undetermined origin" occurred. If it is not significant that it is of undetermined origin the Commission suggests that you drop the phrase; if it is significant, the Commission would like to know if the licensee is examining it. You should make the above changes to the Federal Register Notice and return it for publication.

(EDO/AEOD) (SECY SUSPENSE: 8/9/82)

The Office for Analysis and Evaluation of Operational Data was informed of this action on July 20, 1982.

cc: Chairman Palladino
Commissioner Gilinsky
Commissioner Ahearne
Commissioner Roberts
Commissioner Asselstine
OGC
OPE

CONTACT:
A. Bates (SECY)
41400

Rec'd Off. EDO
Date... 7-22-82
Time... 2:15 P.M.

A21