

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N | J | 5 | G | S | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
7 8 9 14 16 25 26 30 57 CAT 58

CON'T
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 1 | 1 | 7 | 0 | 8 | 1 | 3 | 8 | 2 | 8 | 0 | 9 | 0 | 3 | 8 | 2 | 9
7 8 60 81 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | At 1015 hours, August 17, 1982, it was reported to the operating shift, that the
03 | Reactor Coolant System (RCS) Chemistry Surveillance due on August 13, 1982, at 1810
04 | hours, had not been completed until 0001 hours, August 14, 1982. The Chemistry
05 | Analyst had performed the other tests, but failed to perform the oxygen analysis on
06 | time. Therefore, between 1810 hours, August 13, 1982, and 0001 hours, August 14, 1982,
07 | the conditions of Action Statement 3.4.7a were applicable.

09 | SYSTEM CODE | X | X | 11 | CAUSE CODE | A | 12 | CAUSE SUBCODE | F | 13 | COMPONENT CODE | Z | Z | Z | Z | Z | Z | 14 | COMP. SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16 |
7 8 9 10 11 12 13 18 19 20
17 | LER/RO REPORT NUMBER | 8 | 2 | 21 | 22 | SEQUENTIAL REPORT NO. | 0 | 8 | 1 | 24 | 26 | OCCURRENCE CODE | 0 | 3 | 27 | 29 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32 |
ACTION TAKEN | X | 18 | FUTURE ACTION | H | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 22 | ATTACHMENT SUBMITTED | Y | 23 | NRPD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | Z | 25 | COMPONENT MANUFACTURER | Z | 9 | 9 | 9 | 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | The cause of the occurrence was oversight by the Chemistry Analyst. The surveillance
11 | was completed and dissolved oxygen concentration was shown to be below specified
12 | limits. The Chemistry Analyst was counseled by the Shift Supervisor and written
13 | guidance was given to all Chemistry Analysts stressing the importance of this
14 | surveillance.

15 | FACILITY STATUS | E | 28 | % POWER | 0 | 8 | 2 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Routine Surveillance | 32
7 8 9 10 12 13 44 45 46

16 | ACTIVITY CONTENT | Z | 33 | RELEASED OF RELEASE | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36
7 8 9 10 11 44 45 46

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39
7 8 9 11 12 13

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41
7 8 9 11 12

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43
7 8 9 10
PDR ADOCK 05000311
S PDR

20 | PUBLICITY ISSUED DESCRIPTION | N | 44 | NA | 45
7 8 9 10
NRC USE ONLY
NAME OF PREPARER: R. Heller
PHONE: 609/935-6000 Ext. 3078

917-925