LICENSEE EVENT REPORT CONTROL BLOCK / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) /V/A/N/A/S/2/ (2) /0/0/-/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) 10/1/ ///(5) LICENSEE CODE LICENSE NUMBER LICENSE TYPE /0/1/ REPORT SOURCE /L/ (6) /0/5/0/0/0/3/3/9/ (7) /0/8/1/6/8/2/ (8) /0/9/1/4/8/2/ (9) DOCKET NUMBER EVENT DATE REPORT DATE EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) / On August 16, 1982, with Unit No. 2 in Mode 5, the "1A" Residual Heat Removal 10/2' / (RHR) Pump was removed from service thereby leaving operable only one loop for 10/3/ / decay heat removal. Since the "IB" RHR pump remained available to ensure decay 10/4/ / heat removal, the public health and safety were not affected. This event is con-/ /0/5/ 10/6/ / trary to T.S. 3.4.1.3 and reportable pursuant to T.S. 6.9.1.9.b. There is no 10/7/ / generic implications to this event. /0/8/ SYSTEM CAUSE CAUSE COMP. VALVE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE 10/9/ /C/F/ (11) /E/ (12) /B/ (13) /P/U/M/P/X/X/ (14) /B/ (15) /Z/(16)OCCURRENCE SEQUENTIAL REPORT REVISION LER/RO EVENT YEAR REPORT NO. CODE TYPE NO. (17)REPORT NUMBER /8/2/ /-/ /0/5/0/ / / /0/3/ /L/ /-/ 101 ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT HOURS TAKEN ON PLANT METHOD SUBMITTED FORM SUB. SUPPLIER MANUFACTURER ACTION /A/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /N/ (25) /I/0/7/5/ (26) CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) /1/0/ / The "A" RHR pump was removed from service to replace a mechanical seal. The seal/ /1/1/ / primary "0" ring had apparently been overheated. The seal was replaced, pump /1/2/ / operability verified and the pump restored to service. An engineering study has / /1/3/ / been initiated to determine the cause of the seal problems. /1/4/ FACILITY METHOD OF (30) DISCOVERY %POWER OTHER STATUS DISCOVERY DESCRIPTION (32) /1/5/ /0/0/0/ (29) / NA /B/ (31) / Operator Observation / /G/ (28) ACTIVITY CONTENT AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36) RELEASED OF RELEASE /1/6/ /Z/ (33) /Z/ (34) / NA PERSONNEL EXPOSURES DESCRIPTION (39) NUMBER TYPE /1/7/ /0/0/0/ (37) /Z/ (38) PERSONNEL INJURIES NUMBER DESCRIPTION (41) /1/8/ /0/0/0/ (40) / NA LOSS OF OR DAMAGE TO FACILITY DESCRIPTION TYPE /1/9/ /2/ (42) / PUBLICITY DESCRIPTION (45) NRC USE ONLY ISSUED /2/0/ /N/ (44) / NA 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 NAME OF PREPARER W. R. CARTWRIGHT PHONE (703) 894-5151

8205220147 820914 PDR ADDCK 05000339 S PDR