

October 4, 1982

Docket No. 50-213
LS05-82-10-002

DISTRIBUTION
Docket
NRC PDR
Local File
ORB Reading
NSIC
DCrutchfield
HSmith
JLyons
ELJordan
JMTaylor
OELD
ACRS (10)
SEPB
EReeves
MFields

Mr. W. G. Council, Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Company
Post Office Box 270
Hartford, Connecticut 06101

Dear Mr. Council:

SUBJECT: COMPLETION OF REVIEW OF NUREG-0737, ITEM II.E.4.2.6 AND
ITEM II.E.4.2.7 (HADDAM NECK PLANT)

We have reviewed your submittals dated February 8, 1982 and May 20, 1981 relating to TNI Action Plan, Item II.E.4.2.6 and II.E.4.2.7, concerning Containment Isolation Dependability.

For Items II.E.4.2.6 and II.E.4.2.7 the containment purge valves are closed and sealed closed as follows. The present plant Technical Specifications require that the 42 inch purge valves and the 8-inch purge bypass valves be closed when the plant is in operational modes 1 through 4. Plant procedures require the valves to be locked closed when in modes 1 through 4. Thus these valves will be locked closed whenever the coolant temperature is above 200°F. There is a 3/4 inch line which may be used on rare occasions to vent the containment during periods when workers using breathing air systems cause containment pressure to approach limiting conditions for operation. This vent line has been used on less than five occasions in over 12 years of operation. We conclude that the requirements of NUREG-0737 Items II.E.4.2.6 and II.E.4.2.7 for the Haddam Neck Plant have been met.

Sincerely,

Original signed by
Thomas V. Wambach for/

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

SEO1

DSU use(02)

cc: See next page

8210070404 821004
PDR ADDCK 05000213
P PDR

*SEE PREVIOUS TISSUE FOR CONCURRENCE

OFFICE	DL: ORB #5*	DL: ORB #1*	DSI: CSB*	DL: ORB #5			
SURNAME	CTropf:cc	EReeves	MFields	DCrutchfield			
DATE	8/19/82	8/20/82	9/30/82	10/14/82			

Docket No. 50-213

Mr. W. G. Council, Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Company
Post Office Box 270
Hartford, Connecticut 06101

Dear Mr. Council:

SUBJECT: COMPLETION OF REVIEW OF NUREG - 0737, ITEM II.E.4.2.6
AND ITEM II.E.4.2.7 (HADDAM NECK)

We have reviewed your submittals dated February 8, 1982 and May 20, 1981 relating to TMI Action Plan, Item II.E.4.3.6 and II.E.4.2.7, Concerning Containment Isolation Dependability.

For Items II.E.4.2.6 and II.E.4.2.7 the containment purge valves are closed and sealed closed as follows. The present plant Technical Specifications require that the 42 inch purge valves and the 8-inch purge bypass valves be closed when the plant is in operation modes 1 through 4. Plant procedures require the valves to be locked closed when in modes 1 through 4. Thus these valves will be locked closed whenever the coolant temperature is above 200° F. There is a 3/4 inch line which may be used on rare occasion to vent the containment during periods when workers using breathing air systems cause containment pressure to approach limiting conditions for operation. This vent line has been used on less than five occasions in over 12 years of operation. We conclude that the requirements of NUREG-0737 Items II.E.4.2.6 and II.E.4.2.7 for the Haddam Neck Plant have been met.

Sincerely,

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

cc: See next page

OFFICE ▶	DL:ORB#5	DL:ORB#1	DSI:CSE	DL:ORB#5			
SURNAME ▶	CTropf	FREEVES	MFields	DCrutchfield			
DATE ▶	5/1/82	8/22/82	9/15/82	10/14/82			

October 4, 1982

cc
Day, Berry & Howard
Counselors at Law
One Constitution Plaza
Hartford, Connecticut 06103

Superintendent
Haddam Neck Plant
RFD #1
Post Office Box 127E
East Hampton, Connecticut 06424

Mr. Richard R. Laudenat
Manager, Generation Facilities Licensing
Northeast Utilities Service Company
P. O. Box 270
Hartford, Connecticut 06101

Board of Selectmen
Town Hall
Haddam, Connecticut 06103

State of Connecticut
Office of Policy and Management
ATTN: Under Secretary Energy
Division
80 Washington Street
Hartford, Connecticut 06115

U. S. Environmental Protection Agency
Region I Office
ATTN: Regional Radiation Representative
JFK Federal Building
Boston, Massachusetts 02203

Resident Inspector
Haddam Neck Nuclear Power Station
c/o U. S. NRC
East Haddam Post Office
East Haddam, Connecticut 06423

Ronald C. Haynes, Regional Administrator
Nuclear Regulatory Commission, Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406