

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I | A | D | A | C | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 1 | 1 | 4 | 5

01 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 1 | 7 | 0 | 1 | 9 | 1 | 1 | 0 | 8 | 1 | 2 | 8 | 1 | 1 | 0 | 1 | 0 | 1 | 1 | 8 | 1 | 2 | 9

02 | During normal operation the 'B' river water supply system (RWSS) traveli
03 | ng screen 1F-36B would not run in either 'auto' or 'continuous' mode. Th
04 | e 'B' RWSS was declared inoperable and a 7-day Limiting Condition for Op
05 | eration was briefly entered per T.S.3.5.J.2. The 'A' RWSS was operable.
06 | There have been no previous similar occurrences.
07 |
08 |

09 | C | J | 11 | X | 12 | Z | 13 | P | U | M | P | X | X | 14 | B | 15 | Z | 16 | 17 | 8 | 2 | 18 | 0 | 5 | 8 | 19 | 0 | 3 | 20 | L | 21 | 0 | 0 | 0 | 0 | 22 | N | 23 | N | 24 | A | 25 | G | 2 | 0 | 0 | 26

10 | 1F-36B would not run because the discharge pressure for the screen wash
11 | pump 1P-112B was not high enough to provide a permissive for screen move
12 | ment. Permissive pressure switch PS-2903 was recalibrated to the lower e
13 | nd of its range and 1F-36B was functionally tested satisfactorily. Furth
14 | er investigation into 1P-112B discharge head continues.

15 | E | 28 | 0 | 3 | 6 | 29 | NA | 30 | A | 31 | Operator Observation | 32

16 | Z | 33 | Z | 34 | NA | 35 | NA | 36

17 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39

14 | 0 | 0 | 0 | 40 | NA | 41

19 | Z | 42 | NA | 43

20 | N | 44 | NA | 45

8210130378 821001 PDR ADOCK 05000331 S PDR

NAME OF PREPARER Kimuel L. Hill

PHONE: 319-851-5611

NRC USE ONLY

U.S. G.P.O. 7-78