DCS No: 50387-821006 Date: October 7, 1982

## PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-82-64

Subject:

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility:	Pennsylvania Power & Light Company Susquehanna, Unit 1 (DN 50-387)	Licensee Emergency Classification:  Notification of Unusual Event Alert Site Area Emergency General Emergency Not Applicable
Subject.	PIPE SUPPORT INADEQUACY	

Because of concerns generated by the independent design review requested by NRR, the licensee re-examined 20 additional pipe supports and found 19 satisfactory. The other, an anchor for a 6" Residual Heat Removal System line, was found to have an inadequate weld (about one-third the specified length). The licensee concluded that this support would be overstressed by a factor of 4 under design conditions, that failure of the support would overstress a containment penetration, and that further pipe support adequacy assessment is needed before power operation above 5% is undertaken. The operating license limits power to 5% until the NRC Commissioners approve higher power operation. At the licensee's request, further NRC Commissioner consideration of that authorization has been postponed.

The licensee informed the NRC about this problem around 2 p.m., October 6, 1982. NRC Region I has responded , media inquiries. The Commonwealth of Pennsylvania has been notified.

CONTACT:	McCabe 488-1231		Keimig 488-122	4				
DISTRIBUTION: H. St.	MNBB	Phillip	\$ 8:55	E/W	Willste	Mail:	ADM: DMB	
Chairman Palla Comm. Gilinsky Comm. Ahearne Comm. Roberts Comm. Asselsti ACRS SECY CA	dino EDO PA MPA ELD	NRR Air Rights SP	INPO NSAC	OIA AEOD	NMSS RES		DOT:Trans.	Only
PDR Regi	onal Offices			Ri Resi License	ident Section dent Office dent Office dent dent dent dent dent dent dent den			
Region I Form (Rev. June 198	2) PDR	0130405 8210   I&E  -1-82-064	PDR				IE34	