

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-361

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 9
License No. NPF-10

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment for the San Onofre Nuclear Generating Station, Unit 2 (the facility) filed by the Southern California Edison Company on behalf of itself and San Diego Gas and Electric Company, The City of Riverside and The City of Anaheim, California (licensees) complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8210130573 821007
PDR ADOCK 05000361
P PDR

OFFICE ▶
SURNAME ▶
DATE ▶

- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-10 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 9, are hereby incorporated in the license. SCE shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

- 3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

RS/

Janis Kerrigan, Acting Chief
Licensing Branch No. 3
Division of Licensing

Date of Issuance: OCT 7 1982

OK no legal objection subject to change to son

OFFICE	DL:LB#3	DL:LB#3	DL:LB#3	DL:AD/L	QELD		
SURNAME	JLee/yt	HRood	JKerrigan	TMovak	LChandler		
DATE	10/7/82	10/7/82	10/7/82	10/7/82	10/7/82		

ATTACHMENT TO LICENSE AMENDMENT NO. 9

FACILITY OPERATING LICENSE NO. WPF-10

DOCKET NO. 50-361

Replace the following page of the Appendix A Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

Overleaf
Page

N/A

Amendment
Page

3/4 3-75

OFFICE ▶
SURNAME ▶
DATE ▶

INSTRUMENTATION

3/4.3.4 TURBINE OVERSPEED PROTECTION

LIMITING CONDITION FOR OPERATION

3.3.4 At least one turbine overspeed protection system shall be OPERABLE.

APPLICABILITY: MODES 1, 2* and 3.*

ACTION:

- a. With one stop valve or one control valve per high pressure turbine steam lead inoperable and/or with one reheat stop valve or one reheat intercept valve per low pressure turbine steam lead inoperable, restore the inoperable valve(s) to OPERABLE status within 72 hours, or close at least one valve in the affected steam lead or isolate the turbine from the steam supply within the next 6 hours.
- b. With the above required turbine overspeed protection system otherwise inoperable, within 6 hours isolate the turbine from the steam supply.

SURVEILLANCE REQUIREMENTS

4.3.4.1 The provisions of Specification 4.0.4 are not applicable.

4.3.4.2 The above required turbine overspeed protection system shall be demonstrated OPERABLE:

- a. At least once per 7 days by cycling each of the following valves through at least one complete cycle from the running position.
 1. Four high pressure turbine stop valves.
 2. Four high pressure turbine control valves.
 3. Six low pressure turbine reheat stop valves.
 4. Six low pressure turbine reheat intercept valves.
- b. At least once per 31 days by direct observation of the movement of each of the above valves through one complete cycle from the running position.
- c. At least once per 18 months by performance of a CHANNEL CALIBRATION on the turbine overspeed protection systems.
- d. At least once per 40 months by disassembling at least one of each of the above valves and performing a visual and surface inspection of valve seats, disks and stems and verifying no unacceptable flaws or corrosion.

*With any main steam line isolation valve and/or any main steam line isolation valve bypass valve not fully closed.