

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-361

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL

NOTICE OF ISSUANCE OF AMENDMENT

FACILITY OPERATING LICENSE NO. NPF-10

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 9 to Facility Operating License No. NPF-10, issued to Southern California Edison Company, San Diego Gas and Electric Company, The City of Riverside, California and The City of Anaheim, California (licensees) for the San Onofre Nuclear Generating Station, Unit 2 (the facility) located in San Diego County, California. This amendment is effective as of the date of issuance.

Amendment No. 9 changes the Technical Specifications to allow operation in MODES 2 and 3 with the turbine overspeed protection system inoperable, provided that steam is isolated from the turbine.

Issuance of this amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commission's regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

8210130582 821007
PDR ADGCK 05000361
P PDR

OFFICE ▶
SURNAME ▶
DATE ▶

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR 51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) Southern California Edison Company's letter dated September 30, 1982, (2) Amendment No. 9 to Facility Operating License No. NPF-10, and (3) the Commission's related Safety Evaluation.

These items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and the San Clemente Library, 242 Avenida Del Mar, San Clemente, California 92672. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 7th day of October, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

151

Victor Nerses, Acting Chief
Licensing Branch No. 3
Division of Licensing

*See previous yellow for concurrence

OFFICE ▶
SURNAME ▶
DATE ▶

- 2 -

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR 51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) Southern California Edison Company's letter dated September 30, 1982, (2) Amendment No. 9 to Facility Operating License No. NPF-10, and (3) the Commission's related Safety Evaluation.

These items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and the San Clemente Library, 242 Avenida Del Mar, San Clemente, California 02672. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this day of October, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

Janis Kerrigan, Acting Chief
Licensing Branch No. 3
Division of Licensing

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR 51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) Southern California Edison Company's letter dated September 30, 1982, (2) Amendment No. 9 to Facility Operating License No. NPF-10, and (3) the Commission's related Safety Evaluation.

These items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and the San Clemente Library, 242 Avenida Del Mar, San Clemente, California 02672. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this day of October, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

Janis Kerrigan, Acting Chief
Licensing Branch No. 3
Division of Licensing

no legal objection

OFFICE	DL:LB#3	DL:LB#3	DL:LB#3	DL:LB#3			
SURNAME	JLee/yt	HRood	JKerrigan	EChandler			
DATE	10/4/82	10/4/82	10/4/82	10/4/82			

Document Control (50-361)
NRC PDR
L PDR
TERA
NSIC

LB#3 Reading
HRood
JLee
JKerrigan
Attorney, OELD
JRutberg, OELD
DEisenhut/RPurple
TNovak
AToalston, AIG
JSouder
MPA
TBarnhart (4)
WMiller
IDinitz
WJones, OA (10)
ACRS (16)
BPCotter, ASLBP
ARosenthal, ASLAP
FPagano
LJHarmon, IE File (2)