

APPENDIX A

NOTICE OF VIOLATION

Vermont Yankee Nuclear Power Corporation  
Vermont Yankee Nuclear Power Station

Docket No. 50-271  
License No. DPR-28

As a result of the inspection conducted on July 6-30, 1982, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C), 47 FR 9987 (March 9, 1982), the following violation was identified:

Technical Specification 6.5.B requires that radiation protection procedures be prepared and maintained to implement the requirements of 10 CFR 20. Procedure AP 0503, "Establishing and Posting Controlled Areas", was prepared pursuant to the requirements of Technical Specification 6.5.B. AP 0503 defines "hot spots" within radiation areas and specifies posting requirements for these "hot spots" which include a sticker, annotated with the radiation dose rate.

Contrary to the above, during a routine radiation survey on July 14, 1982, the inspector identified a defined "hot spot" radiation area on the section of the Main Steam Drain line located above the Torus Catwalk (Reactor Building 250 foot elevation - West) that read 250 mRem/hr on contact, 100 mRem/hr at 12 inches, but was not posted and annotated per AP 0503.

This is a Severity Level V Violation (Supplement IV.E).

Pursuant to the provisions of 10 CFR 2.202, Vermont Yankee Nuclear Power Corporation of Vernon, Vermont, is hereby required to submit to this office within thirty days of the date of the Notice, a written statement of explanation in reply, including: (1) corrective steps which have been taken and the results achieved; (2) corrective steps that will be taken to avoid further violations; and (3) the date when corrective actions will be completed. Where good cause is shown, consideration will be given to extend your response time.

OFFICIAL RECORD COPY