

ME-146

SEISMIC STRESS ANALYSIS REPORT

RHRSW PUMPS

DETROIT EDISON COMPANY

Enrico Fermi Plant

P.O. IE-92034

GOULDS PUMPS

Vertical Pump Division

Order # N301213

Analysis By

McDonald Engineering - Analysis Company

Birmingham, Alabama

REVISIONS
E. H. J. M. A. Q. Q. 2
GOULDS

Certification Statement

The RHEW pumps covered by this report have been analyzed in accordance with Detroit Edison Specification 3071-25 and applicable industry codes. The pump meets all requirements for both Operating Basis and Design Basis Earthquakes.

Claudio K. McDonald

Claudio K. McDonald, Ph. D.

January 28, 1974

522-212

TABLE OF CONTENTS

1. Summary of Results	1
2. Seismic Analysis	3
2.1 Lateral Seismic Analysis	3
2.2 Vertical Seismic Analysis	25
3. Stress Analysis	26
3.1 Introduction	26
3.2 Stresses in Column	26
3.3 Stress Analysis of Support Bolting	27
3.4 Analysis of Anchor Bolts	28
3.5 Column Flanges and Bolting	28
3.6 Analysis of Motor Bolting	30
3.7 Stresses in Shaft	31
3.8 Deflections in Shaft	33
3.9 Stresses in Coupling	33
3.10 Column Deflections	34
3.11 Nozzle Loads	35
3.12 Impeller Clearance	36
4. Appendix A - References	37

522-212

1. SUMMARY OF RESULTS

A summary of the OBE stresses and allowable stresses for the pump are given below. The DBE stresses are not given because the OBE was the governing load in all cases.

	<u>Actual</u>	<u>Allowable</u>
Impeller Clearance	.0003"	.015"
Max. Column Stress		
Longitudinal	7,997	15,000
Circumferential	1,975	15,000
Support Bolting	4,567	25,000
Anchor Bolts		
Shear	7,307	10,000
Tensile	14,693	20,000
Column Flanges and Bolting		
Bolting (primary membrane)	9,741	25,000
Radial Flange Stress	10,827	12,600
Tangential Flange Stress	5,388	12,600
Bolting (Stress Due To Primary Bending)	31,095	37,500
Motor Bolting	1,205	10,000
Max. Shaft Combined Stress	13,889	15,000
Max. Coupling Combined Stress	13,894	15,000
Max. Shaft Deflection (in./foot)	.0067	.01

The OBE allowable stresses are from the ASME Code except for the shaft and coupling which are not covered by the Code and the stresses due to primary bending. The shaft and coupling allowable was established to be in general accord with the Code and the primary bending stresses are per the AEC Regulatory Guide 1.48.

DISASSEMBLY
CLEARANCE
20'-0"

ALLIS CHALMERS
ELECTRIC MOTOR
350 H.P. 1800 R.P.M.
3 PH. 40 HZ. 4000 V.
HIGH THRUST
SD7/3 ENCLOSURE
FRAME 507 UP




Figure 1 - Pump Outline Drawing

522-212

2. SEISMIC ANALYSIS

A multidegree of freedom modal analysis is made using the computer program ICES-STRUDL developed at the Massachusetts Institute of Technology. Detailed data on the program, including users manuals, can be obtained from M. I. T. at very modest cost. The program is a general purpose type program and various segments are still under development and have not been checked out adequately. However, the parts of the program used for this analysis have been well checked out against hand solutions and classical results. These verification checks will be made available upon request (see Reference 1 in Appendix A).

2.1 Lateral Seismic Analysis

The computer model for the lateral analysis is shown in Figure 2. The joints and members are numbered to facilitate the computer input. Joint numbers are enclosed in circles. Masses are lumped at the flanges and the motor center of gravity. The results of the analysis show that this is an adequate number of mass points. The impeller masses are shown separately so that the impeller clearance can be easily checked.

The lateral analysis was made for both the high water level case and the low water level case. The detailed input data are included on pages 5 - 10. The input data are obtained from the model and pump detailed drawings. Interpretation of the data should be self explanatory in most cases but detailed comments will be made as follows.

Input for the high water level case is given first. The joint coordinates




Figure 2 Dynamic Model for Lateral Analysis

STRONG 16021 FORMING RUMBLE PUMP FOR DETROIT BRIDGE - HIGH WATER CONDITION

 * ICES STRUOL-II *
 * THE STRUCTURAL DESIGN LANGUAGE *
 * CIVIL ENGINEERING SYSTEMS LABORATORY *
 * MASSACHUSETTS INSTITUTE OF TECHNOLOGY *
 * CAMBRIDGE, MASSACHUSETTS *
 * V2 R2 JUNE, 1972 *
 * 10137125 1/29/76 *

TYPE PLANE FRAME

UNITS INCHES POUNDS

JOINT COORDINATES

1	0.0	0.0
2	0.0	8.94
3	0.0	17.88
4	0.0	26.82
5	0.0	35.76
6	0.0	44.70
7	0.0	104.0
8	0.0	164.0
9	0.0	224.0
10	0.0	284.0
11	0.0	344.0
12	0.0	404.0
13	0.0	464.0
14	0.0	482.75
15	0.0	502.75
16	0.0	520.75
17	0.0	541.75

MEMBER INCIDENCES

1	1	3
2	3	5

5 5 6
6 6 7
5 7 8
6 8 9
7 9 10
8 10 11

9 11 12
10 12 13
11 13 14
12 14 15
13 15 16
14 16 17
15 1 2
16 2 3
17 3 4

18 4 5
CONSTANTS
E 29000000. ALL

MEMBER PROPERTIES
1 PRIS AX 22.7 IZ 999.3
2 PRIS AX 22.7 IZ 999.3
3 PRIS AX 22.7 IZ 999.3
4 TO 11 PRIS AX 9.00 IZ 109.67
12 PRIS AX 16.05 IZ 373.

13 VARIABLE
SEGMENT 1 AX 16.05 AY 16.05 IZ 373. I 2.5
SEGMENT 2 AX 16.06 IZ 56.412 L 15.5
SEGMENT 3 AX 16.05 AY 16.05 IZ 373. I 2.
14 PRIS AX 9.62 IZ 92.69
15 TO 16 PRIS AX 5.41 IZ 2.33
DYNAMIC DEGREES OF FREEDOM

JOINTS 1 TO 4 6 TO 16 16 17 DISP X
INERTIA OF JOINT 1 LINEAR ALL 2.821

INERTIA OF JOINT 2 4 LINEAR ALL .201
 INERTIA OF JOINT 3 LINEAR ALL 5.8425
 INERTIA OF JOINT 6 LINEAR ALL 6.8918
 INERTIA OF JOINT 7 TO 11 LINEAR ALL 2.5667
 INERTIA OF JOINT 12 LINEAR ALL 2.8947
 INERTIA OF JOINT 13 LINEAR ALL 1.3466
 INERTIA OF JOINT 14 LINEAR ALL 3.4230
 INERTIA OF JOINT 16 LINEAR ALL .9092
 INERTIA OF JOINT 17 LINEAR ALL 9.3264

DUMP ORTHOGONALITY

DAMPING .02 15

UNITS CALLED

STONE RESPONSE SPECTRA ACCELERATION VS FREQUENCY '08E'

DAMPING .02 FACTOR 386.

.05 .1

.05 .5167 .32 4.3565 1.52 6.2280 .26 13.753 .16 26.901
 .16 65.249 .16 66.901


DYNAMIC LOADING 1 'OPERATING BASIS EARTHQUAKE'

SUPPORT ACCELERATION

DISP # FILE '08E'

YNAMIC ANALYSIS MODAL

INCJ101 PROGRAM INTERRUPTED OLD PSM IS FF95000FA006A07E



3 5 6

6 6 7
 5 7 8
 6 8 9
 7 9 10
 8 10 11
 9 11 12
 10 12 13
 11 13 14
 12 14 15
 13 15 16
 14 16 17
 15 1 2
 16 2 3
 17 3 4
 18 4 5

CONSTANTS

E 2900000. ALL

MEMBER PROPERTIES

1 PRIS AR 22.7 IZ 599.3

2 PRIS AR 22.7 IZ 599.3

3 PRIS AR 22.7 IZ 599.3

4 TO 11 PRIS AR 9.69 IZ 105.07

12 PRIS AR 16.05 IZ 373.

13 VARIABLE

SEGMENT 1 AR 16.05 AY 16.05 IZ 373. L 2.3

SEGMENT 2 AR 16.66 IZ 56.812 L 13.5

SEGMENT 3 AR 16.05 AY 16.05 IZ 373. L 2.

14 PRIS AR 9.62 IZ 52.69

15 TO 16 PRIS AR 5.41 IZ 2.33

DYNAMIC DEGREES OF FREEDOM

JOINTS 1 72 6 TO 14 16 17 01SP R

INERTIA OF JOINT 1 LINEAR ALL 2.821

522-212

INERTIA OF JOINT 2 4 LINEAR ALL .241
 INERTIA OF JOINT 3 LINEAR ALL 5.6525
 INERTIA OF JOINT 6 LINEAR ALL 3.6963
 INERTIA OF JOINTS 7 TO 12 LINEAR ALL 1.8486
 INERTIA OF JOINT 13 LINEAR ALL 1.3466
 INERTIA OF JOINT 14 LINEAR ALL 3.4230
 INERTIA OF JOINT 16 LINEAR ALL .5052
 INERTIA OF JOINT 17 LINEAR ALL 9.3764

BUMP ORTHOGONALITY
 DYNAMIC ANALYSIS EIGENVALUE

522-212

are obtained from the model and are entered in order X, Y. The member incidences are self explanatory. The area properties are for the simple beam type members except for the exceptions given as follows. The motor is modeled as an equivalent beam the properties of which are obtained from the motor reed frequency furnished by the manufacturer. The motor mount is modeled as a variable cross section beam to account for the holes cut out for access. The moment of inertia of the reduced section was obtained by assuming that the two pipe sectors act independently when the load is applied. This gives a lower moment of inertia than if the two sectors were assumed to bend as one beam. The preliminary analysis showed that the section at the cutouts was inadequate and stiffeners were added prior to the final analysis.

The pump lower bowl assembly is of complex cross sectional geometry. An equivalent beam was obtained to model the bowl assembly.

The lump masses include the water internal to the pump and also external water for the submerged portion of the pump. Both the high water level and low water level was checked to determine which was the worst case. The high water level case was the worst, thus only the frequencies for the low water case are included for reference only.

An inspection of the response spectra for the lateral case showed that the East-West earthquake gave the highest loads for this pump. The OBE also governs the design since the DEE seismic loads are only slightly higher than the OBE loads.

The output sheets for the computer analysis follow.

522-212

ORIGINATION WITH RESPECT TO MAIL

ROW 1	0.10000000 01	-0.11063700-12	-0.65967697-14	-0.23005014-16	-0.37415470-18
	-0.11936049-15	0.62665370-16	0.18313191-15	-0.32471850-15	0.31978664-15
	-0.28922880-16	0.36928330-13			
ROW 2	-0.11062650-12	0.10000000 01	0.63337303-14	0.15885270-14	0.32965167-15
	0.56757867-16	-0.26736650-15	0.72533250-16	0.10755266-15	0.15303175-15
	0.12037800-15	0.13909771-15			
ROW 3	-0.45966332-14	0.65967332-14	0.10000000 01	-0.48030156-18	0.12759639-13
	0.47578146-17	-0.47975963-16	0.38651807-16	0.30270925-15	0.18255254-15
	0.18663880-15	0.70426630-16			
ROW 4	-0.44906605-15	0.55251290-24	0.65663961-23	0.10000000 01	-0.07929290-27
	-0.48000667-24	0.25200280-24	0.47305093-24	0.20728349-24	-0.07377532-24
	0.16216660-24	0.39822434-24			
ROW 5	-0.11661900-16	0.15781613-16	-0.68000156-16	0.10000000 01	-0.38272370-15
	0.25402270-15	0.97576196-17	-0.18122490-15	0.26622937-15	0.25133162-16
	0.26033016-15	0.63367360-16			
ROW 6	-0.37962470-15	0.32965167-15	0.11570180-15	-0.16662874-15	0.10000000 01
	0.35041410-15	0.13357110-15	-0.17580770-15	-0.16376130-16	0.17536910-16
	0.29802020-15	-0.77506820-16			
ROW 7	-0.11935370-15	0.53360049-16	0.99204699-17	0.26600900-15	0.35061416-15
	0.10002320 01	0.12408340-15	-0.23722364-15	-0.11102230-15	-0.17726706-16
	0.32420710-15	-0.33215280-15			
ROW 8	0.45299220-16	-0.23722363-15	-0.75731520-16	0.25270028-24	0.33444107-15
	0.11709193-15	0.10000000 01	-0.62379920-15	0.27755760-16	-0.46945954-16
	0.51620050-15	-0.75851080-15			
ROW 9	-0.14238540-15	0.22873320-16	0.24174020-16	-0.19310218-15	-0.17396024-15
	-0.25066750-15	-0.62379920-15	0.10000000 01	-0.19943619-16	-0.99780681-17
	0.65253690-15	-0.74728617-15			
ROW 10	0.52127250-24	-0.26333170-24	-0.67607748-24	-0.52869718-24	-0.23762700-24
	0.34668190-24	0.16248617-24	-0.79552163-24	-0.29512480-22	0.25304690-22
	-0.13983639-24	-0.83505820-24			
ROW 11	-0.32488180-15	0.15923790-15	0.30310716-15	0.28627937-15	-0.58176343-16
	-0.12490300-15	0.27755760-16	-0.48572570-16	0.10000000 01	-0.66620691-17
	-0.26818063-16	-0.11513290-17			
ROW 12	0.99574970-15	0.16880122-13	0.17902596-13	0.22693707-16	0.95596379-16
	-0.06967763-16	-0.43576570-16	-0.72661564-17	-0.67162790-17	0.10000000 01
	-0.11566366-15	0.16975091-15			
ROW 13	-0.36708127-16	0.12228192-15	0.19048195-15	0.16288600-24	0.29802047-15
	0.32668566-15	0.51333150-15	0.69267270-15	-0.19836050-24	-0.11567998-15
	0.16002007 01	0.92758870-15			
ROW 14	0.37563650-15	0.11665263-15	0.66963125-16	0.39827450-24	-0.80112650-16
	-0.30302720-15	-0.75950783-15	-0.78927330-15	-0.83656670-24	0.12700509-15
	0.59683660-15	0.10300000 01			

ORIGINALLY WITH RESPECT TO STATEMENTS

ROW	1	0.104573400-02	-0.60750500-09	0.60439910-10	-0.34000000-23	0.301003190-09	0.810707900-09
		0.130403820-08	0.169026000-08	0.132600000-08	0.557005700-23	-0.202931010-10	0.151681000-08
		-0.118203500-08	-0.124881000-08				
ROW	2	0.019016700-09	0.748574700-03	0.119252900-09	0.204172510-22	-0.321053000-10	-0.648265400-11
		0.273528550-09	0.345069600-09	0.208277800-09	-0.182195700-21	0.792163600-10	0.575756330-09
		-0.078159210-10	-0.873272430-10				
ROW	3	0.215572750-11	0.933687000-10	0.893436600-08	0.435943200-19	-0.198720770-10	-0.161212000-09
		-0.215572750-11	-0.925113800-10	-0.574118530-11	-0.328751910-20	0.636557600-10	0.758100470-09
		0.317901400-09	0.359841300-09				
ROW	4	0.350808000-23	0.264172510-22	0.455943200-19	0.741355330-04	0.178047520-20	-0.731817500-22
		-0.350808000-23	0.187006000-20	0.350996810-20	0.582076610-10	0.153678160-20	-0.51307.800-20
		0.120750000-20	0.295237720-20				
ROW	5	0.341024750-09	-0.458083600-10	-0.948888410-11	0.176047520-20	0.287403900-09	-0.1055831000-09
		-0.399211310-09	-0.459797530-09	0.354811540-11	-0.152237830-19	0.502376010-10	0.241527800-09
		0.645059120-09	0.134962700-08				
ROW	6	0.762526800-09	-0.268940570-10	-0.185751420-08	-0.182318170-22	-0.131954900-09	0.808303270-05
		-0.394836100-09	-0.516479100-09	-0.139152690-09	-0.187011340-19	-0.5927.3610-10	0.403076680-04
		0.114257000-08	0.615409600-09				
ROW	7	0.130193700-08	0.208121500-09	-0.230091720-09	-0.356539510-20	-0.610437910-09	-0.402337720-09
		0.176895400-08	-0.611464600-09	-0.702382600-09	0.648839110-19	-0.436557600-10	-0.790123520-11
		0.133992800-08	-0.113237800-09				
ROW	8	0.164286100-08	0.321703200-09	-0.105343800-09	0.187006000-29	-0.452760450-09	-0.520747500-09
		-0.583753670-09	0.309656630-06	-0.248683010-06	0.371238920-19	0.291038100-10	-0.5678657.5-10
		0.295283800-08	-0.338016700-08				
ROW	9	0.125039600-08	0.232187000-09	-0.285321100-11	-0.150950810-20	-0.281939880-11	-0.161310960-09
		-0.712949100-09	-0.151725700-08	0.426956710-06	-0.365957810-18	-0.281939880-11	0.750901500-10
		0.268793300-08	-0.332263600-08				
ROW	10	0.557063700-23	-0.182195700-21	-0.328751910-20	0.318323150-10	-0.152237830-19	-0.167815100-19
		0.648039110-19	0.371238920-19	-0.365957600-18	0.338795680-07	-0.107527820-15	0.918076110-18
		0.812278100-19	-0.269252900-17				
ROW	11	-0.190075200-10	0.760813670-10	0.420037140-10	0.153678160-20	0.424894080-10	-0.554791770-10
		-0.509317030-10	0.672937240-10	-0.292852600-09	-0.107527820-15	0.377071700-07	-0.336513040-10
		-0.540513420-11	-0.646866360-11				
ROW	12	0.129272600-08	0.527329290-09	-0.711732690-08	-0.2351907100-20	-0.147529500-09	0.293312710-09
		-0.150528600-09	-0.221244900-09	-0.070521400-10	0.918076110-18	-0.394702930-10	0.392909100-07
		-0.133513110-08	0.640803380-09				
ROW	13	-0.101891000-08	0.761213400-10	0.343135760-09	0.120750690-20	0.711428610-09	0.109585510-08
		0.124404100-08	0.289356700-08	0.292501100-08	-0.611279810-19	-0.671618160-11	-0.157760000-08
		0.954206070-07	0.726818010-08				
ROW	14	-0.107070210-08	0.119354710-09	0.339599210-08	0.295399720-20	0.118254010-08	0.708191080-09
		-0.648039110-19	-0.326093700-08	-0.326093700-08	-0.360369600-17	-0.733835210-11	0.577675350-00
		0.351928910-08	0.122925500-08				

1999 STATEMENT OF FINANCIAL STATEMENTS

RESULTS OF LATEY ANALYSIS

PROBLEM - GP2 TITLE - GOULDS BARRON POND FOR DETAIL DESIGN & HIGH WATER CONDITION

ACTIVE UNITS INCH LB CYC DRGP SEC

ACTIVE STRUCTURE TYPE PLANE FRAME

ACTIVE COORDINATE AXIS X Y

LOADING - OPERATING BASIS EARTHQUAKE

MEMBER FORCES

MEMBER	JOINT	RESPONSE TYPE	AXIAL	FORCE	MOMENT	REMOVAL	REMOVAL
				MEMBER	MEMBER	MEMBER	MEMBER
				MEMBER	MEMBER	MEMBER	MEMBER
1	1	RMS	0.0	162.119752	2017.213789	127.632493	557.0302734
		ABS SUM	0.0	298.393105	5178.7341750		
2	3	RMS	0.0	372.524565	2754.820808	5043.0234375	
		ABS SUM	0.0	642.3352051	9260.044062	16360.4687500	
3	5	RMS	0.0	372.524565	9622.539375	16964.0937500	
		ABS SUM	0.0	642.3352051	16360.4687500		
4	6	RMS	0.0	322.0512695	22217.5296879	21329.5117187	
		ABS SUM	0.0	513.577809	21329.5117187		
5	6	RMS	0.0	638.0247852	12503.1904250	21808.0668437	
		ABS SUM	0.0	644.6696777	21808.0668437		
6	7	RMS	0.0	638.0247852	18938.2304687	62340.7773437	
		ABS SUM	0.0	644.6696777	62340.7773437		
7	1	RMS	0.0	601.1633301	38556.9297812	62038.6210937	
		ABS SUM	0.0	618.3581543	62038.6210937		
8	6	RMS	0.0	601.1633301	61440.3904250	93168.125000	
		ABS SUM	0.0	618.3581543	93168.125000		
9	8	RMS	0.0	379.9650879	61440.3904250	93168.125000	
		ABS SUM	0.0	521.9218750	93168.125000		

6	9	RMS	379,965,379	0.0	79624,379,0000
		ABS SUM	521,921,8750	0.0	112196,875,0000
7	9	RMS	949,183,996	0.0	79629,5379000
		ABS SUM	693,023,375	0.0	112198,0625000
7	10	RMS	450,183,996	0.0	95667,8125000
		ABS SUM	693,023,375	0.0	129242,500000
8	10	RMS	552,537,8918	0.0	95666,1875000
		ABS SUM	835,826,9512	0.0	129240,6250000
8	11	RMS	552,537,8918	0.0	116383,6250000
		ABS SUM	835,826,9512	0.0	131866,3125000
9	11	RMS	656,301,5137	0.0	116383,6250000
		ABS SUM	1010,604,922	0.0	131866,3750000
9	12	RMS	656,301,5137	0.0	139735,6875000
		ABS SUM	1010,604,922	0.0	160748,9375000
10	12	RMS	699,626,5137	0.0	139735,6875000
		ABS SUM	1136,953,3691	0.0	160749,2500000
10	13	RMS	699,626,5137	0.0	171679,5000000
		ABS SUM	1136,953,3691	0.0	223417,2500000
11	13	RMS	701,597,1680	0.0	171679,6250000
		ABS SUM	1165,356,9136	0.0	223417,5000000
11	14	RMS	701,597,1680	0.0	182766,250,000
		ABS SUM	1165,356,9136	0.0	223417,937,000
12	14	RMS	1003,632,6172	0.0	58808,8233125
		ABS SUM	1003,632,6172	0.0	58808,8,03125
12	15	RMS	1003,632,6172	0.0	18740,1601562
		ABS SUM	1003,632,6172	0.0	38740,1640625
13	15	RMS	1003,629,9316	0.0	38740,1171875
		ABS SUM	1003,629,9316	0.0	38740,1210937
13	16	RMS	1003,629,9316	0.0	20678,3750000
		ABS SUM	1003,629,9316	0.0	20678,3628125
14	16	RMS	986,698,7305	0.0	20678,5294379
		ABS SUM	986,698,7305	0.0	20678,5271437
14	17	RMS	986,698,7305	0.0	0,1652111
		ABS SUM	986,698,7305	0.0	0,1652112
15	1	RMS	4,963,6121	0.0	26,6924286
		ABS SUM	8,671,4363	0.0	43,5703583
15	2	RMS	4,963,6121	0.0	19,5105896
		ABS SUM	8,671,4373	0.0	33,9521790
16	2	RMS	6,379,4105	0.0	20,6527405
		ABS SUM	11,305,6774	0.0	35,8235779
16	3	RMS	6,379,4105	0.0	36,6568798
		ABS SUM	11,305,6774	0.0	65,2490082
17	3	RMS	2,960,3196	0.0	28,3387909
		ABS SUM	4,691,9603	0.0	64,9219818

522-212

17	4	RMS	0.0	2.9609194	10.9760143
		ABS SUM	0.0	6.6917603	22.5710079
18	6	RMS	0.0	5.6991006	11.2200007
		ABS SUM	0.0	8.7943487	23.3591616
19	5	RMS	0.0	5.6991006	53.8396634
		ABS SUM	0.0	8.7943487	89.3054047

RESULTANT JOINT DISPLACEMENTS- SUPPORTS

JOINT	RESPONSE TYPE	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
14	GLOBAL	RMS	0.0	0.0	0.0	0.0	0.0
		ABS SUM	0.0	0.0	0.0	0.0	0.0

RESULTANT JOINT DISPLACEMENTS- FREE JOINTS

JOINT	RESPONSE TYPE	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	GLOBAL	RMS	2.2978334	0.0	0.011032		
		ABS SUM	2.3580379	0.0	0.012649		
2	GLOBAL	RMS	2.2364836	0.0	0.011032		
		ABS SUM	2.2848761	0.0	0.012848		
3	GLOBAL	RMS	2.1721691	0.0	0.011031		
		ABS SUM	2.2137070	0.0	0.012865		
4	GLOBAL	RMS	2.1147990	0.0	0.011029		
		ABS SUM	2.1627698	0.0	0.012818		
5	GLOBAL	RMS	2.0546605	0.0	0.011029		
		ABS SUM	2.0729151	0.0	0.012827		
6	GLOBAL	RMS	1.9763178	0.0	0.011019		
		ABS SUM	2.061207	0.0	0.012812		
7	GLOBAL	RMS	1.5914783	0.0	0.011068		
		ABS SUM	1.642472	0.0	0.012341		
8	GLOBAL	RMS	1.2051153	0.0	0.011027		
		ABS SUM	1.3022163	0.0	0.013490		
9	GLOBAL	RMS	0.8521028	0.0	0.011017		
		ABS SUM	0.9548747	0.0	0.012185		
10	GLOBAL	RMS	0.5362759	0.0	0.012663		
		ABS SUM	0.6314898	0.0	0.012832		
11	GLOBAL	RMS	0.2794697	0.0	0.0105925		
		ABS SUM	0.3465011	0.0	0.0116910		
12	GLOBAL	RMS	0.2762265	0.0	0.0110175		
		ABS SUM	0.3231707	0.0	0.010655		
13	GLOBAL	RMS	0.0059118	0.0	0.010960		
		ABS SUM	0.027611	0.0	0.010298		
15	GLOBAL	RMS	0.0007637	0.0	0.010144		
		ABS SUM	0.0009637	0.0	0.010144		
16	GLOBAL	RMS	0.0251022	0.0	0.0103549		
		ABS SUM	0.0251022	0.0	0.0103549		
17	GLOBAL	RMS	0.0142415	0.0	0.0103775		
		ABS SUM	0.0142415	0.0	0.0103775		

522-212

RESULTS OF LATEST ANALYSES

PROBLEM - GP2 TITLE - GONALDS BRUSH PUMP FOR DETROIT EDISON - HIGH WATER CONDITION

ACTIVE MITS INCH LB CYC DFCG SEC

ACTIVE STRUCTURE TYPE PLANE FRAME

ACTIVE COORDINATE AXES X Y

EIGENVALUES

MODE	EIGENVALUE	FREQUENCY	PERIOD
1	2.492786D-01	5.146733D-01	1.942980D-00
2	1.876165D-01	4.354498D-00	2.296476D-01
3	1.726543D-02	1.325347D-01	7.545196D-02
4	1.177878D-02	1.370370D-01	7.297369D-02
5	7.260038D-02	2.698150D-01	3.706237D-02
6	2.047465D-03	6.524672D-01	2.299980D-02
7	5.875750D-03	6.690149D-01	1.494744D-02
8	7.843655D-03	8.856662D-01	1.129127D-02
9	1.091556D-04	1.235150D-02	9.615668D-03
10	4.541808D-04	2.429472D-02	3.413584D-03
11	9.551352D-04	3.070526D-02	3.235615D-03
12	9.952529D-04	3.156763D-02	3.169810D-03
13	2.312336D-05	6.918338D-02	4.239035D-03
14	2.606624D-05	5.105516D-02	1.956666D-03

EIGENVECTORS

MODE 1

JOINT	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
2	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
3	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
4	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
5	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
6	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
7	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
8	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
9	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
10	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
11	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000
12	GLOBAL	0.000000	0.0	0.000000	0.000000	0.000000

0.0002911
 0.0
 -0.0000000
 -0.0000000
 -0.0000000

0.0
 0.0
 0.0
 0.0

GLOBAL 0.002911
 GLOBAL 0.0
 GLOBAL 0.0000000
 GLOBAL 0.0000000
 GLOBAL 0.0000000

MODE 2

JOINT	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	0.0	0.0	0.0	0.0	0.0	0.0
2	0.0	0.0	0.0	0.0	0.0	0.0
3	0.0	0.0	0.0	0.0	0.0	0.0
4	0.0	0.0	0.0	0.0	0.0	0.0
5	0.0	0.0	0.0	0.0	0.0	0.0
6	0.0	0.0	0.0	0.0	0.0	0.0
7	0.0	0.0	0.0	0.0	0.0	0.0
8	0.0	0.0	0.0	0.0	0.0	0.0
9	0.0	0.0	0.0	0.0	0.0	0.0
10	0.0	0.0	0.0	0.0	0.0	0.0
11	0.0	0.0	0.0	0.0	0.0	0.0
12	0.0	0.0	0.0	0.0	0.0	0.0
13	0.0	0.0	0.0	0.0	0.0	0.0
14	0.0	0.0	0.0	0.0	0.0	0.0
15	0.0	0.0	0.0	0.0	0.0	0.0
16	0.0	0.0	0.0	0.0	0.0	0.0
17	0.0	0.0	0.0	0.0	0.0	0.0

MODE 3

JOINT	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	0.0	0.0	0.0	0.0	0.0	0.0
2	0.0	0.0	0.0	0.0	0.0	0.0
3	0.0	0.0	0.0	0.0	0.0	0.0
4	0.0	0.0	0.0	0.0	0.0	0.0
5	0.0	0.0	0.0	0.0	0.0	0.0
6	0.0	0.0	0.0	0.0	0.0	0.0
7	0.0	0.0	0.0	0.0	0.0	0.0
8	0.0	0.0	0.0	0.0	0.0	0.0
9	0.0	0.0	0.0	0.0	0.0	0.0
10	0.0	0.0	0.0	0.0	0.0	0.0
11	0.0	0.0	0.0	0.0	0.0	0.0
12	0.0	0.0	0.0	0.0	0.0	0.0
13	0.0	0.0	0.0	0.0	0.0	0.0
14	0.0	0.0	0.0	0.0	0.0	0.0
15	0.0	0.0	0.0	0.0	0.0	0.0
16	0.0	0.0	0.0	0.0	0.0	0.0
17	0.0	0.0	0.0	0.0	0.0	0.0

MODE 4

JOINT	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	0.0	0.0	0.0	0.0	0.0	0.0
2	0.0	0.0	0.0	0.0	0.0	0.0
3	0.0	0.0	0.0	0.0	0.0	0.0
4	0.0	0.0	0.0	0.0	0.0	0.0
5	0.0	0.0	0.0	0.0	0.0	0.0

JOINT	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
7	GLOBAL	0.000000	0.0			-0.000000
8	GLOBAL	0.000000	0.0			0.000000
9	GLOBAL	-0.000000	0.0			0.000000
10	GLOBAL	-0.000000	0.0			-0.000000
11	GLOBAL	-0.000000	0.0			-0.000000
12	GLOBAL	-0.000000	0.0			-0.000000
13	GLOBAL	0.0	0.0			0.0
14	GLOBAL	0.0	0.0			-0.006323
15	GLOBAL	0.0	0.0			-0.024231
16	GLOBAL	0.0	0.0			-0.034208
17	GLOBAL	0.0	0.0			0.0

NODE 5

JOINT	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	GLOBAL	0.518215	0.0			0.0231481
2	GLOBAL	0.312507	0.0			0.0230518
3	GLOBAL	0.106635	0.0			0.0227582
4	GLOBAL	-0.022315	0.0			0.0222323
5	GLOBAL	-0.284254	0.0			0.0214345
6	GLOBAL	-0.522928	0.0			0.0204041
7	GLOBAL	-0.840487	0.0			-0.0082924
8	GLOBAL	-0.207839	0.0			-0.0207483
9	GLOBAL	0.459998	0.0			-0.0011669
10	GLOBAL	0.302580	0.0			0.0206857
11	GLOBAL	-0.885767	0.0			0.0127122
12	GLOBAL	-0.913720	0.0			-0.0107173
13	GLOBAL	-0.094972	0.0			-0.0091854
14	GLOBAL	0.0	0.0			0.0
15	GLOBAL	-0.000000	0.0			0.000000
16	GLOBAL	-0.000000	0.0			0.000000
17	GLOBAL	-0.000000	0.0			0.000000

NODE 6

JOINT	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	GLOBAL	0.468820	0.0			0.0249023
2	GLOBAL	0.249114	0.0			0.0246575
3	GLOBAL	0.029495	0.0			0.0239117
4	GLOBAL	-0.174479	0.0			0.0226460
5	GLOBAL	-0.367793	0.0			0.0208308
6	GLOBAL	-0.535888	0.0			0.0185574
7	GLOBAL	-0.780957	0.0			-0.0210672
8	GLOBAL	-0.883130	0.0			-0.0051376
9	GLOBAL	0.093193	0.0			0.0239631
10	GLOBAL	-0.095680	0.0			-0.0010656
11	GLOBAL	0.184094	0.0			-0.0242987
12	GLOBAL	0.359998	0.0			0.0034770
13	GLOBAL	0.133876	0.0			0.0129017
14	GLOBAL	0.0	0.0			0.0
15	GLOBAL	0.000000	0.0			-0.000000
16	GLOBAL	0.000000	0.0			-0.000000
17	GLOBAL	0.000000	0.0			-0.000000

NODE 7

JOINT	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	GLOBAL	0.0	0.0			0.0
2	GLOBAL	0.0	0.0			0.0
3	GLOBAL	0.0	0.0			0.0
4	GLOBAL	0.0	0.0			0.0
5	GLOBAL	0.0	0.0			0.0
6	GLOBAL	0.0	0.0			0.0
7	GLOBAL	0.0	0.0			0.0
8	GLOBAL	0.0	0.0			0.0
9	GLOBAL	0.0	0.0			0.0
10	GLOBAL	0.0	0.0			0.0
11	GLOBAL	0.0	0.0			0.0
12	GLOBAL	0.0	0.0			0.0
13	GLOBAL	0.0	0.0			0.0
14	GLOBAL	0.0	0.0			0.0
15	GLOBAL	0.0	0.0			0.0
16	GLOBAL	0.0	0.0			0.0
17	GLOBAL	0.0	0.0			0.0

JOINT	GLOBAL	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	GLOBAL	-0.4386416	0.0	0.0	-0.0284363		
2	GLOBAL	-0.2078952	0.0	0.0	-0.0259355		
3	GLOBAL	0.0220194	0.0	0.0	-0.0244128		
4	GLOBAL	0.2310136	0.0	0.0	-0.0219616		
5	GLOBAL	0.4060068	0.0	0.0	-0.0185778		
6	GLOBAL	0.5421291	0.0	0.0	-0.0144914		
7	GLOBAL	-0.3461840	0.0	0.0	-0.0223610		
8	GLOBAL	-0.5581184	0.0	0.0	-0.0196901		
9	GLOBAL	0.0624277	0.0	0.0	-0.0039513		
10	GLOBAL	-0.3165320	0.0	0.0	-0.0234158		
11	GLOBAL	-0.5766293	0.0	0.0	-0.0203491		
12	GLOBAL	0.9999998	0.0	0.0	-0.0078458		
13	GLOBAL	0.1773769	0.0	0.0	0.0166421		
14	GLOBAL	0.0	0.0	0.0	0.0		
15	GLOBAL	-0.7000000	0.0	0.0	0.0000000		
16	GLOBAL	-0.0000000	0.0	0.0	0.0000000		
17	GLOBAL	-0.0000000	0.0	0.0	0.0000000		

NODE 8

JOINT	GLOBAL	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	GLOBAL	-0.478611	0.0	0.0	-0.0317404		
2	GLOBAL	-0.2036187	0.0	0.0	-0.0337845		
3	GLOBAL	0.0657630	0.0	0.0	-0.0278814		
4	GLOBAL	0.3029259	0.0	0.0	-0.0233412		
5	GLOBAL	0.4740555	0.0	0.0	-0.0174457		
6	GLOBAL	0.5736617	0.0	0.0	-0.0104937		
7	GLOBAL	-0.928777	0.0	0.0	0.0108694		
8	GLOBAL	0.4047001	0.0	0.0	-0.0235656		
9	GLOBAL	0.2825687	0.0	0.0	0.0246408		
10	GLOBAL	-0.7941051	0.0	0.0	-0.0158673		
11	GLOBAL	0.9499999	0.0	0.0	0.0007569		
12	GLOBAL	-0.9333217	0.0	0.0	0.0200506		
13	GLOBAL	-0.2169239	0.0	0.0	-0.0200130		
14	GLOBAL	0.0	0.0	0.0	0.0		
15	GLOBAL	0.0000000	0.0	0.0	-0.0000000		
16	GLOBAL	0.0000000	0.0	0.0	-0.0000000		
17	GLOBAL	0.0000000	0.0	0.0	-0.0000000		

NODE 9

JOINT	GLOBAL	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	GLOBAL	-0.3795905	0.0	0.0	-0.0268129		
2	GLOBAL	-0.149747	0.0	0.0	-0.0257657		
3	GLOBAL	0.0747536	0.0	0.0	-0.0225889		
4	GLOBAL	0.2648063	0.0	0.0	-0.0177409		
5	GLOBAL	0.3837045	0.0	0.0	-0.0116322		
6	GLOBAL	0.5528935	0.0	0.0	-0.0066320		
7	GLOBAL	-0.9697716	0.0	0.0	-0.0058188		
8	GLOBAL	0.9999998	0.0	0.0	0.0005918		
9	GLOBAL	-0.9714271	0.0	0.0	0.0035344		
10	GLOBAL	0.7544185	0.0	0.0	-0.0074503		
11	GLOBAL	-0.6554901	0.0	0.0	0.0104700		
12	GLOBAL	0.6752201	0.0	0.0	-0.0155246		
13	GLOBAL	0.1349578	0.0	0.0	0.0121061		
14	GLOBAL	0.0	0.0	0.0	0.0		
15	GLOBAL	0.0000000	0.0	0.0	-0.0000000		
16	GLOBAL	0.0000000	0.0	0.0	-0.0000000		
17	GLOBAL	0.0000000	0.0	0.0	-0.0000000		

522-212

LOW WATER CASE

ORIGONALITY WITH RESPECT TO MASS

ROW 1	0.180020000 01	-0.45717760-13	-0.442336480-23	-0.340738640-14	-0.578942390-15	-0.267713290-13
	-0.264731820-15	0.220845210-15	-0.348909810-16	0.421987450-24	-0.172171300-15	0.401914170-15
	-0.135533810-15	-0.811964280-16				
ROW 2	0.457631940-13	0.100000000 01	-0.143477560-25	0.607654660-15	0.947592700-16	-0.277047870-15
	-0.410379520-16	-0.116551730-16	0.108094960-15	-0.227010730-24	-0.199493200-16	0.211822610-15
	0.851783550-16	0.197328950-16				
ROW 3	-0.442536480-23	-0.143477560-25	0.100000000 01	0.590952010-23	0.143717240-25	-0.277498830-23
	-0.535459120-24	0.477035160-24	0.482816190-25	0.416333630-16	-0.194763350-24	-0.390508430-25
	0.319275420-24	0.275478680-25				
ROW 4	0.337110660-14	0.605916550-15	0.590952010-23	0.100000000 01	-0.797322280-15	0.376218150-15
	-0.33012700-15	-0.144632570-15	0.106034970-15	-0.397823200-24	0.187350140-15	0.108216930-15
	0.581175450-16	0.745265530-16				
ROW 5	-0.577175030-15	0.111239160-15	0.143717240-25	-0.797322280-15	0.100000000 01	0.319893960-15
	0.234251027-16	-0.2220093040-15	0.118178040-16	-0.400283210-24	0.251334900-15	0.455669840-16
	0.234486960-15	0.128830030-15				
ROW 6	-0.271127603-15	-0.290745690-15	-0.277498830-23	0.302340370-13	0.319893960-15	0.100000000 01
	-0.273214950-15	-0.266280050-15	-0.129187690-15	-0.165180670-24	-0.164798730-16	0.535697520-16
	0.241088540-15	0.577704230-16				
ROW 7	-0.283861070-15	-0.394349670-16	-0.535459120-24	-0.318972280-15	0.375318390-16	-0.272351590-15
	0.143003300 01	-0.262810610-15	-0.222044600-15	0.189005620-24	-0.416333630-16	-0.518248640-16
	0.350882240-15	-0.192684650-15				
ROW 8	0.224314650-15	0.487690980-18	0.807035160-24	-0.144686780-15	-0.206161040-15	-0.266280050-15
	-0.27755760-15	0.100000000 01	-0.304443970-15	0.257399370-24	0.138777080-16	-0.134441070-16
	0.585624150-15	-0.695624400-15				
ROW 9	-0.391769400-16	0.803323813-18	0.582818190-23	0.109329540-13	0.118178040-16	-0.129236920-15
	-0.235922393-15	-0.304443970-15	0.100000000 01	-0.842228120-24	0.867361740-17	-0.456511870-16
	0.373939370-15	-0.336701170-15				
ROW 10	0.421587450-24	-0.227010730-24	0.416333630-16	-0.397823200-24	-0.400283210-24	-0.145180670-24
	0.189005620-24	0.257399370-24	-0.842228120-24	0.100000000 01	0.312095409-22	0.869295880-23
	-0.528183720-24	-0.133019090-24				
ROW 11	-0.122550730-15	-0.164798730-16	-0.194763350-24	0.181278600-15	0.256739070-15	-0.780625540-17
	-0.416333630-16	0.138777880-16	0.954097410-17	0.312095400-22	0.100000000 01	-0.504154010-17
	0.160724500-17	-0.314439810-17				
ROW 12	0.403662810-15	0.225487010-15	-0.290950430-25	0.104488980-15	0.430462140-16	0.397258450-16
	-0.370255040-16	-0.107336020-16	-0.448927460-16	0.669295880-23	-0.444522490-17	0.100000000 01
	0.112859740-15	0.429879110-16				
ROW 13	-0.164591560-15	0.425932490-16	0.319275420-24	0.57498720-16	0.231821110-15	0.238679900-19
	0.35154050-15	0.54517060-15	0.372187490-15	-0.528149790-24	0.167225480-17	0.129326330-15
	0.100000000 01	0.202025470-15				
ROW 14	-0.101074000-15	0.188664937-16	0.252498880-23	0.729441540-16	0.124496670-15	0.540325230-15
	-0.192684650-15	-0.495612650-15	-0.337468340-15	-0.133019040-24	-0.303280150-17	0.438584520-15
	0.520363170-15	0.100000000 01				

522-212

LOW WATER CASE

---DYNAMIC ANALYSIS WITH RESONANCE TO EFFECTS---

ROW	1	0.112108750-02	-0.354037500-09	-0.376088940-24	0.511210310-09	0.971919800-09	0.112015090-08
		0.941675450-09	0.818409180-09	0.699365540-09	0.473965430-23	-0.171324040-09	0.177158000-08
		-0.143318320-08	-0.241144140-08				
ROW	2	-0.332422850-09	0.988400950-03	-0.305931690-22	0.213472130-09	-0.104699140-09	-0.413820090-10
		0.759104510-10	0.107041800-09	-0.165846010-09	-0.224383390-21	0.248210430-09	0.807968800-09
		0.533077850-09	-0.187583300-08				
ROW	3	-0.379087940-24	-0.104931690-22	0.761355330-04	0.444703370-19	0.118543700-21	-0.210594860-21
		-0.397718910-20	0.596060080-20	0.360044330-21	0.582076610-10	-0.144392200-20	-0.290701090-21
		-0.236684750-20	0.187329700-21				
ROW	4	0.516493270-09	0.196210410-09	0.444703370-19	0.911340040-04	-0.130776450-09	-0.293795210-09
		-0.319714760-09	-0.547970560-10	-0.245790940-09	-0.342988940-20	0.291038100-09	0.244540390-09
		0.222400340-08	0.675822860-09				
ROW	5	0.942669700-09	-0.127525320-09	0.118543700-21	-0.134993130-09	0.364959050-05	-0.174306790-09
		-0.291772770-04	-0.323316460-04	-0.565023580-10	-0.146119590-19	0.291038100-10	-0.199179340-09
		0.154878830-08	0.111749390-08				
ROW	A	0.104473660-08	-0.174756930-10	-0.210324860-21	-0.322576190-09	-0.211924400-09	0.899348080-05
		-0.171212320-09	-0.259490300-09	0.410604480-10	-0.164404380-19	-0.189174400-09	-0.387899490-09
		0.206102020-08	0.433970190-09				
ROW	F	0.527231010-09	0.533693490-10	-0.397718910-20	-0.351796590-09	-0.280500960-09	-0.192414970-09
		0.219062540-06	-0.213333300-09	-0.901536620-10	0.444465500-19	0.218276730-09	-0.696616100-09
		0.283363500-04	-0.157236340-08				
ROW	B	0.768974030-09	0.765210310-10	0.598060080-20	-0.805575610-10	-0.125674760-09	-0.313253600-09
		-0.202079350-09	0.396973430-06	-0.435027680-09	0.638611870-19	0.130967240-09	-0.498687310-09
		0.674475500-08	-0.589069180-08				
ROW	S	0.113324240-08	-0.164521220-08	0.302054330-21	-0.274242920-09	-0.484634000-10	0.129401000-10
		-0.890736370-10	-0.473344030-09	0.574544630-06	-0.449076290-18	-0.160071070-09	-0.375935330-09
		0.270196980-08	-0.197977430-08				
ROW	10	0.473945430-23	-0.243433900-21	0.318323150-10	-0.362988940-20	-0.146119590-19	-0.164404380-19
		0.484445530-19	0.638611870-19	-0.489396290-18	0.338795680-07	0.114522720-15	0.361934410-16
		-0.123403930-17	-0.132528390-17				
ROW	11	-0.170527510-04	0.264226640-04	-0.144392200-20	0.294029690-09	0.298272950-10	-0.185536920-09
		0.224446180-04	0.151945620-09	-0.152795110-09	0.114522720-15	0.378152000-07	-0.209181780-10
		-0.208767940-11	-0.207727170-10				
ROW	12	0.144379340-08	0.262321330-07	-0.290301090-21	0.106147450-09	-0.364409900-09	-0.631043680-09
		-0.886689300-09	-0.370694690-09	-0.473066480-09	0.341934410-16	-0.233648620-10	0.400158600-07
		0.318972180-08	0.160024700-08				
ROW	13	-0.132316220-04	0.728322080-09	0.216699750-20	0.338091970-09	0.201603870-08	0.235316200-08
		0.287923130-05	0.432712550-08	0.267931610-08	-0.171008950-17	-0.248175090-11	-0.337961700-08
		0.934235520-07	0.121335540-08				
ROW	14	-0.224202360-08	-0.344527380-10	0.167324700-21	0.760789510-09	0.123572730-08	0.501030660-09
		-0.154271650-08	-0.585575230-04	-0.193807650-08	-0.105328340-17	-0.214117390-10	0.131030740-0
		-0.161642460-08	0.122907750-08				

---DYNAMIC ANALYSIS WITH RESONANCE TO EFFECTS--- FIGURE VALUES

LOW WATER CASE

RESULTS OF LATEST ANALYSES

PROBLEM - GP2 TITLE - COMBOS BWRISH PUMP FOR DETROIT EDISON -LOW WATER CONDITION

ACTIVE UNITS INCH LB RAD DEGP SEC

ACTIVE STRUCTURE TYPE PLANE FRAME

ACTIVE COORDINATE AXES X Y

EIGENVALUES

MODE	EIGENVALUE	FREQUENCY	PERIOD
1	1.123088D-01	5.333685D-01	1.87487D-00
2	9.684090D-02	5.00365D-00	1.998540D-01
3	7.41553D-03	1.373357D-01	7.297369D-02
4	9.113400D-03	1.519360D-01	6.581718D-02
5	3.669591D-04	3.04048D-01	3.288951D-02
6	9.593481D-04	5.031244D-01	1.987564D-02
7	2.130623D-05	7.688119D-01	1.342441D-02
8	3.969738D-05	1.002770D-02	9.972374D-03
9	3.745448D-05	1.206375D-02	8.282964D-03
10	3.187457D-06	2.929472D-02	3.413584D-03
11	3.761520D-06	3.094950D-02	3.231070D-03
12	6.001544D-06	3.181732D-02	3.140947D-03
13	8.532283D-06	3.316569D-02	2.923739D-03
14	1.024078D-07	5.105573D-02	1.958644D-03

EIGENVECTORS

MODE	X DISP.	Y DISP.	Z DISP.	X ROT.	Y ROT.	Z ROT.
1	GLOBAL	0.999998	0.0			0.0029919
2	GLOBAL	0.973537	0.0			0.0229918
3	GLOBAL	0.946506	0.0			0.0229916
4	GLOBAL	0.920153	0.0			0.0229911
5	GLOBAL	0.893804	0.0			0.0229902
6	GLOBAL	0.868332	0.0			0.0229898
7	GLOBAL	0.843860	0.0			0.0229899
8	GLOBAL	0.820424	0.0			0.0229874
9	GLOBAL	0.806532	0.0			0.0229829
10	GLOBAL	0.792678	0.0			0.0229803
11	GLOBAL	0.778855	0.0			0.0229854
12	GLOBAL	0.765033	0.0			0.0229758

Simple conservative checks were made to insure that it was not necessary to include separate mass points to account for the movement of the shaft relative to the bearings. The shaft is supported at sufficiently short intervals so that this is not necessary.

The response spectra must be input into the computer in order to perform the modal analysis. Experience has shown that STRUDL does a very poor job of interpolating between specified points of the spectra. Thus, in order to avoid interpolation errors, the analysis is performed and the frequencies obtained. Then the spectra is input paying particular attention to inputting points that coincide with the frequencies.

An orthogonality check is printed out to show that the mode shapes and frequencies are accurate. The off diagonal terms in this matrix should be zero.


The computer output shows that two frequencies (3rd and 4th) are very close to each other. This should not be interpreted to mean that the square root of the sum of the squares method is not applicable for these frequencies because one of these frequencies is for the lower part of the pump and the other is for the upper part. The support makes the lower and upper parts two separate independent cantilever beams.

The damping was taken to be 2% for the OBE.

522-212

2.2 Vertical Seismic Analysis

The pump is obviously rigid in the vertical direction* except for the impeller-shaft assembly. The shaft is supported at short intervals in the lateral direction but is only supported near the motor in the vertical direction. In addition, some of the internal water is supported by the impeller. The exact amount of water supported by the impeller is difficult to determine due to friction effects, etc. Thus, in order to be conservative, the entire amount of water inside the pump is assumed to be supported by the impeller. The model is shown below.



From the response spectra curve for the OBE, the acceleration is 1.2 g for the impeller assembly and .2 g for the remainder of the pump.

* This has been proved many times in previous reports. This work will be made available upon request.

522-212

3. STRESS ANALYSIS

3.1 Introduction

The seismic loads are combined with the normal operating loads and a stress analysis is made. Since the allowable stress for the DBE loading is approximately twice that for the OBE and the DBE seismic loads are only slightly more than the OBE and in some cases less, the OBE condition is the worst case.

The piping loads on the pump are estimated in accordance with the specification. These are:

$$M_t = 400,000 \text{ in-lbs}$$

$$M_c = M_l = 200,000 \text{ in-lbs}$$

$$P = 16,000 \text{ lbs}$$

$$V_c = V_L = 4,000 \text{ lbs}$$

The nomenclature used is that of Welding Research Council Bulletin 107. The above loads are much higher than expected on this pump because the thermal gradient will be low.

3.2 Stresses in Column

The highest stresses in the pump column occur at the support and are due to seismic, pressure, and dead load. These stresses are:

Lateral Seismic

$$S_1 = 182266/30 = 6,076 \text{ psi}$$

where the moment is taken from the computer printout, page 15, and the section modulus is that of a 12" sch. 30 pipe in the corroded condition.

Vertical Seismic Plus Dead Load

522-212

Total vertical load is $P = 1.2 (7961) = 9553$ lbs

$$S_2 = 9553/9.82 = 973 \text{ psi}$$

Pressure Stress

$$S = PR/t + .6P \text{ (from ASME Code)}$$

$$= \frac{80.3(6)}{.25} + .6(80.3) = 1,975 \text{ psi Circumferential}$$

$$S_L = \frac{1}{2}(PR/t - .4P) = \frac{1}{2}(80.3(6)/.25 - .4(80.3)) = 948$$


Total Circum. Stress = 1,975 psi

Total Longitudinal Stress = 948 + 973 + 6,076 = 7,997 psi

The ASME Code allowable stress for SA 106 Gr.B is 15,000 psi. Therefore the column is adequate.

3.3 Stress Analysis of Support Flange and Bolting

The pump is subjected to overturning moments due to seismic and nozzle loads. These are shown in the worst condition in the sketch below.



The overturning moment , $M = 400,000 + 241,074 - 11.22(7961 - 1592)$
 $= 569,591$ in-lbs

522-212

The tensile stress in the bolts is:

$$S = \frac{569591}{2(22.44)(.9691)} = 13,096 \text{ psi}$$

The shearing loads are due to both seismic and nozzle loads. These are

$$V = 16,000 + 1704 = 17,704 \text{ lbs}$$

The shearing stress is:

$$S_s = 17,704 / (4(.9691)) = 4,567 \text{ psi}$$

The allowable stress for SA 193 Gr. B7 is 25,000 psi tensile. Thus the bolts are more than adequate.

3.4 Analysis of Anchor Bolts

The overturning moment on the anchor bolts is the same as for the bolts previously analyzed. The distance between the bolts is different and the bolts are different size. Thus the stress in tension is:

$$S = \frac{569591}{32(2)(.6057)} = 14,693 \text{ psi}$$

The shearing stress is:

$$S_s = 17,704 / (4(.6057)) = 7,307 \text{ psi}$$

SA 307 anchor bolts will be more than adequate.

3.5 Column Flanges and Bolting

The column is subjected to both internal pressure and external forces and moments due to seismic. The external forces are converted to equivalent internal pressure by the method given on page 170, Ref. 3.

$$P_{eq} = \frac{16M}{3.142G^3} + \frac{4F}{3.142G^2}$$

522-212

where:

M = external moment

F = external force

G = gasket diameter

$$P_{eq} = \frac{16(182266)}{3.152(15^3)} + \frac{4(7961)}{3.152(15^2)} = 320$$

The total design pressure is:

$$P = 320 + 80.3 = 400.3$$

This flange is also flat faced with metal to metal contact outside the bolt circle and is designed to ASME Section VIII, App. II, Part B.

$$A = 16.6, \quad B = 12.75, \quad C = 15, \quad t = 1.04, \quad l = 3.71, \quad r_E = 1$$

$$r_g = .5 \text{ (assumed)}, \quad B_1 = 13, \quad a = 1.181, \quad S_B = 25000, \quad G = 15$$

$$h_D = 1.125" \quad h_G = 0, \quad h_T = .5625" \quad H_D = .785(12.75)^2 (400.3) = 51,682$$

$$H_T = 19,630 \quad H = .785(15)(400.3) = 70,712$$

$$M_p = 51082(1.125) + 19630(.5625) = 68509 \text{ in-lbs}$$

The value of h_c which governs in this case is: $h_c = (A - C)/2 = .8$

$$H_c = 68509/.8 = 85,636 \text{ lbs}$$

The total bolt load is $85,636 + 70,712 = 156,348 \text{ lbs}$

The above bolt load can be broken down into two types, that caused by primary loads (pressure plus dead load plus vertical seismic) and primary bending (lateral seismic). The ASME Code does not provide allowable stresses for the stresses due to bending but AEC Regulatory Guide 1.48 does. The loads are:

Bolt loads due to primary membrane stress in pipe = 48,978 lbs

Bolt loads due to primary bending stress in pipe = 107,370 lbs

522-212

The allowable bolt loads are:

Loads due to primary membrane stress = $12(.419)(25000) = 125,700$ lbs

Loads due to primary bending stress in the pipe plus primary membrane stress (AEC Reg. Guide 1.48) = $12(.419)(25000)(1.5) = 188,550$ lbs

$$48,978 < 125,700$$

$$156,348 < 188,550$$

Thus, the bolts are adequate.

Flange Stresses

$$EOA = \frac{(1)(.5)(25000)(3.68)}{16.6 - 15} - \frac{.29(16.6 - 15)(68509)}{13.(1.81)(1.04)^3}$$

$$= 27,549 \text{ psi}$$

$$S_R = \frac{6(68509)}{(1.04)^2(3.14(15) - 12(1))} = 10,827 \text{ psi}$$

$$S_T = \frac{5.46(68509)}{12.75(1.04)^2} \left[.318 \left(\frac{2.25}{27.75} + \frac{2(.8)}{31.6} + .075 \right) \right] + \frac{27549(1.04)}{12.75}$$



$$= 5,418 \text{ psi}$$

The ASME Code allowable stress for SA 283 Gr. D is 12,600 psi. Thus the flanges are adequate.

3.6 Analysis of Motor Bolting

The motor is fastened to the mount by 4 - 5/8" screws of AISI C 1018 material on a 14.75" B. C. The moment caused by lateral seismic is 20,679 in-lbs from page 15.

522-212



$$M = 20,579 - 5.21(3600 - 720) = 5,674 \text{ in-lbs}$$

The tensile stress is:

$$S = \frac{5,674}{2(10.42)(.2260)} = 1,205 \text{ psi}$$

The shearing load from page 15 is 985 lbs.

Thus the shearing stress is:

$$S_s = \frac{985}{4(.226)} = 1,090 \text{ psi}$$

The AISI C 1018 bolts are more than adequate for these loads.

3.7 Stresses in Shaft

The stresses in the shaft are caused by normal torsion, normal downthrust, seismic bending due to lateral moment, and axial load due to vertical seismic. The shaft is weakest at the threaded end where it engages the coupling. The most highly stressed location is the coupling near where the moment is highest. This is near the support, thus the moment is 182,265 in-lbs from page 15. The minimum root diameter of the threads is 2.0792"

$$I = \frac{3.142(2.0792)^4}{64} = .9174 \quad J = 2I = 1.835 \text{ in.}^4$$

522-212

The torque $T = \frac{63000(300)}{1800} = 10,500$ in-lbs

The shearing stress due to torque is:

$$S_1 = \frac{10500(2.0792)}{1.835 (2)} = 5,949 \text{ psi}$$

The vertical seismic load on the shaft due to weight of the shaft plus internal fluid is:

$$1.2(2681) = 3217 \text{ lbs}$$

The total axial load on the shaft, conservatively is:

Dead load	2681
seismic	3217
downthrust	<u>15000</u>
	20898

Axial stress is:

$$S_2 = 20898/(3.40) = 6,146 \text{ psi}$$

Bending stress in shaft:

$$S_3 = \frac{182,266 (1.04)}{185.67} = 1,020 \text{ psi}$$

The total tensile stress is:

$$S = 6146 + 1020 = 7,166 \text{ psi}$$

The combined stress is:


$$S_C = \sqrt{(7166)^2 + (2(5949))^2} = 13,889 \text{ psi}$$

The maximum normal stress in the shaft is 13,889 psi and the maximum shearing stress is 6,949 psi. The ASME Code does not provide stress values to be used for the design of shafts. An allowable of 15000 psi is established for the A-582 TP 416 shaft, which is in accordance with the general stress limits of the Code.

522-212

3.8 Deflections in Shaft

Good practice in transmission shaft design limits the maximum deflection to .01 inches per foot to prevent excessive wear on the bearings (see Ref. 5). As mentioned before, the shaft is supported such that it is rigid between the bearings insofar as the seismic analysis is concerned. However, the shaft will experience accelerations imposed by the bearing supports and must be checked for resulting deflections. It is clear that the maximum total acceleration of the bearings would be less than $1g$. This analysis will be made for the conservative value of $1g$ and the shaft will be taken as simply supported at the bearings.



$$\text{Defl. @ midpoint} = \frac{5(1.06)(60)^4}{384(29000000)(.9174)} = .0067''$$

The above deflection is well within acceptable limits.

3.9 Stresses in Coupling

The maximum loads in the coupling are the same as those previously applied to the shaft (Article 3.5, page 27). The coupling has the following dimensions:

$$\text{O.D.} = 2.75'' \quad \text{Length} = 5.5'' \quad \text{Root thd. dia.} = 2.1875''$$

Therefore:

$$I = \frac{3,142((2.75)^4 - (2.1875)^4)}{64} = 1.6834 \text{ in.}^4$$

$$J = 2I = 3.3667$$

$$A = \frac{3.142((2.75)^2 - (2.1875)^2)}{4} = 2.181 \text{ in.}^2$$

$$S_1 = \frac{10500(1.375)}{3.3667} = 4288 \text{ psi}$$

$$S_2 = 20898/2.181 = 9582 \text{ psi}$$

$$S_3 = \frac{182266(1.375)}{185.67} = 1350 \text{ psi}$$

$$S = 9582 + 1350 = 10932 \text{ psi}$$

$$S_c = \sqrt{(10932)^2 + (2(4288))^2} = 13,894 \text{ psi}$$

The allowable stress for ASTM A-582 TP 416 is 15000 psi. Thus, the coupling is adequate.

The thread engagement of the coupling is more than the diameter of the threads, thus the full strength of the coupling is developed.

3.10 Column Deflections

Excessive column deflections can cause wear on the solid bearings and must, therefore, be kept within tolerances. The most critical joint is 13 because the bearing located at the support cannot undergo rotation. Thus the deflection at joint 13 causes the shaft to bend at the bearing. The deflection of joint 13 is .0058" (from page 16). The span is 18.75", thus the deflection is less than the .01 inch/foot given by Ref. 5.

522-213

3.11 Nozzle Loads

As mentioned previously, the nozzle loads assumed for this pump in accordance with the specification are fairly high. This is a low temperature system, therefore, the piping loads are expected to be much lower than those previously assumed. The reinforcement of this nozzle due to internal pressure is covered by the ASME Code, and no reinforcement is required. The ASME Code does not cover the stresses in the nozzle caused by external loads. There is no analysis method available at this time (known to this analyst) which covers these stresses. Welding Research Council Bulletin 107 is widely used but it is limited to nozzles which do not exceed half the size of the vessel. Nevertheless, an estimate of the stresses can be made by WRC Bulletin 107.

$$Y = 6.87/.25 = 27.48$$

$$\beta = \frac{.875(6.25)}{6.87} = .796$$

This gives a longitudinal stress of:


$$S = 130,000 \text{ psi}$$

This is much too high, of course. The Code does not give limits for a discontinuity stress of this type but SC is often used, which in this case would be 45,000 psi. Thus, the nozzle will withstand loads of approximately one third of those specified without a reinforcing pad. A 16" O.D. pad will be required for the loads given by the specification. However, it is recommended that this pad not be added until firm nozzle loads are received.

502-212

3.18 Impeller Clearance

The impeller clearance relative to the pump casing or wear ring is checked by assuming that the shaft is simply supported at the bearings and a 80-seismp load is applied. This a conservative approach.



The deflection is:

$$D = \frac{786(17.88)^3}{48(29000000)(2.33)} = .0003"$$

The impeller clearance is .018", thus o.k.

503-272

Appendix A - References

1. McDonald, C. K. , Course Notes for Short Course entitled "Dynamic Seismic Analysis of Nuclear Power Plant Components", The University of Alabama in Birmingham, 1973.
2. Frits, R. J. , "The Effects of Liquids on the Dynamic Motions of Immersed Solids", Jr. of Engr. for Industry, ASME, Feb., 1972, pp 167-173.
3. ASME Boiler and Pressure Vessel Code, Sect. III, Nuclear Power Plant Components, 1971.
4. ASA B17.C, Code for Design for Transmission Shafting (being updated).
5. Machinery's Handbook, 15th Edition, 1956, p507.

520-212