

October 8, 1982

Docket No. 50-329

Docket No. 50-330

Consumers Power Company

ATTN: Mr. D. B. Miller

Site Manager

P. O. Box 1963

Midland, MI 48640

SUBJECT: PROOF LOADJACKING OF FIVP

REFERENCES: CPCo LETTER DATED JUNE 18, 1982

NRC LETTER DATED JUNE 30, 1982

CPCo LETTER DATED SEPTEMBER 21, 1982

Dear Mr. Miller:

RIII and NRR have reviewed your request to delete the requirement for four point proof jacking of the feedwater isolation valve pit (FIVP). We believe it is an essential and inherent part of the remedial action to be achieved prior to excavation beneath the FIVP for the following reasons:

- (1) The original jacking accomplished in early 1981 is no longer valid due to the modifications made to reinforce the support systems.
- (2) The previous proof load jacking performed by individual lift offs of the rock bolts and rods is also unacceptable to ensure the overall integrity of the complete support systems.
- (3) We have not been able to substantiate your conclusion that performing the four point jacking will change the tensions in the individual rock anchors and rods.

8210150441 821008
PDR ADOCK 05000329
A PDR

1201

OFFICE ▶							
SURNAME ▶							
DATE ▶							

In conclusion, the staff still requires accomplishment of the four point proof load jacking of the FIVP prior to excavation beneath it.

Sincerely,

R. F. Warnick, Acting Director
Office of Special Cases

- cc: DMB/Document Control Desk (RIDS)
- Resident Inspector, RIII
- The Honorable Charles Bechhoefer, ASLB
- The Honorable Jerry Harbour, ASLB
- The Honorable Frederick P. Cowan, ASLB
- The Honorable Ralph S Decker, ASLB
- William Paton, ELD
- Michael Miller
- Ronald Callen, Michigan
- Public Service Commission
- Myron M. Cherry
- Barbara Stamiris
- Mary Sinclair
- Wendell Marshall
- Colonel Steve J. Gadler (P.E.)

*This was discussed
by Landsman with
Joe Kane.
RW*

OFFICE ▶	RIII					
SURNAME ▶	Landsman/le	Gardner	Shafer	Warnick		
DATE ▶	10/8/82			10/8/82		