

APPENDIX A
NOTICE OF VIOLATION

Omaha Public Power District
Fort Calhoun Station

Docket: 50-285
License: DPR-40

During an NRC inspection conducted June 17 through July 28 and August 1, 1990, a violation of NRC requirements was identified. The violation involved surveillance testing of emergency diesel generators (EDGs). In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1990) (Enforcement Policy), the violation is listed below:

Failure to Adequately Perform a Surveillance Test

Technical Specification 3.7(i)c.iii states, "Tests shall be conducted during each refueling outage to demonstrate the satisfactory overall automatic operation of each diesel system. This test shall be conducted by verification that emergency loads do not exceed the 2000 hr-kW rating of the engine."

Contrary to the above, the licensee failed, during the 1990 refueling outage, to verify that emergency loads do not exceed the 2000 hr-kW rating of the EDG in that a load profile for emergency loads was not determined for the equipment when operating in an emergency condition.

This is a Severity Level IV violation. (Supplement I) (285/9032-01)

Pursuant to the provisions of 10 CFR Part 2.201, the Omaha Public Power District is hereby required to submit to this office, within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the reason for the violation if admitted, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington, Texas,
this *16th* day of *August* 1990