



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, P.O. Box 15830, Sacramento CA 95852-1830, (916) 452-3211
AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

AGM/NUC 90-224

August 15, 1990

RECEIVED
NRC
REGION V
1990 AUG 16 AM 10:27

U. S. Nuclear Regulatory Commission
Attn: J. B. Martin, Regional Administrator
Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596

Docket No. 50-312
Rancho Seco Nuclear Generating Station
License No. DPR-54
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Dear Mr. Martin:

As a condition of the approval of Amendment No. 45 to Facility Operating License No. DPR-54, the District agreed to provide the NRC with a copy of any changes to the NPDES discharge permit and any permit violations. Attached is a copy of the July 1990 Discharger Self Monitoring Report. This report makes note of a water quality violation. High Coliform on July 9 and 10 is attributed to a low chlorine residual caused by chlorine disinfection equipment problems.

Members of your staff with questions requiring additional information or clarification may contact Mr. Mark Leinwander at (209) 333-2935, extension 4927.

Sincerely,

Dan R. Keuter
Assistant General Manager
Nuclear

Attachment

cc: A. D'Angelo, NRC, Rancho Seco
Document Control Desk, NRC, Washington, DC

9008270103 900815
PDR ADI0CK 05000312
R PDC